



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/06/2024

L-30330

Permit # 000049146


Re: 33-3S-17-06475-000 / Lots 3, 4, & 5 Block B Duval Heights

Orange State Towing

To Whom It May Concern:

The finished floor elevation is found to be 188.81 feet. The Construction plans show a minimum floor elevation of 188.80 feet. All elevations are shown in NAVD 88 datum.

Sincerely,


L. Scott Britt
LS-5757