



Affine Engineering and Surveying, Inc.

Date:3/14/2022

Mr. Kevin Bedenbaugh, Jr

Plumb Level Construction

386.365.5264


Re: Elevation Letter– Lot 11 The Oaks Of Lake City Phase I.

SUBJECT:

FINISH FLOOR HEIGHT VERIFICATION

To whom it may concern,

During a field survey conducted 3/14/2022 on Lot 11, Oaks of Lake City Phase I – Parcel 17-5S-17-09280-111, the finish floor of the existing structure was measured. According to the Oaks of Lake City Phase I plat the minimum floor elevation is 77 feet. Based on the field survey, it was found that the Finish Floor is at elevation 92.37 feet. Elevations are referenced to the plans of OAKS OF LAKE CITY as prepared by GCT Design Group having an elevation. Assumed datum



Victor O. Marrero, PE, PSM

Florida PSM 6586