

FIELD DENSITY WORKSHEET

CLIENT McCoy Construction DATE 10.30.24
 PROJECT NO. _____
 PROJECT NAME 240 sw Iowa Dr. Fort white PERMIT NO. _____
 EARTH CONTRACTOR _____ TESTED BY CB
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor ☐ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
NW Corner	113.1	10.5	1/1	12	4.9	116.1	110.7	97.9
SW			1/1		4.0	113.9	109.5	96.8
NE			1/1		4.4	114.5	109.7	97.0
SE			1/1		3.6	114.2	110.2	97.4
approximate Center			1/1		4.2	113.6	109.0	96.4

REMARKS _____

- * Density failed to meet minimum project requirement
- ** Retest indicates minimum density requirement was obtained.
- () Client is aware of unsatisfactory test results.