

Bounds Heating and Air Inc  
Lic:CA-C057642 MQ # LQ4452  
25645 W Newberry Road  
Newberry, FL 32669



Phone: (352) 472-2761  
bounds\_hvac@yahoo.com  
www.boundshvac.com

Phone Number:

Email Address:

Bill to  
**Amira Custom Homes**  
20757 NW 100th Ln  
Alachua, FL 32615

Ship to  
**Amira Blackburn 25-089**  
1199 SW Marynik Dr  
High Springs, FL 32643

Work Order #: 166981

Assigned Tech: Julius J.

Task: New Const Misc

Completion Date: 10/6/2025

## Blower Door Test Form

Blower Door Test Form

### Air Filtration Test Results

1. CFM (50) =	1866
2. VOLUME =	23811
3. ACH (50)= CFM (50) X 60 / VOLUME =	4.7
4. Double check grills, pick up all trash including dry wall debris. Do final walk through of home.	<input checked="" type="checkbox"/>
5. Pass Fail (more than 7 ACH)	PASS
6. Pass Fail (more than 7 ACH)	<input checked="" type="checkbox"/> PASS

*Passing results of 3-7 ACH, does not require mechanical ventilation. Less than 3 ACH will require mechanical ventilation.*

7. Certification of Test Results R402.4.1.1 Testing.