

**Mark Disosway, P.E.**

163 SW Midtown Place, Suite 103 Lake City, FL 32025, Ph (386) 754-5419

2/11/20

Columbia County Building Department

Re: B&B Homes | Blackwell, Donnie & Sheila Res. | 237 Hill Creek Drive Lake City, FL

To whom it may concern:

This letter is in reference to inspection issues on the above referenced project.

1. The builder added a 3' door on the left side wall of the game room @ the rear of the house. Header is (2) 2x10 sp #2 1 jack & 1 king stud each side. Please accept this letter as an addendum to allow this door.

Mark Disosway, PE  
Florida Professional Engineer #53915

THIS PDF HAS DIGITAL SIGNATURE  
AND ELECTRONIC SEAL. **PRINTED  
COPIES ARE NOT CONSIDERED  
SIGNED OR SEALED.** YOU MUST  
VERIFY SIGNATURE ON THIS PDF.  
[CLICK HERE TO VERIFY.](#)

