

DATE 12/17/2008

Columbia County Building Permit

This Permit Must Be Prominently Posted on Premises During Construction

PERMIT
000027525

APPLICANT CHARLOTTE COLLINS PHONE 754-0093
ADDRESS 795 SW NORRIS AVE LAKE CITY FL 32024
OWNER CHARLOTTE COLLINS PHONE 754-0093
ADDRESS 238 SW SHELLCRACKER DR FT. WHITE FL 32038
CONTRACTOR RONNIE NORRIS PHONE 752-3871
LOCATION OF PROPERTY 47S, TR ON WILSON SPRINGS RD, TL NEWARK, STRAIGHT
TO SHELLCRACKER, 1ST VACANT LOT ON RIGHT
TYPE DEVELOPMENT MH, UTILITY ESTIMATED COST OF CONSTRUCTION 0.00
HEATED FLOOR AREA TOTAL AREA HEIGHT STORIES
FOUNDATION WALLS ROOF PITCH FLOOR
LAND USE & ZONING A-3 MAX. HEIGHT
Minimum Set Back Requirments: STREET-FRONT 30.00 REAR 25.00 SIDE 25.00
NO. EX.D.U. 0 FLOOD ZONE X DEVELOPMENT PERMIT NO.

PARCEL ID 01-7S-15-01439-711 SUBDIVISION WILSON SPRINGS COMMUNITY
LOT 7 BLOCK 11 PHASE UNIT TOTAL ACRES 1.99

IH0000049 Charlotte Collins
Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor
WAIVER 08-721 BK WR Y
Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: ONE FOOT ABOVE THE ROAD

Check # or Cash 1442

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power Foundation Monolithic
date/app. by date/app. by date/app. by
Under slab rough-in plumbing Slab Sheathing/Nailing
date/app. by date/app. by date/app. by
Framing Rough-in plumbing above slab and below wood floor
date/app. by date/app. by
Electrical rough-in Heat & Air Duct Peri. beam (Lintel)
date/app. by date/app. by date/app. by
Permanent power C.O. Final Culvert
date/app. by date/app. by date/app. by
M/H tie downs, blocking, electricity and plumbing Pool
date/app. by date/app. by
Reconnection Pump pole Utility Pole
date/app. by date/app. by date/app. by
M/H Pole Travel Trailer Re-roof
date/app. by date/app. by date/app. by

BUILDING PERMIT FEE \$ 0.00 CERTIFICATION FEE \$ 0.00 SURCHARGE FEE \$ 0.00
MISC. FEES \$ 300.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ 64.20 WASTE FEE \$ 167.50
FLOOD DEVELOPMENT FEE \$ FLOOD ZONE FEE \$ 25.00 CULVERT FEE \$ TOTAL FEE 606.70
INSPECTORS OFFICE GALE T. EDOLIN CLERKS OFFICE CH

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

EVERY PERMIT ISSUED SHALL BECOME INVALID UNLESS THE WORK AUTHORIZED BY SUCH PERMIT IS COMMENCED WITHIN 180 DAYS AFTER ITS ISSUANCE, OR IF THE WORK AUTHORIZED BY SUCH PERMIT IS SUSPENDED OR ABANDONED FOR A PERIOD OF 180 DAYS AFTER THE TIME THE WORK IS COMMENCED. A VALID PERMIT RECIEVES AN APPROVED INSPECTION EVERY 180 DAYS. WORK SHALL BE CONSIDERED TO BE IN ACTIVE PROGRESS WHEN THE PERMIT HAS RECIEVED AN APPROVED INSPECTION WITHIN 180 DAYS.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

10,000.00
70.00
10.00

This Instrument Prepared by & return to:
Name: M BRYAN, an employee of
TITLE OFFICES, LLC
Address: 343 NW COLE TERRACE, SUITE 101
LAKE CITY, FLORIDA 32055
File No. 08Y-10001

Inst:200812019428 Date:10/23/2008 Time:4:11 PM
Doc Stamp-Deed:0.70
DC, P. DeWitt Cason, Columbia County Page 1 of 2 B:1160 P:2651

Inst:200812019080 Date:10/17/2008 Time:12:12 PM
Doc Stamp-Deed:70.00
DC, P. DeWitt Cason, Columbia County Page 1 of 1 B:1160 P:1762

Parcel I.D. #: 01439-000 (parent)

SPACE ABOVE THIS LINE FOR PROCESSING DATA

SPACE ABOVE THIS LINE FOR RECORDING DATA

THIS WARRANTY DEED Made the 14th day of October, A.D. 2008, by WILSON SPRINGS, INC., A FLORIDA CORPORATION having its principal place of business at 321 N. MARION AVE., LAKE CITY, FL 32055, hereinafter called the grantor, to CHARLOTTE COLLINS, whose post office address is 795 SW NORRIS AVE., LAKE CITY, FL 32024, hereinafter called the grantee:

(Wherever used herein the terms "grantor" and "grantee" include all the parties to this instrument, singular and plural, the heirs, legal representatives and assigns of individuals, and the successors and assigns of corporations, wherever the context so admits or requires.)

Witnesseth: That the grantor, for and in consideration of the sum of \$10.00 and other valuable consideration, receipt whereof is hereby acknowledged, does hereby grant, bargain, sell, alien, remise, release, convey and confirm unto the grantee all that certain land situate in Columbia County, State of Florida, viz:

See Attached Exhibit A


Together with all the tenements, hereditaments and appurtenances thereto belonging or in anywise appertaining.

To Have and to Hold the same in fee simple forever.

And the grantor hereby covenants with said grantee that it is lawfully seized of said land in fee simple; that it has good right and lawful authority to sell and convey said land, and hereby fully warrants the title to said land and will defend the same against the lawful claims of all persons whomsoever, and that said land is free of all encumbrances, except taxes accruing subsequent to December 31, 2008.

In Witness Whereof, the said grantor has caused these presents to be executed in its name and its corporate seal to be hereunto affixed by its proper officers thereunto duly authorized, the day and year first above written.


Signed, sealed and delivered in the presence of:


Witness Signature Regina Simpkins

Printed Name

Witness Signature PATRICIA LANG
Printed Name


WILSON SPRINGS, INC.

By:  L.S.
Name: HUGH WILSON
Title: President

STATE OF FLORIDA
COUNTY OF COLUMBIA

The foregoing instrument was acknowledged before me this 14th day of October, 2008, by HUGH WILSON as President of WILSON SPRINGS, INC., a Florida corporation. He (she) is personally known to me or has produced _____ as identification.


PATRICIA H. LANG
Commission DD 622516
Expires December 14, 2010
Bonded Thru Troy Pain Insurance 800-385-7019


Notary Public
My commission expires 12-14-10
My commission expires _____

This deed is being rerecorded to add the "Exhibit A".

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

ND 12-16-08

For Office Use Only

(Revised 1-10-08)

Zoning Official

RLK 17-12-08

Building Official

12/9/08

AP#

0812-11

Date Received

12-8-08

By

GT

Permit #

27525 11696

Flood Zone

XE

Development Permit

ni...

A-3

and then Plan Map Category

A-3

Comments

FEMA Map#

Elevation

Finished Floor

River

In Floodway

☒ Site Plan with Setbacks Shown

☒ EH#

☐ EH Release

☒ Well letter

☐ Existing well

☒ Recorded Deed or Affidavit from land owner

☐ Letter of Auth. from installer

☐ State Road Access

☐ Parent Parcel #

☐ STUP-MH

☐ F W Comp. letter

IMPACT FEES: EMS

29.88

Fire

78.63

Corr

442.89

Road/Code

1046.00/210

School

1500.00

= TOTAL

3097.40

Lot 11, Block 7

Lot 7 BIK. 11

Property ID #

01-75-15-01439-711

Subdivision

Wilcox Spring Community Phase 4

☒ New Mobile Home

☐ Used Mobile Home

MH Size

28X52 Year 2008

Applicant

Charlotte Collins

Phone #

386-754-0093

Address

795 S.W. Norris Ave. Lake City, Fla. 32024

Name of Property Owner

Charlotte Collins

Phone#

386-754-0093

911 Address

238 S.W. Shellcracker Dr. Fort White, 32038

Circle the correct power company -

FL Power & Light

-

Clay Electric

(Circle One) -

Suwannee Valley Electric

-

Progress Energy

Name of Owner of Mobile Home

Charlotte Collins

Phone #

386-754-0093

Address

795 S.W. Norris Ave. Lake City, Fla. 32024

Relationship to Property Owner

Self

Current Number of Dwellings on Property

0

Lot Size

Total Acreage

1.99 ac

Do you : Have

Existing Drive

or Private Drive

or need Culvert Permit

or Culvert Waiver

(Circle one)

(Currently using)

(Blue Road Sign)

(Putting in a Culvert)

(Not existing but do not need a Culvert)

Is this Mobile Home Replacing an Existing Mobile Home

No

Driving Directions to the Property

from Lake City - 47 South to Ft. White. turn right on 27 - left on Wilcox Spring Rd. to Pope's store. turn left & 2nd go straight to Shellcracker - 1st vacant lot on right that's been cleared.

Newark

Name of Licensed Dealer/Installer

Ronnie Norris

ie #

752-3871

Installers Address

1004 SW Charles Terr. LC, FL 32024

License Number

IH0000049

Installation Decal #

300440

352-494-8099

PERMIT WORKSHEET

PERMIT NUMBER

Installer Lanvienne Norris License # TH0000049


Address of home being installed _____

Manufacturer Town Homes Length x width 28 x 60

NOTE: if home is a single wide fill out one half of the blocking plan
if home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used) where the sidewall ties exceed 5 ft 4 in.

Installer's initials RN



New Home ☒ Used Home ☐
Home installed to the Manufacturer's Installation Manual ☒
Home is installed in accordance with Rule 15-C ☐
Single wide ☐ Wind Zone II ☒ Wind Zone III ☐
Double wide ☒ Installation Decal # 300440
Triple/Quad ☐ Serial # _____

PIER SPACING TABLE FOR USED HOMES

Load bearing capacity	Footer size (sq in)	16' x 16' (256)	18 1/2' x 18 1/2' (342)	20' x 20' (400)	22' x 22' (484)	24' x 24' (576)	26' x 26' (676)
1000 dsf	3'	4'	4'	5'	6'	7'	8'
1500 dsf	4' 6"	6'	6'	7'	8'	8'	8'
2000 dsf	6'	8'	8'	8'	8'	8'	8'
2500 dsf	7' 6"	8'	8'	8'	8'	8'	8'
3000 dsf	8'	8'	8'	8'	8'	8'	8'
3500 dsf	8'	8'	8'	8'	8'	8'	8'

* Interpolated from Rule 15C-1 pier spacing table.

PIER PAD SIZES

I-beam pier pad size 17 x 25
Perimeter pier pad size 6 x 16
Other pier pad sizes (required by the mfg.) 17 x 25

POPULAR PAD SIZES

Pad Size	Sq in
16 x 16	256
18 x 18	324
18 1/2 x 18 1/2	342
16 x 22 1/2	360
17 x 22	374
13 1/4 x 26 1/4	348
20 x 20	400
17 3/16 x 25 3/16	441
17 1/2 x 25 1/2	446
24 x 24	576
26 x 26	676

Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 foot and their pier pad sizes below.

Opening 5 Pier pad size 17 x 25
4 17 x 25
4 17 x 25

ANCHORS 5 ft
FRAME TIES within 2' of end of home spaced at 5' 4" oc

TIEDOWN COMPONENTS

Longitudinal Stabilizing Device (LSD)
Manufacturer _____
Longitudinal Stabilizing Device w/ Lateral Arms
Manufacturer _____

OTHER TIES

Number
Sidewall 2
Longitudinal 6
Marriage wall 4
Shearwall 4

PERMIT WORKSHEET

page 2 of 2

PERMIT NUMBER

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to 1500 psi or check here to declare 1000 lb. soil without testing.

x 1500 x 1500 x 1500

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 6 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

x 1500 x 1500 x 1500

TORQUE PROBE TEST

The results of the torque probe test is 275 inch pounds or check here if you are declaring 5" anchors without testing showing 275 inch pounds or less will require 4 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. I understand 5 ft. anchors are required at all centerline tie points where the torque test reading is 275 or less and where the mobile home manufacturer may require anchors with 4000 lb. holding capacity.

Installer's initials

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name

Date Tested

12-8-08

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg.

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg.

Connect all potable water supply piping to an existing water meter, water tap, or other independent water supply systems. Pg.

Site Preparation

Debris and organic material removed ☒ Swale ☐ Pad ☐ Other ☐

Fastening multi wide units

Floor: Type Fastener: Ln Length: 6 Spacing: 24" on center
Walls: Type Fastener: metalic Length: 6 Spacing: 24" on center
Roof: Type Fastener: 30 gauge Length: 6 Spacing: 24" on center
For used homes 30 gauge, 8" wide, galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherstripping requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's initials

Type gasket Pg.

Installed:

Between Floors ☒ Yes
Between Walls ☒ Yes
Bottom of ridgebeam ☒ Yes

Weatherproofing

The bottomboard will be repaired and/or taped. Yes Pg.
Siding on units is installed to manufacturer's specifications. Yes
Fireplace chimney installed so as not to allow intrusion of rain water. Yes

Miscellaneous

Skirting to be installed. Yes No
Dryer vent installed outside of skirting. Yes N/A
Range downflow vent installed outside of skirting. Yes
Drain lines supported at 4 foot intervals. Yes
Electrical crossovers protected. Yes
Other:

Installer verifies all information given with this permit worksheet is accurate and true based on the

Installer Signature

Date

12-16-08



I-BEAM BLOCKING
SEE SOIL BEARING CAPACITY CHARTS FOR SPACING

COLUMN BLOCKING
SEE SOIL BEARING CAPACITY CHARTS FOR PAD SIZE

SHEARWALL BLOCKING

SHEARWALL FRAME TIE


CENTER LINE TIES

LONGITUDINAL TIES



BLOCKING LEGEND:

- 1) ALL EXTERIOR DOORS, BAY WINDOWS, RECESSED SIDEWALLS AND EXTERIOR WALL OPENINGS 48" OR GREATER, WILL REQUIRE BLOCKING ON EACH SIDE.
- 2) 32" WIDE HOMES REQUIRED TO BE BLOCKED MIN 8'-0" ON CENTER BETWEEN COLUMNS.



TownHomes
P.O. BOX 1059
LAKE CITY, FLORIDA
32058

Date: 10-2-07

Revisions

Code: 28284

Dy'n: RCB

Parent: NEW

Code: T (07)

Model: 2828-183

Zone: 1

Print: BLOCKING PLAN


LETTER OF AUTHORIZATION TO PULL PERMITS

I, Ronnie Norris, DO HEREBY GRANT
Charlotte Collins, AUTHORIZATION TO PULL TE
NECESSARY PERMITS REQUIRED FOR THE DELIVERY AND SET OF A
MANUFACTURED HOME IN Columbia COUNTY, FLORIDA.
Ronnie Norris
SIGNATURE

THIS FOREGOING INSTRUMENT WAS ACKNOWLEDGED BEFORE ME THIS
16 DAY OF December, 2008.
BY Ronnie Norris, WHO IS PERSONALLY KNOWN TO ME.


STATE OF FLORIDA
COUNTY OF Columbia

Rebecca L. Arman
NOTARY PUBLIC




(STAMP)

SITE PLAN EXAMPLE / WORKSHEET



Use this example to draw your own site plan. Show all existing buildings and any other homes on this property and show the distances between them, Also show where the roads or roads are around the property. This site plan can also be used for the 911 Addressing department if you include the distance from the driveway to the nearest property line.



Lynch Well Drilling, Inc.

173 SW Young Place
Lake City, FL 32025
www.lynchwelldrilling.com

December 3, 2008

To Whom It May Concern:

As required by building code regulations for Columbia County in order that a building permit can be issued:

Size of Pump Motor:	1 Horse Power
Size of Pressure Tank:	81 -Gallon Bladder Tank
Cycle Stop Valve Used:	No
Constant Pressure System:	No

Should you require any additional information, please contact us.

Sincerely,



Linda Newcomb
Lynch Well Drilling, Inc.

WILSON ACRES

WILSON
SPRINGS
COMMUNITY
PHASE 3

NE
Sec.
NW
Sec.

744.32'
N 87°44'00" E

N 81°07'53" E 1057.29'
JAY ROAD

N 89°28'24" E
S 44°23'06" W
19.05'

737.09'

750.75'

714.23'

823.83'

823.33'

13-1
7.0 ACRES

7-14
2.11 ACRES

7-10
2.25 ACRES

7-11
1.99 ACRES

7-12
1.89 ACRES

7-13
1.11 ACRES

COMMONS
2.75 ACRES

7-9
3.80 ACRES


7-8
2.72 ACRES

7-7
1.21 ACRES

WILSON SPRINGS COMMUNITY
PHASE 2

EAST
EAST

8-1
3.25 ACRES
8-2
6.74 ACRES
8-3
6.74 ACRES



"EXHIBIT A"

BLOCK 7 - LOT 11

COMMENCE at the Northeast corner of the Southeast 1/4 of Section 1, Township 7 South, Range 15 East, Columbia County, Florida and run South $88^{\circ}10'31''$ West along the North line of said Southeast 1/4 of Section 1, being also the North line of Wilson Springs Community Phase 2, a distance of 33.01 feet to a point on the West line of Wilson Springs Road as deeded to County, being also the East line of Wilson Springs Community Phase 2; thence North $00^{\circ}15'08''$ West along said West line of Wilson Springs Road as deeded to County a distance of 32.85 feet; thence South $44^{\circ}23'06''$ West along the West line of Wilson Springs Community Phase 2 a distance of 19.06 feet; thence South $33^{\circ}20'10''$ West along said West line a distance of 127.29 feet; thence South $13^{\circ}50'26''$ West still along said West line a distance of 201.28 feet; thence South $36^{\circ}15'19''$ West still along said West line a distance of 100.83 feet; thence South $45^{\circ}36'37''$ West still along said West line a distance of 159.64 feet to the POINT OF BEGINNING; thence South $65^{\circ}38'07''$ West still along said West line a distance of 134.90 feet; thence North $24^{\circ}13'10''$ West a distance of 566.04 feet; thence North $81^{\circ}07'53''$ East a distance of 190.00 feet; thence South $18^{\circ}51'48''$ East a distance of 517.66 feet to the POINT OF BEGINNING.

@ CAM110M01 S CamaUSA Appraisal System
12/17/2008 9:23 Property Maintenance
Year T Property Sel
2009 R 01-7S-15-01439-711 ... *
Owner COLLINS CHARLOTTE Conf
Addr 795 SW NORRIS AVE

Columbia County
18715 Land 001 *
AG 000
Bldg 000
Xfea 000
18715 TOTAL B*

-Cap?- 1.990 Total Acres
SOH 10% ApYr ERnwl ARnwl S/C Notc

City,St LAKE CITY FL Zip 32024 N
Country (PUD1) (PUD2) (PUD3) MKTA02
pud4 pud5 pud6

Appr By SCCP Date 4/09/2008 AppCode UseCd 000000 VACANT
TxDist Nbhd MktA ExCode Exemption/% TxCode Units Tp
003 1715.02 02

WILSON ACRES UNR

House# Street MD Dir #
City

Subd N/A Condo .00 N/A

Sect 1 Twn 7S Rnge 15E Subd Blk Lot

Legals (AKA LOT 11, BLOCK 7, WILSON SPRINGS COMMUNITY PHASE 4 UNR)
COMM AT NE COR OF SE1/4 OF SEC RUN W 33.01 FT TO W R/W OF +

Map# Mnt 11/14/2008 LARRY

F1=Task F2=ExTx F3=Exit F4=Prompt F11=Docs F10=GoTo PgUp/PgDn F24=More

STATE OF FLORIDA
DEPARTMENT OF HEALTH AND REHABILITATIVE SERVICES
ONSITE SEWAGE DISPOSAL SYSTEM
APPLICATION FOR CONSTRUCTION PERMIT
Authority: Chapter 381, FS & Chapter 10D-6, FAC

PERMIT # AP 901753
DATE PAID 11/12/08
FEE PAID \$ 310.00
RECEIPT #
CR # 08-4513

12-030-1079246

APPLICATION FOR:

☒ New System ☐ Existing System ☐ Holding Tank ☐ Temporary/Experimental System
☐ Repair ☐ Abandonment ☐ Other (Specify) _____

APPLICANT: CHARLOTTE COLLINS

TELEPHONE: 386-754-0093

AGENT: CHARLOTTE COLLINS

MAILING ADDRESS: 795 SW NORRIS AVENUE CITY: LAKE CITY STATE: FL ZIP: 32024

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. ATTACH BUILDING PLAN AND TO-SCALE SITE PLAN SHOWING PERTINENT FEATURES REQUIRED BY CHAPTER 10D-6, FLORIDA ADMINISTRATIVE CODE.

PROPERTY INFORMATION [IF LOT IS NOT IN A RECORDED SUBDIVISION, ATTACH LEGAL DESCRIPTION OR DEED]

LOT: 11 BLOCK: _____ SUBDIVISION: WILSON SPRINGS PH 4 U-7 DATESUBD: 2007

PROPERTY ID #: PART OF 01-7S-15-01439-000 [Section/Township/Range/Parcel] ZONING: _____

PROPERTY SIZE: 1.99 ACRES [Sqft/43560] PROPERTY WATER SUPPLY: ☒ PRIVATE ☐ PUBLIC

PROPERTY STREET ADDRESS: SW SHELLCRACKER

DIRECTIONS TO PROPERTY: STATE ROAD 47 SOUTH, TR ON STATE ROAD 27, TL ON WILSON SPRINGS ROAD, TL ON NEWARK, GO STRAIGHT ON SHELLCRACKER, LOT ON RIGHT

BUILDING INFORMATION

☒ RESIDENTIAL

☐ COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	# Persons Served	Business Activity For Commercial Only
1	<u>MOBILE HOME</u>	<u>3</u>	<u>1387</u>	<u>4</u>	
2					
3					
4					

[N] Garbage Grinders/Disposals

[N] Ultra-low Volume Flush Toilets

[N] Spas/Hot Tubs

[N] Other (Specify) _____


[N] Floor/Equipment Drains

APPLICANT'S SIGNATURE: Charlotte Collins

DATE: 11-12-08

**Application for Onsite Sewage Disposal System
Construction Permit. Part II Site Plan**
Permit Application Number: 08-721-N

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH UNIT



Site Plan Submitted By Paul L. Ladd Date 4/14/08
Plan Approved X Not Approved _____ Date 4/14/08
By [Signature] **Columbia CHD** CPHU

Notes: _____

AtN Webbie

**Columbia County Building Department
Culvert Waiver**

**Culvert Waiver No.
000001696**

DATE: 12/17/2008

BUILDING PERMIT NO. 27525

APPLICANT CHARLOTTE COLLINS

PHONE 754-0093

ADDRESS 795 SW NORRIS AVE

LAKE CITY

FL 32024

OWNER CHARLOTTE COLLINS

PHONE 754-0093

ADDRESS 238 SW NORRIS AVE

LAKE CITY

FL 32024

CONTRACTOR RONNIE NORRIS

PHONE 752-3871

LOCATION OF PROPERTY 47S, TR ON WILSON SPRINGS, TL AT NEWARK, AT POPES, STRAIGHT

TO SHELLCRAKER, 1ST VACANT LOT ON RIGHT

SUBDIVISION/LOT/BLOCK/PHASE/UNIT WILSON SPRINGS

7

11

PARCEL ID # 01-7S-15-01439-711

I HEREBY CERTIFY THAT I UNDERSTAND AND WILL FULLY COMPLY WITH THE DECISION OF THE COLUMBIA COUNTY PUBLIC WORKS DEPARTMENT IN CONNECTION WITH THE HEREIN PROPOSED APPLICATION.

SIGNATURE: X Charlotte Collins

A SEPARATE CHECK IS REQUIRED

MAKE CHECKS PAYABLE TO BCC

Amount Paid 50.00

PUBLIC WORKS DEPARTMENT USE ONLY

I HEREBY CERTIFY THAT I HAVE EXAMINED THIS APPLICATION AND DETERMINED THAT THE
CULVERT WAIVER IS:

☒ APPROVED

☐ NOT APPROVED - NEEDS A CULVERT PERMIT

COMMENTS:

No Drainage Problems Driveway To
Be Sunked To Match Existing Sunk

SIGNED:

12-29-08

DATE:

12-29-08

ANY QUESTIONS PLEASE CONTACT THE PUBLIC WORKS DEPARTMENT AT 386-752-5955.

135 NE Hernando Ave., Suite B-21
Lake City, FL 32055
Phone: 386-758-1008 Fax: 386-758-2160

