

Date: 1/11/2024

To: Attention: Louie Goodin
Columbia County Building and Zoning
135 NE Hernando Ave # 21
Lake City, Florida 32055

29

From: Blake Hunter, Manager
ABH Engineering, PLLC
P.O. Box 763
Trenton, Florida 32693

Re: Adrian/Maria/Jairo Augdelo Project
312 SW Hammock Hill Circle
Lake City, Florida 32024

Hello Mr. Goodin,

the Augdelo's request to change their roof system from a shingle roof to a metal roof. The metal to be used is PBR, min. 26 gauge, over 15/32" plywood. The Florida Product Approval # is: 36904.2. This change applies to their house plan dated, 11/14/23.

I appreciate your consideration.


Blake Hunter, Manager, P.E.
ABH Engineering, PLLC
352-816-0846

Structural Design is in accordance with 2023
Florida Residential Building Code

ABH Engineering, PLLC

Blake Hunter, P.E.
P.O. Box 763, Trenton, Florida 32693
352-816-0846

Certificate of Authorization #26820
License Number PE51397


Blake Hunter
Date 1/11/2024
Florida P.E. License No.: 51397