



Columbia County, Florida
Building Department
135 NE Hernando Avenue
Lake City, Florida 32055
Phone: 386-758-1008

www.columbiacountyfla.com

ROOFING AFFIDAVIT

JOB ADDRESS: 342 SW RIDGE ST. LAKE CITY, FL 32024

I (Print Name) DANIEL DUFRESNE, licensed under Chapter 468, Florida Statutes as a(n):

(Check One) ☒ Contractor ☐ Engineer ☐ Architect

License Number: CCC1332763

On this (Date) 11/10/2021, did personally examine the roof at the above address for regulatory compliance as required for: (Check all that apply)

☒ Roof Deck Attachment ☒ Secondary Water Barrier ☒ Roof to Wall Connection

Based on my examination, I have determined and affirm the installation is in accordance with the Florida Building Code 2020 7th Edition and 2020 Florida Statute (553.844).

(Affiant Signature)

STATE OF Florida

COUNTY Duval

The foregoing instrument acknowledged before me by means of ☒ physical presence or ☐ online notarization, this 16th day of November 2021, by Daniel Dufresne, who is ☒ personally known to me or ☐ has provided the following identification _____.

Notary Public Signature Carrie Dees

(Seal)



Carrie Dees
Notary Public
State of Florida
Comm# HH155917
Expires 7/20/2025

Notary Printed Name Carrie Dees

FINAL INSPECTION & CERTIFICATE OF COMPLETION:

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) [Welcome to Columbia County Online \(columbiacountyfla.com\)](http://Welcome to Columbia County Online (columbiacountyfla.com)).

Clearly visible in the Photographs must be the permit number or address and must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge and valley flashing.



Columbia County, Florida
Building Department
135 NE Hernando Avenue
Lake City, Florida 32055
Phone: 386-758-1008

ROOFING UNDERLAYMENT AFFIDAVIT

www.columbiacountyfla.com

REQUIRED FOR WALK-IN OR PAPER SUBMITTALS

Job Address: 342 SW RIDGE ST. LAKE CITY, FL 32024

I (Print Name) Daniel Dufresne, as a Florida license Roofing Contractor or an Owner Builder, I understand to comply with the 2020 Florida Building Code 7th Edition underlayment requirements, I must select an option for sealing the roof deck.

The options are summarized below...



~~a self-adhering polymer-modified bitumen underlayment complying with ASTM D1970 applied over the entire roof.~~



a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire roof.



two layers of felt underlayment comply ASTM 0226 Type II or ASTM D4869 Type III or IV, or two layers of a synthetic underlayment meeting the performance requirements specified, lapped and fastened as specified.



Other (explain) _____

Contractor/Owners Signature _____

A handwritten signature in black ink, appearing to read "DD", is written over a horizontal line.

FINAL INSPECTION & CERTIFICATE OF COMPLETION:

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) [Welcome to Columbia County Online \(columbiacountyfla.com\)](http://Welcome to Columbia County Online (columbiacountyfla.com)).

Clearly visible in the Photographs must be the permit number or address and must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge and valley flashing.

nov. 10, 2021 12:48:28 p. m.
342 SW Ridge St
Lake City FL 32024
Estados Unidos



bezo plástico
ap staples

FOI
SYN

CON EXTRA-TRACCO

nov. 10, 2021 5:22:08 p. m.
342 SW Ridge St
Lake City FL 32024
Estados Unidos



Nov 12, 2021 at 3:10:54 PM
342 SW Ridge St
Lake City FL 32024
United States



nov. 11, 2021 11:28:32 a. m.
361 SW Ridge St
Lake City FL 32024
Estados Unidos

Ste
Felt





Columbia County, Florida
Building Department
135 NE Hernando Avenue
Lake City, Florida 32055
Phone: 386-758-1008

ROOFING UNDERLAYMENT AFFIDAVIT

www.columbiacountyfla.com

REQUIRED FOR WALK-IN OR PAPER SUBMITTALS

Job Address: 342 SW RIDGE ST. LAKE CITY, FL 32024

I (Print Name) Daniel Dufresne, as a Florida license Roofing Contractor or an Owner Builder, I understand to comply with the 2020 Florida Building Code 7th Edition underlayment requirements, I must select an option for sealing the roof deck.

The options are summarized below...



~~a self-adhering polymer-modified bitumen underlayment complying with ASTM D1970 applied over the entire roof.~~



a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 ¾ - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire roof.



two layers of felt underlayment comply ASTM 0226 Type II or ASTM D4869 Type III or IV, or two layers of a synthetic underlayment meeting the performance requirements specified, lapped and fastened as specified.



Other (explain) _____

Contractor/Owners Signature _____

A handwritten signature in black ink, appearing to read "DD", is written over a horizontal line.

FINAL INSPECTION & CERTIFICATE OF COMPLETION:

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) [Welcome to Columbia County Online \(columbiacountyfla.com\)](http://Welcome to Columbia County Online (columbiacountyfla.com)).

Clearly visible in the Photographs must be the permit number or address and must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge and valley flashing.