

Building Input Summary Report

PROJECT													
Title:	Radford_SLAB_FrmA1_LH	Bedrooms:	4	Address type:	Street address								
Building Type:	FLAsBuilt	Bathrooms:	2	Lot#:									
Owner:		Conditioned Area:	1774	Block/Subdivision:									
# of Units:	1	Total Stories:	1	Platbook:									
Builder Name:	Century CMP Florida	Worst Case:	No	Street:	Lot 24 SW Jewel Lake								
Permit Office:	Columbia County	Rotate Angle:	0	County:									
Jurisdiction:	221000	Cross Ventilation:	No	City, State, Zip:	Lake City, FL 32024								
Family Type:	Single-Family	Whole House Fan:	No										
New/Existing:	New (From Plans)	Terrain:	Suburban										
Year Construct:	2021	Shielding:	Suburban										
Comment:													
CLIMATE													
✓	Design Location	TMY Site	IECC Zone	Design Temp 97.5 %	2.5 %	Int Design Temp Winter	Summer	Heating Degree Days	Design Moisture	Daily Temp Range			
	FL, Gainesville Regional AP	FL_Gainesville_Rgn	2	33	92	70	75	0	45	Medium			
BLOCKS													
#	Name	Area	Volume										
1	System 1	1773.50 ft²	14335.79 ft³										
SPACES													
#		Area	Volume	Kitchen	Occupants	Bedrooms	Infil ID	Finished	Cooled	Heated			
1	BEDROOM 3	148.50 ft²	1200.37 ft³	No	1	1	1	Yes	Yes	Yes			
2	BATH 2	54.00 ft²	436.50 ft³	No	0	0	1	Yes	Yes	Yes			
3	BEDROOM 4	146.63 ft²	1185.22 ft³	No	1	1	1	Yes	Yes	Yes			
4	HVAC	25.00 ft²	202.08 ft³	No	0	0	1	Yes	Yes	Yes			
5	LAU	41.69 ft²	336.97 ft³	No	0	0	1	Yes	Yes	Yes			
6	O. BATH	99.88 ft²	807.32 ft³	No	0	0	1	Yes	Yes	Yes			
7	O.WIC	64.63 ft²	522.39 ft³	No	0	0	1	Yes	Yes	Yes			
8	OWNER'S SUITE	217.00 ft²	1754.08 ft³	No	2	1	1	Yes	Yes	Yes			
9	GREAT ROOM	268.06 ft²	2166.84 ft³	No	0	0	1	Yes	Yes	Yes			
10	FOYER	214.63 ft²	1734.89 ft³	No	0	0	1	Yes	Yes	Yes			
11	BEDROOM 2	151.50 ft²	1224.62 ft³	No	1	1	1	Yes	Yes	Yes			
12	PANTRY	20.03 ft²	161.92 ft³	No	0	0	1	Yes	Yes	Yes			
13	DINING	162.00 ft²	1309.50 ft³	No	0	0	1	Yes	Yes	Yes			
14	KITCHEN	159.97 ft²	1293.08 ft³	Yes	0	0	1	Yes	Yes	Yes			
FLOORS (Total Exposed Area = 1774 sq.ft.)													
✓	#	Floor Type	Space	Perimeter	R-Value	Area	U-Factor	Tile	Wood	Carpet			
	1	Bg floor, heavy dry or light damp soil, on grade	BEDROOM 3	33 ft	0	148.50 ft²	1.180	0	1.0	0			
	2	Bg floor, heavy dry or light damp soil, on grade	BATH 2	9 ft	0	54.00 ft²	1.180	0	1.0	0			
	3	Bg floor, heavy dry or light damp soil, on grade	BEDROOM 4	24 ft	0	146.63 ft²	1.180	0	1.0	0			
	4	Bg floor, heavy dry or light damp soil, on grade	HVAC	0 ft	0	25.00 ft²	1.180	0	1.0	0			
	5	Bg floor, heavy dry or light damp soil, on grade	LAU	0 ft	0	41.69 ft²	1.180	0	1.0	0			
	6	Bg floor, heavy dry or light damp soil, on grade	O. BATH	12 ft	0	99.88 ft²	1.180	0	1.0	0			
	7	Bg floor, heavy dry or light damp soil, on grade	O.WIC	0 ft	0	64.63 ft²	1.180	0	1.0	0			
	8	Bg floor, heavy dry or light damp soil, on grade	OWNER'S SUITE	38 ft	0	217.00 ft²	1.180	0	1.0	0			
	9	Bg floor, heavy dry or light damp soil, on grade	GREAT ROOM	13 ft	0	268.06 ft²	1.180	0	1.0	0			
	10	Bg floor, heavy dry or light damp soil, on grade	FOYER	26 ft	0	214.63 ft²	1.180	0	1.0	0			
	11	Bg floor, heavy dry or light damp soil, on grade	BEDROOM 2	11 ft	0	151.50 ft²	1.180	0	1.0	0			
	12	Bg floor, heavy dry or light damp soil, on grade	PANTRY	5 ft	0	20.03 ft²	1.180	0	1.0	0			
	13	Bg floor, heavy dry or light damp soil, on grade	DINING	34 ft	0	162.00 ft²	1.180	0	1.0	0			
	14	Bg floor, heavy dry or light damp soil, on grade	KITCHEN	10 ft	0	159.97 ft²	1.180	0	1.0	0			
ROOF													
✓	#	Type	Materials	Roof Area	Gable Area	Roof Color	Rad Barr	Solar Absor.	SA Tested	Emitt	Emitt Tested	Deck Insul.	Pitch (deg)
	1	Hip	RoofAsph	1921 ft²		Medium	N	0.75	No	0.90	No	0	23
	2	Hip	RoofAsph	439 ft²		Medium	N	0.75	No	0.90	No	0	23
ATTIC													
✓	#	Type	Ventilation	Vent Ratio (1 in)	Area	RBS	IRCC						
	1	Full attic	Vented	300	1773.50 ft²	N	N						
	2	Full attic	Vented	300	405.00 ft²	N	N						

CEILING (Total Exposed Area = 1774 sq.ft.)														
✓ #	Ceiling Type	Space	R-Value	U-Factor	Area	Framing Fraction	Truss Type							
1	Attic ceiling, asphalt shingles roof	BEDROOM 3	30	0.032	148.50 ft ²	0.10	—							
2	Attic ceiling, asphalt shingles roof	BATH 2	30	0.032	54.00 ft ²	0.10	—							
3	Attic ceiling, asphalt shingles roof	BEDROOM 4	30	0.032	146.63 ft ²	0.10	—							
4	Attic ceiling, asphalt shingles roof	HVAC	30	0.032	25.00 ft ²	0.10	—							
5	Attic ceiling, asphalt shingles roof	LAU	30	0.032	41.69 ft ²	0.10	—							
6	Attic ceiling, asphalt shingles roof	O. BATH	30	0.032	99.88 ft ²	0.10	—							
7	Attic ceiling, asphalt shingles roof	O.WIC	30	0.032	64.63 ft ²	0.10	—							
8	Attic ceiling, asphalt shingles roof	OWNER'S SUITE	30	0.032	217.00 ft ²	0.10	—							
9	Attic ceiling, asphalt shingles roof	GREAT ROOM	30	0.032	268.06 ft ²	0.10	—							
10	Attic ceiling, asphalt shingles roof	FOYER	30	0.032	214.63 ft ²	0.10	—							
11	Attic ceiling, asphalt shingles roof	BEDROOM 2	30	0.032	151.50 ft ²	0.10	—							
12	Attic ceiling, asphalt shingles roof	PANTRY	30	0.032	20.03 ft ²	0.10	—							
13	Attic ceiling, asphalt shingles roof	DINING	30	0.032	162.00 ft ²	0.10	—							
14	Attic ceiling, asphalt shingles roof	KITCHEN	30	0.032	159.97 ft ²	0.10	—							

WALLS (Total Exposed Area = 1730 sq.ft.)														
✓ #	Omt	Adjacent To	Wall Type	Space	Cavity R-Value	Width Ft In	Height Ft In	Area	Sheathing R-Value	U-Factor	Frm. Frac.	Solar Absor.	Below Grade%	
1	NE	Exterior	Frm wall, wd ext,	BEDROOM 3	13	14 0	8 1	113.2 ft ²	0	0.091	0.25	0.75	0	
2	SE	Exterior	Frm wall, wd ext,	BEDROOM 3	13	7 6	8 1	60.6 ft ²	0	0.091	0.25	0.75	0	
3	NW	Exterior	Frm wall, wd ext,	BEDROOM 3	13	11 3	8 1	90.9 ft ²	0	0.091	0.25	0.75	0	
4	NW	Exterior	Frm wall, wd ext,	BATH 2	13	9 0	8 1	72.8 ft ²	0	0.091	0.25	0.75	0	
5	SE	Exterior	Frm wall, wd ext,	BEDROOM 4	13	11 6	8 1	93.0 ft ²	0	0.091	0.25	0.75	0	
6	-	Partition	Frm wall, 1/2" gy	BEDROOM 4	13	12 9	8 1	103.1 ft ²	0	0.091	0.25	0.75	0	
7	SE	Exterior	Frm wall, wd ext,	O. BATH	13	11 9	8 1	95.0 ft ²	0	0.091	0.25	0.75	0	
8	SE	Exterior	Frm wall, wd ext,	OWNER'S SUITE	13	15 6	8 1	125.3 ft ²	0	0.091	0.25	0.75	0	
9	SW	Exterior	Frm wall, wd ext,	OWNER'S SUITE	13	14 0	8 1	113.2 ft ²	0	0.091	0.25	0.75	0	
10	NW	Exterior	Frm wall, wd ext,	OWNER'S SUITE	13	8 0	8 1	64.7 ft ²	0	0.091	0.25	0.75	0	
11	SW	Exterior	Frm wall, wd ext,	GREAT ROOM	13	13 0	8 1	105.1 ft ²	0	0.091	0.25	0.75	0	
12	NE	Exterior	Frm wall, wd ext,	FOYER	13	5 0	8 1	40.4 ft ²	0	0.091	0.25	0.75	0	
13	-	Partition	Frm wall, 1/2" gy	FOYER	13	21 0	8 1	169.8 ft ²	0	0.091	0.25	0.75	0	
14	NW	Exterior	Frm wall, wd ext,	BEDROOM 2	13	11 3	8 1	90.9 ft ²	0	0.091	0.25	0.75	0	
15	NW	Exterior	Frm wall, wd ext,	PANTRY	13	4 9	8 1	38.4 ft ²	0	0.091	0.25	0.75	0	
16	SE	Exterior	Frm wall, wd ext,	DINING	13	8 0	8 1	64.7 ft ²	0	0.091	0.25	0.75	0	
17	SW	Exterior	Frm wall, wd ext,	DINING	13	12 0	8 1	97.0 ft ²	0	0.091	0.25	0.75	0	
18	NW	Exterior	Frm wall, wd ext,	DINING	13	13 6	8 1	109.1 ft ²	0	0.091	0.25	0.75	0	
19	NW	Exterior	Frm wall, wd ext,	KITCHEN	13	10 3	8 1	82.9 ft ²	0	0.091	0.25	0.75	0	

DOORS (Total Exposed Area = 40 sq.ft.)														
✓ #	Omt	Door Type	Space	Storms	U-Value	Width Ft In	Height Ft In	Area						
1	NE	Door, mtl pur core type	FOYER	None	0.290	3 0	6 8	20.0 ft ²						
2	N	Door, mtl pur core type	FOYER	None	0.290	3 0	6 8	20.0 ft ²						

WINDOWS (Total Exposed Area = 159 sq.ft.)														
✓ #	Omt	Wall ID	Frame	Panes	NFRC	U-Factor	SHGC	Impact	Area	Overhang Depth	Separation	Interior Shade	Screening	
1	NE	1	Vinyl	Low-E Double	Yes	0.330	0.29	No	30.0ft ²	1 ft 0 in	3 ft 9 in	Blinds 45°	outdoor	
2	SE	5	Vinyl	Low-E Double	Yes	0.330	0.29	No	15.0ft ²	1 ft 0 in	1 ft 0 in	Blinds 45°	outdoor	
3	SE	7	Vinyl	Low-E Double	Yes	0.330	0.29	No	6.0ft ²	1 ft 0 in	1 ft 0 in	Blinds 45°	outdoor	
4	SW	9	Vinyl	Low-E Double	Yes	0.330	0.29	No	30.0ft ²	1 ft 0 in	1 ft 0 in	Blinds 45°	outdoor	
5	SW	11	Vinyl	Low-E Double	Yes	0.330	0.29	No	33.3ft ²	9 ft 0 in	1 ft 0 in	None	outdoor	
6	NW	14	Vinyl	Low-E Double	Yes	0.330	0.29	No	15.0ft ²	1 ft 0 in	1 ft 0 in	Blinds 45°	outdoor	
7	SW	17	Vinyl	Low-E Double	Yes	0.330	0.29	No	30.0ft ²	1 ft 0 in	1 ft 0 in	Blinds 45°	outdoor	

GARAGE						
✓ #	Floor Area	Ceiling Area	Exposed Wall Perimeter	Avg. Wall Height	Exposed Wall Insulation	
1	405 ft ²	405 ft ²	47 ft	8 ft	13	

INFILTRATION								
#	Scope	Method	SLA	CFM 50	ELA	EqLA	ACH	ACH 50
1	Wholehouse	Blower Door	0.000308	1434	78.66	147.7	0.47	6.00

HEATING SYSTEM							
✓ #	System Type	Subtype	Efficiency	Capacity	Block	Ducts	
1	Split air source heat pump		HSPF: 8.5	28.4 kBtu/hr	1	sys#1	

COOLING SYSTEM							
✓ #	System Type	Subtype	Efficiency	Capacity	Air Flow	SHR	Ducts
1	Split air source heat pump		SEER: 15.0	27.0 kBtu/hr	888 cfm	0.82	1 sys#1

ENERGY PERFORMANCE LEVEL (EPL) DISPLAY CARD

ESTIMATED ENERGY PERFORMANCE INDEX = 98

The lower the EnergyPerformance Index, the more efficient the home.

1. New home or addition	1. <u>New (From Plans)</u>	12. Ducts, location & insulation level	
2. Single-family or multiple-family	2. <u>Single-Family</u>	a. Supply ducts:	R <u>6.0</u>
3. Number of units, if multiple-family	3. <u>1</u>	b. Return ducts:	R <u>6.0</u>
4. Number of bedrooms	4. <u>4</u>	c. AHU location:	<u>System 1</u>
5. Is this a worst case? (yes/no)	5. <u>No</u>	13. Cooling systems	Capacity <u>27.0</u>
6. Conditioned floor area (ft ²)	6. <u>1773.50</u>	a. Split system:	SEER <u>15.00</u>
7. Windows, type and area*		b. Single package:	SEER <u> </u>
a. U-Factor:	7a. <u>DbI, 0.330</u>	c. Ground/water source:	SEER/COP <u> </u>
b. Solar Heat Gain Coefficient (SHGC):	7b. <u>0.29</u>	d. Room unit/PTAC:	EER <u> </u>
c. Area (ft ²)	7c. <u>159</u>	e. Other:	<u> </u>
8. Skylights		14. Heating systems	Capacity <u>28.4</u>
a. U-Factor:	8a. <u> </u>	a. Split system heat pump:	HSPF <u>8.50</u>
b. Solar Heat Gain Coefficient (SHGC):	8b. <u> </u>	b. Single package heat pump:	HSPF <u> </u>
9. Floor type, insulation level		c. Electric resistance:	COP <u> </u>
a. Slab-on-grade (R-value):	9a. <u>0.0</u>	d. Gas furnace, natural gas:	AFUE <u> </u>
b. Wood, raised (R-value):	9b. <u> </u>	e. Gas furnace, LPG:	AFUE <u> </u>
c. Concrete, raised (R-value)	9c. <u> </u>	f. Other:	<u> </u>
10 Wall type and insulation:		15. Water heating systems	
a. Exterior:		a. Electric resistance:	EF <u>0.920</u>
1. Wood frame (Insulation R-value):	10a1. <u>13</u>	b. Gas fired, natrual gas:	EF <u> </u>
2. Masonry (Insulation R-value):	10a2. <u> </u>	c. Gas fired, LPG:	EF <u> </u>
b. Adjacent:		d. Solar system with tank:	EF <u> </u>
1. Wood frame (Insulation R-value):	10b1. <u>13</u>	e. Dedicated heat pump with tank:	EF <u> </u>
2. Masonry (Insulation R-value):	10b2. <u> </u>	f. Heat recovery unit:	HeatRec% <u> </u>
11. Ceiling type and insulation level		g. Other:	<u> </u>
a. Under attic (R-value):	11a. <u>30.0</u>	16. HVAC credits claimed (Performance Method)	
b. Single assembly (R-value):	11b. <u> </u>	a. Ceiling fans:	<u> </u>
c. Knee walls/skylight walls (R-value)	11c. <u> </u>	b. Cross ventilation:	<u> </u>
d. Radiant barrier installed	11d. <u> </u>	c. Whole house fan:	<u> </u>
		d. Multizone cooling credit:	<u> </u>
		e. Multizone heating credit:	<u> </u>
		f. Programmable thermostat:	<u> </u>

*Label required by Section 303.1.3 of the Florida Building Code, Energy Conservation, if not DEFAULT.

I certify that this home has complied with the Florida Building Code, Energy Conservation, through the above energy saving features which will be installed (or exceeded) in this home before final inspection. Otherwise, a new EPL Display Card will be completed based on installed Code compliant features.

Builder Signature: _____

Date: _____

Address of New Home: Lot 24 SW Jewel Lake Drive

City/FL Zip: Lake City, FL 32024

Florida Building Code, Energy Conservation, 7th Edition (2020)

Mandatory Requirements for Residential Performance, Prescriptive and ERI Methods

ADDRESS: Lot 24 SW Jewel Lake Drive
Lake City, FL 32024

PERMIT #:

MANDATORY REQUIREMENTS - See individual code sections for full details.

SECTION R401 GENERAL



- ☐ **R401.3 Energy Performance Level (EPL) display card (Mandatory).** The building official shall require that an energy performance level (EPL) display card be completed and certified by the builder to be accurate and correct before final approval of the building for occupancy. Florida law (Section 553.9085, Florida Statutes) requires the EPL display card to be included as an addendum to each sales contract for both presold and nonpresold residential buildings. The EPL display card contains information indicating the energy performance level and efficiencies of components installed in a dwelling unit, completed and signed by the builder. The building official shall verify that the EPL display card accurately reflects the plans and specifications submitted to demonstrate compliance for the building. A copy of the EPL display card can be found in Appendix RD.

SECTION R402 BUILDING THERMAL ENVELOPE

- ☐ **R402.4 Air leakage (Mandatory).** The building thermal envelope shall be constructed to limit air leakage in accordance with the requirements of Sections R402.4.1 through R402.4.5.

Exception: Dwelling units of R-2 Occupancies and multiple attached single family dwellings shall be permitted to comply with Section C402.5.

- ☐ **R402.4.1 Building thermal envelope.** The building thermal envelope shall comply with Sections R402.4.1.1 and R402.4.1.2. The sealing methods between dissimilar materials shall allow for differential expansion and contraction.

- ☐ **R402.4.1.1 Installation.** The components of the building thermal envelope as listed in Table R402.4.1.1 shall be installed in accordance with the manufacturer's instructions and the criteria listed in Table 402.4.1.1, as applicable to the method of construction. Where required by the code official, an approved third party shall inspect all components and verify compliance.

- ☐ **R402.4.1.2 Testing.** The building or dwelling unit shall be tested and verified as having an air leakage rate not exceeding seven air changes per hour in Climate Zones 1 and 2, and three air changes per hour in Climate Zones 3 through 8. Testing shall be conducted in accordance with ANSI/RESET/ICC 380 and reported at a pressure of 0.2 inch w.g. (50 Pascals). Testing shall be conducted by either individuals as defined in Section 553.993(5) or (7), Florida Statutes or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i) or an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.

Exception: Testing is not required for additions, alterations, renovations, or repairs, of the building thermal envelope of existing buildings in which the new construction is less than 85 percent of the building thermal envelope.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures.
2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures.
3. Interior doors, if installed at the time of the test, shall be open.
4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed.
5. Heating and cooling systems, if installed at the time of the test, shall be turned off.
6. Supply and return registers, if installed at the time of the test, shall be fully open.

- ☐ **R402.4.2 Fireplaces.** New wood-burning fireplaces shall have tight-fitting flue dampers or doors, and outdoor combustion air. Where using tight-fitting doors on factory-built fireplaces listed and labeled in accordance with UL 127, the doors shall be tested and listed for the fireplace. Where using tight-fitting doors on masonry fireplaces, the doors shall be listed and labeled in accordance with UL 907.

- ☐ **R402.4.3 Fenestration air leakage.** Windows, skylights and sliding glass doors shall have an air infiltration rate of no more than 0.3 cfm per square foot (1.5 L/s/m²), and swinging doors no more than 0.5 cfm per square foot (2.6 L/s/m²), when tested according to NFRC 400 or AAMA/WDMA/CSA 101/I.S.2/A440 by an accredited, independent laboratory and listed and labeled by the manufacturer.

Exception: Site-built windows, skylights and doors.

MANDATORY REQUIREMENTS - (Continued)

- ☐ **R402.4.4 Rooms containing fuel-burning appliances** In Climate Zones 3 through 8, where open combustion air ducts provide combustion air to open combustion fuel burning appliances, the appliances and combustion air opening shall be located outside the building thermal envelope or enclosed in a room, isolated from inside the thermal envelope. Such rooms shall be sealed and insulated in accordance with the envelope requirements of Table R402.1.2, where the walls, floors and ceilings shall meet not less than the basement wall R-value requirement. The door into the room shall be fully gasketed and any water lines and ducts in the room insulated in accordance with Section R403. The combustion air duct shall be insulated where it passes through conditioned space to a minimum of R-8.

Exceptions:

1. Direct vent appliances with both intake and exhaust pipes installed continuous to the outside.
2. Fireplaces and stoves complying with Section R402.4.2 and Section R1006 of the Florida Building Code, Residential.

- ☐ **R402.4.5 Recessed lighting.** Recessed luminaires installed in the building thermal envelope shall be sealed to limit air leakage between conditioned and unconditioned spaces. All recessed luminaires shall be IC-rated and labeled as having an air leakage rate not more than 2.0 cfm (0.944 L/s) when tested in accordance with ASTM E283 at a 1.57 psf (75 Pa) pressure differential. All recessed luminaires shall be sealed with a gasket or caulk between the housing and the interior wall or ceiling covering.

SECTION R403 SYSTEMS

- ☐ **R403.1 Controls**

- ☐ **R403.1.1 Thermostat provision (Mandatory).** At least one thermostat shall be provided for each separate heating and cooling system.

- ☐ **R403.1.3 Heat pump supplementary heat (Mandatory).** Heat pumps having supplementary electric-resistance heat shall have controls that, except during defrost, prevent supplemental heat operation when the heat pump compressor can meet the heating load.

- ☐ **R403.3.2 Sealing (Mandatory).** All ducts, air handlers, filter boxes and building cavities that form the primary air containment passageways for air distribution systems shall be considered ducts and plenum chambers, shall be constructed and sealed in accordance with Section C403.2.9.2 of the Commercial Provisions of this code and shall be shown to meet duct tightness criteria below.

Duct tightness shall be verified by testing in accordance with ANSI/RESNET/ICC 380 by either individuals as defined in Section 553.993(5) or (7), Florida Statutes, or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i), Florida Statutes, to be "substantially leak free" in accordance with Section R403.3.3.

- ☐ **R403.3.2.1 Sealed air handler.** Air handlers shall have a manufacturer's designation for an air leakage of no more than 2 percent of the design air flow rate when tested in accordance with ASHRAE 193.

- ☐ **R403.3.3 Duct testing (Mandatory).** Ducts shall be pressure tested to determine air leakage by one of the following methods:

1. Rough-in test: Total leakage shall be measured with a pressure differential of 0.1 inch w.g. (25 Pa) across the system, including the manufacturer's air handler enclosure if installed at the time of the test. All registers shall be taped or otherwise sealed during the test.
2. Post construction test: Total leakage shall be measured with a pressure differential of 0.1 inch w.g. (25 Pa) across the entire system, including the manufacturer's air handler enclosure. All registers shall be taped or otherwise sealed during the test.

Exceptions:

1. A duct leakage test shall not be required where the ducts and air handlers are located entirely within the building thermal envelope.
2. Duct testing is not mandatory for buildings complying by Section 405 of this code. Duct leakage testing is required for Section R405 compliance where credit is taken for leakage, and a duct air leakage Q_n to the outside of less than 0.080 (where Q_n = duct leakage to the outside in cfm per 100 square feet of conditioned floor area tested at 25 Pascals) is indicated in the compliance report for the proposed design.

A written report of the results of the test shall be signed by the party conducting the test and provided to the code official.

- ☐ **R403.3.5 Building Cavities (Mandatory).** Building framing cavities shall not be used as ducts or plenums.

- ☐ **R403.4 Mechanical system piping insulation (Mandatory).** Mechanical system piping capable of carrying fluids above 105°F (41°C) or below 55°F (13°C) shall be insulated to a minimum of R-3.

- ☐ **R403.4.1 Protection of piping insulation.** Piping insulation exposed to weather shall be protected from damage, including that caused by sunlight, moisture, equipment maintenance, and wind, and shall provide shielding from solar radiation that can cause degradation of the material. Adhesive tape shall not be permitted.

- ☐ **R403.5.1 Heated water circulation and temperature maintenance systems (Mandatory).** Heated water circulation systems shall be in accordance with Section R403.5.1.1. Heat trace temperature maintenance systems shall be in accordance with Section R403.5.1.2. Automatic controls, temperature sensors and pumps shall be accessible. Manual controls shall be readily accessible.

- ☐ **R403.5.1.1 Circulation systems.** Heated water circulation systems shall be provided with a circulation pump. The system return pipe shall be dedicated return pipe or a cold water supply pipe. Gravity and thermosiphon circulation systems shall be prohibited. Controls for circulating hot water system pumps shall start the pump based on the identification of a demand for hot water within the occupancy. The controls shall automatically turn off the pump when the water in the circulation loop is at the desired temperature and when there is no demand for hot water.

- ☐ **R403.5.1.2 Heat trace systems.** Electric heat trace systems shall comply with IEEE 515.1 or UL 515. Controls for such systems shall automatically adjust the energy input to the heat tracing to maintain the desired water temperature in the piping in accordance with the times when heated water is used in the occupancy.

MANDATORY REQUIREMENTS - (Continued)

- ☐ **R403.5.5 Heat traps (Mandatory).** Storage water heaters not equipped with integral heat traps and having vertical pipe risers shall have heat traps installed on both the inlets and outlets. External heat traps shall consist of either a commercially available heat trap or a downward and upward bend of at least 3 1/2 inches (89 mm) in the hot water distribution line and cold water line located as close as possible to the storage tank.
- ☐ **R403.5.6 Water heater efficiencies (Mandatory).**
- ☐ **R403.5.6.1 Storage water heater temperature controls.**
- ☐ **R403.5.6.1.1 Automatic controls.** Service water heating systems shall be equipped with automatic temperature controls capable of adjustment from the lowest to the highest acceptable temperature settings for the intended use. The minimum temperature setting range shall be from 100°F to 140°F (38°C to 60°C).
- ☐ **R403.5.6.1.2 shut down.** A separate switch or a clearly marked circuit breaker shall be provided to permit the power supplied to electric service systems to be turned off. A separate valve shall be provided to permit the energy supplied to the main burner(s) of combustion types of service water heating systems to be turned off.
- ☐ **R403.5.6.2 Water heating equipment.** Water heating equipment installed in residential units shall meet the minimum efficiencies of Table C404.2 in Chapter 4 of the Florida Building Code, Energy Conservation, Commercial Provisions, for the type of equipment installed. Equipment used to provide heating functions as part of a combination system shall satisfy all stated requirements for the appropriate water heating category. Solar water heaters shall meet the criteria of Section R403.5.6.2.1.
- ☐ **R403.5.6.2.1 Solar water heating system.** Solar systems for domestic hot water production are rated by the annual solar energy factor of the system. The solar energy factor of a system shall be determined from the Florida Solar Energy Center Directory of Certified Solar Systems. Solar collectors shall be tested in accordance with ISO Standard 9806, Test Methods for Solar Collectors, and SRCC Standard TM-1, Solar Domestic Hot Water System and Component Test Protocol. Collectors in installed solar water-heating systems should meet the following criteria:
1. Be installed with a tilt angle between 10 degrees and 40 degrees of the horizontal; and
 2. Be installed at an orientation within 45 degrees of true south.
- ☐ **R403.6 Mechanical ventilation (Mandatory).** The building shall be provided with ventilation that meets the requirements of the Florida Building Code, Residential or Florida Building Code, Mechanical, as applicable, or with other approved means of ventilation, including: Natural, Infiltration or Mechanical means. Outdoor air intakes and exhausts shall have automatic or gravity dampers that close when the ventilation system is not operating.
- ☐ **R403.6.1 Whole-house mechanical ventilation system fan efficacy.** When installed to function as a whole-house mechanical ventilation system, fans shall meet the efficacy requirements of Table R403.6.1.
- Exception:** Where mechanical ventilation fans are integral to tested and listed HVAC equipment, they shall be powered by an electronically commutated motor.
- ☐ **R403.6.2 Ventilation air.** Residential buildings designed to be operated at a positive indoor pressure of for mechanical ventilation shall meet the following criteria:
1. The design air change per hour minimums for residential buildings in ASHRAE 62.2, Ventilation for Acceptable Indoor Air Quality, shall be the maximum rates allowed for residential applications.
 2. No ventilation or air-conditioning system make-up air shall be provided to conditioned space from attics, crawlspaces, attached enclosed garages or outdoor spaces adjacent to swimming pools or spas.
 3. If ventilation air is drawn from enclosed spaces(s), then the walls of the space(s) from which air is drawn shall be insulated to a minimum of R-11 and the ceiling shall be insulated to a minimum of R-19, space permitting, or R-10 otherwise.
- ☐ **R403.7 Heating and cooling equipment.**
- ☐ **R403.7.1 Equipment sizing (Mandatory).** Heating and cooling equipment shall be sized in accordance with ACCA Manual S based on the equipment loads calculated in accordance with ACCA Manual J or other approved methodologies, heating and cooling calculation based on building loads for the directional orientation of the building. The manufacturer and model number of the outdoor and indoor units (if split system) shall be submitted along with the sensible and total cooling capacities at the design conditions described in Section R302.1. This code does not allow designer safety factors, provisions for future expansion or other factors that affect equipment sizing. System sizing calculations shall not include loads created by local intermittent mechanical ventilation such as standard kitchen and bathroom exhaust systems. New or replacement heating and cooling equipment shall have an efficiency rating equal to or greater than the minimum required by federal law for the geographic location where the equipment is installed.

TABLE R403.6.1**WHOLE-HOUSE MECHANICAL VENTILATION SYSTEM FAN EFFICACY**

FAN LOCATION	AIRFLOW RATE MINIMUM CFM	MINIMUM EFFICACY (a) CFM/WATT	AIRFLOW RATE MAXIMUM CFM
HRV or ERV	Any	1.2 cfm/watt	Any
Range hoods	Any	2.8 cfm/watt	Any
In-line fan	Any	2.8 cfm/watt	Any
Bathroom, utility room	10	1.4 cfm/watt	< 90
Bathroom, utility room	90	2.8 cfm/watt	Any

For SI: 1 cfm - 28.3 L/min.

(a) When tested in accordance HVI Standard 916

MANDATORY REQUIREMENTS - (Continued)

- ☐ **R403.7.1.1 Cooling equipment capacity.** Cooling only equipment shall be selected so that its total capacity is not less than the calculated total load but not more than 1.15 times greater than the total load calculated according to the procedure selected in Section 403.7, or the closest available size provided by the manufacturer's product lines. The corresponding latent capacity of the equipment shall not be less than the calculated latent load.

The published value for AHRI total capacity is a nominal, rating-test value and shall not be used for equipment sizing. Manufacturer's expanded performance data shall be used to select cooling-only equipment. This selection shall be based on the outdoor design dry-bulb temperature for the load calculation (or entering water temperature for water-source equipment), the blower CFM provided by the expanded performance data, the design value for entering wet-bulb temperature and the design value for entering dry-bulb temperature

Design values for entering wet-bulb and dry-bulb temperatures shall be for the indoor dry bulb and relative humidity used for the load calculation and shall be adjusted for return side gains if the return duct(s) is installed in an unconditioned space.

Exceptions:

1. Attached single- and multiple-family residential equipment sizing may be selected so that its cooling capacity is less than the calculated total sensible load but not less than 80 percent of that load.
2. When signed and sealed by a Florida-registered engineer, in attached single- and multiple-family units, the capacity of equipment may be sized in accordance with good design practice.

- ☐ **R403.7.1.2 Heating equipment capacity.**

- ☐ **R403.7.1.2.1 Heat pumps** Heat pump sizing shall be based on the cooling requirements as calculated according to Section R403.7.1.1, and the heat pump total cooling capacity shall not be more than 1.15 times greater than the design cooling load even if the design heating load is 1.15 times greater than the design cooling load.

- ☐ **R403.7.1.2.2 Electric resistance furnaces.** Electric resistance furnaces shall be sized within 4 kW of the design requirements calculated according to the procedure selected in Section R403.7.1

- ☐ **R403.7.1.2.3 Fossil fuel heating equipment.** The capacity of fossil fuel heating equipment with natural draft atmospheric burners shall not be less than the design load calculated in accordance with Section R403.7.1.

- ☐ **R403.7.1.3 Extra capacity required for special occasions.** Residences requiring excess cooling or heating equipment capacity on an intermittent basis, such as anticipated additional loads caused by major entertainment events, shall have equipment sized or controlled to prevent continuous space cooling or heating within that space by one or more of the following options:

1. A separate cooling or heating system is utilized to provide cooling or heating to the major entertainment areas.
2. A variable capacity system sized for optimum performance during base load periods is utilized.

- ☐ **R403.8 Systems serving multiple dwelling units (Mandatory).** Systems serving multiple dwelling units shall comply with Sections C403 and C404 of the IECC—Commercial Provisions in lieu of Section R403.

- ☐ **R403.9 Snow melt and ice system controls (Mandatory).** Snow- and ice-melting systems, supplied through energy service to the building, shall include automatic controls capable of shutting off the system when the pavement temperature is above 50°F (10°C), and no precipitation is falling and an automatic or manual control that will allow shutoff when the outdoor temperature is above 40°F (4.8°C).

- ☐ **R403.10 Pools and permanent spa energy consumption (Mandatory).** The energy consumption of pools and permanent spas shall be in accordance with Sections R403.10.1 through R403.10.5.

- ☐ **R403.10.1 Heaters.** The electric power to heaters shall be controlled by a readily accessible on-off switch that is an integral part of the heater mounted on the exterior of the heater, or external to and within 3 feet (914 mm) of the heater. Operation of such switch shall not change the setting of the heater thermostat. Such switches shall be in addition to a circuit breaker for the power to the heater. Gas-fired heaters shall not be equipped with continuously burning ignition pilots.

- ☐ **R403.10.2 Time switches.** Time switches or other control methods that can automatically turn off and on according to a preset schedule shall be installed for heaters and pump motors. Heaters and pump motors that have built-in time switches shall be in compliance with this section.

Exceptions:

1. Where public health standards require 24-hour pump operations.
2. Pumps that operate solar- and waste-heat-recovery pool heating systems.
3. Where pumps are powered exclusively from on-site renewable generation.

- ☐ **R403.10.3 Covers.** Outdoor heated swimming pools and outdoor permanent spas shall be equipped with a vapor-retardant cover on or at the water surface or a liquid cover or other means proven to reduce heat loss.

Exception: Where more than 70 percent of the energy for heating, computed over an operation season, is from site-recovered energy, such as from a heat pump or solar energy source, covers or other vapor-retardant means shall not be required.

- ☐ **R403.10.4 Gas- and oil-fired pool and spa heaters.** All gas- and oil-fired pool and spa heaters shall have a minimum thermal efficiency of 82 percent for heaters manufactured on or after April 16, 2013, when tested in accordance with ANSI Z 21.56. Pool heaters fired by natural or LP gas shall not have continuously burning pilot lights.

MANDATORY REQUIREMENTS - (Continued)

- ☐ **R403.10.5 Heat pump pool heaters.** Heat pump pool heaters shall have a minimum COP of 4.0 when tested in accordance with AHRI 1160, Table 2, Standard Rating Conditions-Low Air Temperature. A test report from an independent laboratory is required to verify procedure compliance. Geothermal swimming pool heat pumps are not required to meet this standard.
- ☐ **R403.11 Portable spas (Mandatory).** The energy consumption of electric-powered portable spas shall be controlled by the requirements of APSP-14.
- ☐ **R403.13 Dehumidifiers (Mandatory)** If installed, a dehumidifier shall conform to the following requirements:
1. The minimum rated efficiency of the dehumidifier shall be greater than 1.7 liters/ kWh if the total dehumidifier capacity for the house is less than 75 pints/day and greater than 2.38 liters/kWh if the total dehumidifier capacity for the house is greater than or equal to 75 pints/day.
 2. The dehumidifier shall be controlled by a sensor that is installed in a location where it is exposed to mixed house air.
 3. Any dehumidifier unit located in unconditioned space that treats air from conditioned space shall be insulated to a minimum of R-2.
 4. Condensate disposal shall be in accordance with Section M1411.3.1 of the Florida Building Code, Residential.
- ☐ **R403.13.1 Ducted dehumidifiers** Ducted dehumidifiers shall, in addition to conforming to the requirements of Section R403.13, conform to the following requirements:
1. If a ducted dehumidifier is configured with return and supply ducts both connected into the supply side of the cooling system, a backdraft damper shall be installed in the supply air duct between the dehumidifier inlet and outlet duct.
 2. If a ducted dehumidifier is configured with only its supply duct connected into the supply side of the central heating and cooling system, a backdraft damper shall be installed in the dehumidifier supply duct between the dehumidifier and central supply duct.
 3. A ducted dehumidifier shall not be ducted to or from a central ducted cooling system on the return duct side upstream from the central cooling evaporator coil.
 4. Ductwork associated with a dehumidifier located in unconditioned space shall be insulated to a minimum of R-6.

SECTION R404

ELECTRICAL POWER AND LIGHTING SYSTEMS

- ☐ **R404.1 Lighting equipment (Mandatory).** Not less than 90 percent of the lamps in permanently installed luminaires shall have an efficacy of at least 45 lumens-per-watt or shall utilize lamps with an efficacy of not less than 65 lumens-per-watt.

Exception: Low-voltage lighting.

- ☐ **R404.1.1 Lighting equipment (Mandatory).** Fuel gas lighting systems shall not have continuously burning pilot lights.

TABLE 402.4.1.1
AIR BARRIER AND INSULATION INSPECTION COMPONENT CRITERIA

Project Name:	Radford SLAB FmA1 LH	Builder Name	Century CMP Florida
Street:	Lot 24 SW Jewel Lake Drive	Permit Office:	Columbia County
City, State, Zip:	Lake City, FL 32024	Permit Number:	
Owner:		Jurisdiction:	221000
Design Location:	FL, Gainesville Regional AP		

COMPONENT	AIR BARRIER CRITERIA	INSULATION INSTALLATION CRITERIA	✓
General requirements	A continuous air barrier shall be installed in the building envelope. The exterior thermal envelope contains a continuous barrier. Breaks or joints in the air barrier shall be sealed.	Air-permeable insulation shall not be used as a sealing material.	☐
Ceiling/attic	The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier shall be sealed. Access openings, drop down stairs or knee wall doors to unconditioned attics paces shall be sealed.	The insulation in any dropped ceiling/soffit shall be aligned with the air barrier.	☐
Walls	The junction of the foundation and sill plate shall be sealed. The junction of the top plate and the top of exterior walls shall be sealed. Knee walls shall be sealed.	Cavities with corners and headers of frame walls shall be insulated by completely filling the cavity with a material having a thermal resistance of R-3 per inch minimum. Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier	☐
Windows, skylights and doors	The space between window/door jambs and framing, and skylights and framing shall be sealed.		☐
Rim joists	Rim joists are insulated and include an air barrier.	Rim joists shall be insulated.	☐
Floors (including above-garage and cantilevered floors)	The air barrier shall be installed at any exposed edge of insulation.	Floor framing cavity Insulation shall be installed to maintain permanent contact with the underside of subfloor decking, or floor framing cavity insulation shall be permitted to be in contact with the top side of sheathing, or continuous insulation installed on the underside of floor framing and extends from the bottom to the top of all perimeter floor framing members.	☐
Crawl space walls	Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.	Where provided in lieu of floor insulation, insulation shall be permanently attached to the crawlspace walls.	☐
Shafts, penetrations	Duct shafts, utility penetrations, and flue shaft openings to exterior or unconditioned space shall be sealed.		☐
Narrow cavities		Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity spaces.	☐
Garage separation	Air sealing shall be provided between the garage and conditioned spaces.		☐
Recessed lighting	Recessed light fixtures installed in the building thermal envelope shall be sealed to the drywall.	Recessed light fixtures installed in the building thermal envelope shall be air tight and IC rated.	☐
Plumbing and wiring		Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring.	☐
Shower/tub on exterior wall	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.	Exterior walls adjacent to showers and tubs shall be insulated.	☐
Electrical/phone box on exterior walls	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.		☐
HVAC register boots	HVAC register boots that penetrate building thermal envelope shall be sealed to the subfloor or drywall.		☐
Concealed sprinklers	When required to be sealed, concealed fire sprinklers shall only be sealed in a manner that is recommended by the manufacturer. Caulking or other adhesive sealants shall not be used to fill voids between fire sprinkler cover plates and walls or ceilings.		☐

a. In addition, inspection of log walls shall be in accordance with the provisions of ICC-400.

Envelope Leakage Test Report (Blower Door Test)

Residential Prescriptive, Performance or ERI Method Compliance
2020 Florida Building Code, Energy Conservation, 7th Edition

Jurisdiction: 221000

Permit Number:

Job Information

Builder: Century CMP Florida

Community:

Lot:

Address: Lot 24 SW Jewel Lake

Unit:

City: Lake City

State: FL

Zip: 32024

Air Leakage Test Results☐**PRESCRIPTIVE METHOD**

The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding 7 air changes per hour at a pressure of 0.2 inch w.g. (50 pascals) in Climate Zones 1 and 2.

☐**PERFORMANCE or ERI METHOD**

The building or dwelling unit shall be tested and verified as having an air leakage rate of not exceeding the selected ACH(50) value, as shown on FORM R405-2020 (Performance) or R406-2020 (ERI), section labeled as Infiltration, sub-section ACH50.

H

(

(

M

M

(

(

H

(

M

(

H

6.000

$$\frac{\text{CFM}(50)}{\text{Building Volume}} \times 60 \div \frac{14336}{\text{ACH}(50)} =$$

☐**PASS**☐

When ACH(50) is less than 3, Mechanical Ventilation installation must be verified by building department.

Method for calculating building volume:☐

Retrieved from architectural plans

☒

Code software calculated

☐

Field measured and calculated

R402.4.1.2 Testing. Testing shall be conducted in accordance with ANSI/RESNET/ICC 380 and reported at a pressure of 0.2 inch w.g. (50 Pascals). Testing shall be conducted by either individuals as defined in Section 553.993(5) or (7), Florida Statutes, or individuals licensed as set forth in Section 489.105(3)(f), (g), or (i) or and approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures.
2. Dampers including exhaust, intake, makeup air, back draft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures.
3. Interior doors, if installed at the time of the test, shall be open.
4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed.
5. Heating and cooling systems, if installed at the time of the test, shall be turned off.
6. Supply and return registers, if installed at the time of the test, shall be fully open.

Testing Company

Company Name: _____ Phone: _____

I hereby verify that the above Air Leakage results are in accordance with the 2020 7th Edition Florida Building Code Energy Conservation requirements according to the compliance method selected above.

Signature of Tester: _____ Date of Test: _____

Printed Name of Tester: _____

License/Certification #: _____ Issuing Authority: _____