



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM (OSTDS)

SS #: 256203241
done on: 09-13-2022

PERMIT NO. 22-0786
DATE PAID: 9/15/22
FEE PAID: 318.00
RECEIPT #: 1880894

APPLICATION FOR CONSTRUCTION PERMIT

APPLICATION FOR:

☒ New System ☐ Existing System ☐ Holding Tank ☐ Innovative
☒ Repair ☐ Abandonment ☐ Temporary ☐

APPLICANT: Calvin Eichner EMAIL: fordseptic@yahoo.com

AGENT: RONALD FORD - FORD'S SEPTIC TANK SERVICE, LLC TELEPHONE: 386-755-6288

MAILING ADDRESS: 116 N.W. Lawtey Way Lake City, Florida 32055

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3) (m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

OSTDS REMEDIATION PLAN? [Y / N]

LOT: n/a BLOCK: n/a SUBDIVISION: Meets + Bounds PLATTED:

PROPERTY ID #: 23-45-15-00372-000 ZONING: I/M OR EQUIVALENT: [Y / N]

PROPERTY SIZE: 20.00 ACRES WATER SUPPLY: ☒ PRIVATE PUBLIC [] <=2000GPD [] >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? [Y / ☒ N] DISTANCE TO SEWER: N/A FT

PROPERTY ADDRESS: 2384 SW Anderson St. Lake city, FL 32024

DIRECTIONS TO PROPERTY: go W. on Pinemount Road.
on Birtley Avenue. on Marcus Terrace.
on Anderson Street. Home #2384 on left.


BUILDING INFORMATION

☒ RESIDENTIAL ☐ COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table I, Chapter 62-6, FAC
1	M.H.	2	640	(16' x 40')
2				
3				
4				

☐ Floor/Equipment Drains ☐ Other (Specify)


SIGNATURE: R. Ford - RONALD FORD DATE: 9-8-2022



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
APPLICATION FOR CONSTRUCTION PERMIT

Permit Application Number 22-0784

PART II - SITEPLAN



Notes: Columbia County, Florida parcel id #: 23-45-15-00372-000

Address: 2384 SW Anderson Street
Lake City, Florida 32024

Site Plan submitted by: RC Ford - RONALD FORD

Plan Approved X Not Approved _____

By _____

Date 9/15/22
County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)

Incorporated: 62-6.004, F.A.C.



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM



E-MAILED

Ford

PERMIT #: 12-SC-2568236
APPLICATION #: AP1880896
DATE PAID: 9/15/22
FEE PAID: _____
RECEIPT #: _____
DOCUMENT #: PR1828100

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: CALVIN**22-0786 EICHNER
PROPERTY ADDRESS: 2384 SW ANDERSON Lake City, FL 32024
LOT: _____ BLOCK: _____ SUBDIVISION: _____
PROPERTY ID #: 00372-000 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [900] GALLONS / GPD Septic Tank CAPACITY
A [] GALLONS / GPD N/A CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [250] SQUARE FEET Drainfield SYSTEM
R [] SQUARE FEET N/A SYSTEM
A TYPE SYSTEM: [] STANDARD [x] FILLED [] MOUND []
I CONFIGURATION: [x] TRENCH [] BED []

F LOCATION OF BENCHMARK: Nail in tree E. of site

I ELEVATION OF PROPOSED SYSTEM SITE [24.00] [INCHES] FT [] ABOVE / [x] BELOW BENCHMARK/REFERENCE POINT

E BOTTOM OF DRAINFIELD TO BE [30.00] [INCHES] FT [] ABOVE / [x] BELOW BENCHMARK/REFERENCE POINT

L

D FILL REQUIRED: [12.00] INCHES EXCAVATION REQUIRED: [0.00] INCHES

O The system is sized for 2 bedrooms with a maximum occupancy of 4 persons (2 per bedroom), for a total estimated flow of 200 gpd.

T

H

E

R

SPECIFICATIONS BY: Ronald Ford TITLE: M. Ford

APPROVED BY: Dustin W Jones TITLE: Environmental Specialist II Columbia CHD

DATE ISSUED: 09/15/2022 EXPIRATION DATE: 03/15/2024

DE 4016, 08/09 (Obsoletes all previous editions which may not be used)

Incorporated: 64E-6.003, FAC