



Project Summary

Entire House

Bounds Heating and Air

Job:
Date: Oct 06, 2025
By:

Email: jlegler@boundshvac.com

Project Information

For: Curasco, Amira Builders

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	68 °F
Design TD	35 °F

Ventilation Method MJ8

Heating Summary

Structure	34685 Btuh
Ducts (R-6.0)	10269 Btuh
Central vent (0 cfm)	0 Btuh

Humidification	0 Btuh
Piping	0 Btuh
Equipment load	44954 Btuh

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	0

	Heating	Cooling
Area (ft ²)	2465	2465
Volume (ft ³)	25289	25289
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	135	67

Heating Equipment Summary

Make	Carrier
Trade	15 SEER2 HP
Model	GH5SAN54800AA0
AHRI ref	214101900

Efficiency	7.5 HSPF2
Heating input	
Heating output	47500 Btuh @ 47°F
Temperature rise	28 °F
Actual air flow	1567 cfm
Air flow factor	0.035 cfm/Btuh
Static pressure	0.50 in H2O
Space thermostat	
Capacity balance point = 32 °F	

Backup: n/a n/a
Input = 0 kW, Output = 0 Btuh, 100 AFUE

Bold/italic values have been manually overridden

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	44 gr/lb

Sensible Cooling Equipment Load Sizing

Structure	21977 Btuh
Ducts (R-6.0)	12750 Btuh
Central vent (0 cfm)	0 Btuh

Blower 0 Btuh

Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	33755 Btuh

Latent Cooling Equipment Load Sizing

Structure	2800 Btuh
Ducts	2565 Btuh
Central vent (0 cfm)	0 Btuh

Equipment latent load 5364 Btuh

Equipment Total Load (Sen+Lat)	39120 Btuh
Req. total capacity at 0.70 SHR	4.0 ton

Cooling Equipment Summary

Make	Carrier
Trade	15 SEER2 HP
Cond	GH5SAN54800AA0
Coil	FJ5ANXC48L00
AHRI ref	214101900

Efficiency	12.0 EER2, 15 SEER2
Sensible cooling	32900 Btuh
Latent cooling	14100 Btuh
Total cooling	47000 Btuh
Actual air flow	1567 cfm
Air flow factor	0.045 cfm/Btuh
Static pressure	0.50 in H2O
Load sensible heat ratio	0.87

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Load Short Form

Entire House

Bounds Heating and Air

Job:
Date: Oct 06, 2025
By:

Email: jlegler@boundshvac.com

Project Information

For: Curasco, Amira Builders

Design Information

	Htg	Clg	Infiltration	Simplified
Outside db (°F)	33	92	Method	Average
Inside db (°F)	68	75	Construction quality	0
Design TD (°F)	35	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	44		

HEATING EQUIPMENT

Make Carrier
Trade 15 SEER2 HP
Model GH5SAN54800AA0
AHRI ref 214101900

Efficiency 7.5 HSPF2
Heating input
Heating output 47500 Btuh @ 47°F
Temperature rise 28 °F
Actual air flow 1567 cfm
Air flow factor 0.035 cfm/Btuh
Static pressure 0.50 in H2O
Space thermostat
Capacity balance point = 32 °F

Backup: n/a n/a

Input = 0 kW, Output = 0 Btuh, 100 AFUE

COOLING EQUIPMENT

Make Carrier
Trade 15 SEER2 HP
Cond GH5SAN54800AA0
Coil FJ5ANXC48L00
AHRI ref 214101900

Efficiency 12.0 EER2, 15 SEER2
Sensible cooling 32900 Btuh
Latent cooling 14100 Btuh
Total cooling 47000 Btuh
Actual air flow 1567 cfm
Air flow factor 0.045 cfm/Btuh
Static pressure 0.50 in H2O
Load sensible heat ratio 0.87

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
sewing room	180	5397	3571	188	161
bath 3	60	930	753	32	34
bedroom 3	174	2292	2832	80	128
hall 1	36	0	0	0	0
bath 2	74	1026	884	36	40
bedroom 2	230	6940	3570	242	161
hall 2	43	0	0	0	0
study	132	3667	2256	128	102
great room	361	4738	4629	165	209
foyer	61	1542	794	54	36
kitchen/dining	350	5682	5337	198	241
powder	32	1364	985	48	44
drop area	101	412	259	14	12
pantry	35	51	90	2	4


Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

laundry	78	1334	1518	46	68
wic	67	860	172	30	8
storage	28	1083	358	38	16
wc	27	639	688	22	31
master bath	153	1346	1017	47	46
master suite	235	5651	5015	197	226
Entire House	2457	44954	34728	1567	1567
Other equip loads		0	0		
Equip. @ 0.97 RSM			33755		
Latent cooling			5364		
TOTALS	2457	44954	39120	1567	1567

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Level 1



Job #:
Performed for:
Curasco

Bounds Heating and Air

jlegler@boundshvac.com

Scale: 1 : 112

Page 1
Right-Suite® Universal 2025
25.0.01 RSU57217
2025-Oct-07 06:56:16
...(2025)\\Amira\\Curasco\\Curasco.rup



Manual S Compliance Report

Entire House

Bounds Heating and Air

Job:
Date: Oct 06, 2025
By:

Email: jlegler@boundshvac.com

Project Information

For: Curasco, Amira Builders

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	34728 Btuh	Entering coil DB:	77.4°F
Outdoor design WB:	75.8°F	Latent gain:	5364 Btuh	Entering coil WB:	63.7°F
Indoor design DB:	75.0°F	Total gain:	40092 Btuh		
Indoor RH:	50%	Estimated airflow:	1567 cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Carrier	Model:	GH5SAN54800AA0+FJ5ANXC48L00
Actual airflow:	1567 cfm		
Sensible capacity:	32900 Btuh	95% of load	
Latent capacity:	14100 Btuh	263% of load	
Total capacity:	47000 Btuh	117% of load	SHR: 70%

Heating Equipment

Design Conditions

Outdoor design DB:	33.2°F	Heat loss:	44954 Btuh	Entering coil DB:	66.9°F
Indoor design DB:	68.0°F				

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP		
Manufacturer:	Carrier	Model:	GH5SAN54800AA0+FJ5ANXC48L00
Actual airflow:	1567 cfm		
Output capacity:	47500 Btuh	106% of load	
Supplemental heat required:	0 Btuh		
		Capacity balance:	32 °F
		Economic balance:	-99 °F

Backup equipment type:	Elec strip		
Manufacturer:	n/a	Model:	n/a+n/a
Actual airflow:	1567 cfm		
Output capacity:	0 kW	0% of load	Temp. rise: 0 °F

Meets all requirements of ACCA Manual S.



Duct System Summary

Entire House

Bounds Heating and Air

Job:
Date: Oct 06, 2025
By:

Email: jlegler@boundshvac.com

Project Information

For: Curasco, Amira Builders

	Heating	Cooling
External static pressure	0.50 in H ₂ O	0.50 in H ₂ O
Pressure losses	0 in H ₂ O	0 in H ₂ O
Available static pressure	0.50 in H ₂ O	0.50 in H ₂ O
Supply / return available pressure	0.394 / 0.106 in H ₂ O	0.394 / 0.106 in H ₂ O
Lowest friction rate	0.188 in/100ft	0.188 in/100ft
Actual air flow	1567 cfm	1567 cfm
Total effective length (TEL)	266 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath 2	c 884	36	40	0.204	4.0	0x0	VIFx	62.5	130.0	st3
bath 3	c 753	32	34	0.202	4.0	0x0	VIFx	65.2	130.0	st3
bedroom 2	h 6940	242	161	0.188	7.0	0x0	VIFx	74.4	135.0	st3
bedroom 3	c 2832	80	128	0.208	7.0	0x0	VIFx	59.3	130.0	st3
drop area	h 412	14	12	0.375	4.0	0x0	VIFx	15.0	90.0	st1
foyer	h 1542	54	36	0.256	4.0	0x0	VIFx	43.5	110.0	st2
great room	c 2314	83	104	0.262	6.0	0x0	VIFx	40.5	110.0	st2
great room-A	c 2314	83	104	0.214	6.0	0x0	VIFx	53.5	130.0	st3
kitchen/dining	c 2669	99	120	0.273	7.0	0x0	VIFx	33.9	110.0	st2
kitchen/dining-A	c 2668	99	120	0.264	7.0	0x0	VIFx	38.9	110.0	st2
laundry	c 1518	46	68	0.343	5.0	0x0	VIFx	24.7	90.0	st1
master bath	h 1346	47	46	0.370	4.0	0x0	VIFx	16.3	90.0	st1
master suite	c 2507	99	113	0.355	6.0	0x0	VIFx	20.7	90.0	st1
master suite-A	c 2507	98	113	0.348	6.0	0x0	VIFx	23.0	90.0	st1
pantry	c 90	2	4	0.355	4.0	0x0	VIFx	20.9	90.0	st1
powder	h 1364	48	44	0.365	4.0	0x0	VIFx	17.8	90.0	st1
sewing room	h 5397	188	161	0.197	7.0	0x0	VIFx	69.4	130.0	st3
storage	h 1083	38	16	0.358	4.0	0x0	VIFx	20.0	90.0	st1
study	h 3667	128	102	0.201	6.0	0x0	VIFx	60.7	135.0	st3
wc	c 688	22	31	0.375	4.0	0x0	VIFx	15.1	90.0	st1
wic	h 860	30	8	0.380	4.0	0x0	VIFx	13.5	90.0	st1

Bold/italic values have been manually overridden

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3	Peak AVF	789	730	0.188	738	14.0	0 x 0	VinIFlx	st2
st2	Peak AVF	1123	1111	0.188	804	16.0	0 x 0	VinIFlx	st1
st1	Peak AVF	1567	1567	0.188	887	18.0	0 x 0	VinIFlx	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x 0	1567	1567	56.6	0.188	594	22.0	0x 0		VIFx	rst4

Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rst4	Peak AVF	1567	1567	0.188	887	18.0	0 x 0	VinIFlx	

Bold/italic values have been manually overridden

