



MAC JOHNSON ROOFING, INC.

ROOFING CONTRACTOR

CCC1325497

Po Box 367 Newberry, Fl 32669
(352) 472-1365 FAX (352) 472-1369
(866)376-4943




PREFERRED
CONTRACTOR

Jerry Tomsey
3356 SW CR 18
Fort White Fl. 32038
Columbia County
Permit #000047333

To: Columbia County Building inspector

Per Mac Johnson Roofing's discussion on the cricket requirement with Columbia Counties final inspection on the above mentioned property and permit number, Mac Johnson Roofing has spoken to our customer Jerry Tomsey in regards to the chimney cricket required on above mentioned property. Customers chimney is a unique large stoned walled chimney that would need to be modified to what would be considered a very unattractive finish to accommodate the cricket request due to pitch of roof and random stone design. It has been discussed with Mr. Tomsey and he has expressed his desire to keep the current integrity of the chimney without the cricket and has confirmed the chimney has no current leaking issues. Upon a discussion with the building inspector on the appearance issue an option to install a diverter upon homeowners approval and confirmation of no chimney leak and satisfaction of current flashing could be done as an alternative. Jerry Tomsey has agreed to this alternative and Mac Johnson Roofing will be performing the installation of the diverter per the agreement made by all parties, Columbia County Building inspector Jerry Tomsey and Mac Johnson Roofing.

Mac Johnson Roofing


Brian Saltzman / Operations Manager

Jerry Tomsey


Homeowner