



**Britt Surveying and Mapping, LLC**

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

02/21/2025

L-30910 F

Permit # 000051354


Re: Lot 1 Capital Business Park

Plumb Level Construction

To Whom It May Concern:

The finished floor elevation on Lot 1 is determined to be 99.88' feet. The plans on this parcel shows an engineer stating 99.00 was sufficient for a minimum floor elevation. The elevations are shown in NAVD 88 datum.

Sincerely,

  
L. Scott Britt

LS 5757