



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/03/2023

Permit # 000045805

L-29151

Re: 08481-002

Juliana Moore

To Whom It May Concern:

The finished floor elevation is found to be 97.69 feet. The engineering letter provided to our office establishes the minimum floor elevation to be 96.80 feet. All elevations shown hereon are based on NAVD 88 datum.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over a circular, faded official seal.

L. Scott Britt
LS 5757