

Permit #51169



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

12/18/2024

L-30984

Re: Lots 1 & 2 Timuqua

Permit #000051169

William Perri

To Whom It May Concern:

The finished floor elevation of the slab is determined to be 103.6 feet. The elevation of SW Hawk Lane is found to be 100.0 feet. The building permit requires the floor to be 1 foot higher than SW Hawk Lane. The elevations are shown in an assumed datum.

Sincerely,


L. Scott Britt
LS 5757

