



Britt Surveying and Mapping, LLC

1438 SW Main Boulevard • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

03/29/2022

L-28488

Permit # 000043447


Plumb Level Construction

Re: Lot 4 Turkey Creek

To Whom It May Concern:

The elevation of the foundation on Lot 4 is found to be 159.65 feet. The centerline of NW Turkey Run Court is found to be 158.2 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt

LS 5757
