

**Tallahassee**

4770 Woodlane Circle  
Unit A  
Tallahassee, FL 32303  
Phone: 850.421.6682  
Fax: 850.249.6683

**Client:**

Ajax Building Corporation  
1080 Commerce Blvd.  
Midway, FL 32343

**Project:**

10117-1020031.000  
Columbia County Detention Facility Materials  
Testing  
Jacksonville, Florida

**Activity Number:** 78

**Date:** 01/08/2021

**Weather:** Cloudy

**Temperature:** 55

**Location:** Column lines 1 to 11 and column lines A2 to A23. Elevation : 178.43

**NOVA Representative:** Louis Roberts

At the request of the contractor, the above noted NOVA representative visited the columbia county detention facility project to evaluate a proofroll on the prepared building pad within the building limits of column lines A2 through A23 and column lines 1 to 11.

The proofroll began at the East corner and progressed to the West side between column lines 1 to 11 and progressed from the North corner to the South side between column lines A2 to column line A23 using overlapping passes. The proofroll was performed using a fully loaded dump truck, reported to weigh approximately 64,000 Lbs.

Based on the observation of the proofroll, the observed subgrade appears firm, stable and suitable for the placement of the required structural fill.



Should the exposed subgrade approved this date be exposed to rain, freezing or other inclement conditions prior to sealing/paving/concrete placement, etc. NOVA recommends re-evaluation.

**No observations, tests, inspections or approvals by NOVA shall relieve the Contractor from his obligation to perform the Work in strict conformity with the Contract Documents. NOVA's inspections and/or tests reported herein are in no way a guarantee of deficient-free construction. The information provided herein is intended for the sole and exclusive use of our Client unless other written agreement is entered into by NOVA and other parties. All other recipients are provided this document and any corresponding tests and/or inspection results for information purposes only, and any use of said information shall be at their sole risk.**

**Tallahassee**  
4770 Woodlane Circle  
Unit A  
Tallahassee, FL 32303  
Phone: 850.421.6682  
Fax: 850.249.6683

**Client:**  
Ajax Building Corporation  
1080 Commerce Blvd.  
Midway, FL 32343

**Project:**  
10117-1020031.000  
Columbia County Detention Facility Materials  
Testing  
Jacksonville, Florida

Images	
Picture	Caption
	Proof rolling east to west, building pad appears to be firm and un-yealding.
	Proof rolling north to south, building pad appears to be firm and un-yealding.

Electronically signed and sealed by  
William L. Lawrence, P.E., Senior Regional  
Engineer on Jan 08, 2021 using a Digital  
Signature.