

August 12, 2020

Charles Peeler Construction
2102 SW Dairy Street
Lake City, FL 32024

Subject: Permit # 40306 – Parcel # 08110-000

Dear Chuck:

Daniel & Gore, LLC has performed a vertical survey on Parcel # 08110-000, Columbia County, Florida from a benchmark being a concrete monument, PSM 5757 on the East property line (elevation – 161.66', NAVD 1988) and have determined the following:

- The Construction Plans by Carol Chadwick, PE requires the finish floor elevation of the proposed school to be 163.0'.
- The finish floor elevation of the school building is at 163.3', being 0.3' above the finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

