

November 28, 2022

Pam Seely
343 SW Federal Court
Lake City, FL 32038

Subject: Parcel # 03745-319 - Elevation Letter

Dear Pam:

Daniel & Gore, LLC has performed a vertical survey on Parcel 03745-319, Columbia County, Florida from a benchmark being a FDOT concrete monument 2902007 BM10 (elevation – 77.63', NAVD 1988) and have determined the following:

- The elevation of the concrete foundation slab is at 63.75' and being 0.25' above the required minimum finished floor elevation as determined in a letter by Carol Chadwick, P.E., dated 06/22/2022.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

