Job: J-10893 - C-1309 Date: Jun 06, 2024 LaNiika Stewart

# **Project Information**

COOLWATER/MCNUTT RESIDENCE For: Columbia County, FL

Notes:

# **Design Information**

Weather: Gainesville, FL, US

### **Winter Design Conditions**

### **Summer Design Conditions**

Outside db	33 °F	Outside db	92 °F
Inside db	70 °F	Inside db	75 °F
Design TD	37 °F	Design TD	17 °F
<b>o</b>		Daily range	M
		Relative humidity	50 %
Ventilation Method	MJ8	Moisture difference	43 gr/lb

### **Heating Summary**

## **Sensible Cooling Equipment Load Sizing**

Structure Ducts (R-6.0) Central vent (0 cfm)	4180 Btuh 452 Btuh 0 Btuh	Structure Ducts (R-6.0) Central vent (0 cfm)	6667 Btuh 501 Btuh 0 Btuh
Humidification	0 Btuh 0 Btuh	Blower	0 Btuh
Piping Equipment load	4633 Btuh	Use manufacturer's data	n
Infiltra	tion	Rate/swing multiplier Equipment sensible load	0.97 6981 Btuh

Simplified

# **Latent Cooling Equipment Load Sizing**

Construction quality Fireplaces		Average 0	Structure Ducts Central vent (0 cfm)	708 Btuh 97 Btuh 0 Btuh
Area (ft²) Volume (ft³)	<b>Heating</b> 224 1792	<b>Cooling</b> 224 1792	Equipment latent load	806 Btuh
Air changes/hour Equiv. AVF (cfm)	0.67 20	0.35 10	Equipment Total Load (Sen+Lat) Req. total capacity at 0.80 SHR	7787 Btuh 0.7 ton

### **Heating Equipment Summary**

### **Cooling Equipment Summary**

Make	GREE ELECTRIC AP	PLIANC	ES INC. OF ZHU			CTRIC APPLIA	NCES	INC. OF ZHUH	iΑl
Trade	GREE			Trade	GREE				
Model	4LIV09HP230V1AO			Cond	4LIV09HP2	30V1AO			
AHRI ref	210278963			Coil	4LIV09HP2	30V1AH			
				AHRI ref	210278963				
Efficiency		8.8 F	HSPF2	Efficiency	1	1.3 EER2,19.5	SEER	2	
Heating inpu	ut			Sensible co	oling		7280	Btuh	
Heating outp	out	10000	Btuh @ 47°F	Latent cooli	ng ັ		1820	Btuh	
Temperature	e rise	30	°F	Total coolin	g		9100	Btuh	
Actual air flo		303	cfm	Actual air flo			303	cfm	
Air flow factor	or	0.065	cfm/Btuh	Air flow fact	or		0.042	cfm/Btuh	
Static pressi	ure	0	in H2O	Static press	ure		0	in H2O	
Space therm	nostat			Load sensib	ole heat ratio		0.90		
Canacityhal	ance point = 15 °F								

Capacity balance point = 15 °F

Method

Input = 1 kW, Output = 4333 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Notes:

Job: J-10893 - C-1309 Date: Jun 06, 2024 LaNiika Stewart

# **Project Information**

COOLWATER/MCNUTT RESIDENCE For: Columbia County, FL

# **Design Information**

Weather: Gainesville, FL, US

### **Winter Design Conditions**

### **Summer Design Conditions**

Outside db Inside db	33 °F 70 °F	Outside db Inside db	92 °F 75 °F
Design TD	37 °F	Design TD Daily range	17 °F M
Ventilation Method	MJ8	Relative humidity Moisture difference	50 % 43 gr/lb

#### **Heating Summary**

### Sensible Cooling Equipment Load Sizing

Structure Ducts (R-6.0) Central vent (0 cfm)	427	Btuh Btuh Btuh	Structure Ducts (R-6.0) Central vent (0 cfm)	478	Btuh Btuh Btuh
Humidification Piping Equipment load	_	Btuh Btuh	Blower	0	Btuh
Equipment load	4864	Btuh	Use manufacturer's data	r	1
Infiltration			Rate/swing multiplier Equipment sensible load	0.97 7365	Btuh

Method Construction quality	Simplified	Latent Cooling I	Equipment Load Sizing
Fireplaces	Average	Structuro	204 Rtub

Fireplaces		0	Structure Ducts Central vent (0 cfm)	93	Btuh Btuh Btuh
Area (ft²) Volume (ft³)	<b>Heating</b> 208 2045	<b>Cooling</b> 208 2045	Equipment latent load	388	Btuh
Air changes/hour Equiv. AVF (cfm)	0.56 19	0.29 10	Equipment Total Load (Sen+Lat) Req. total capacity at 0.80 SHR	7752 0.8	

### **Heating Equipment Summary**

# **Cooling Equipment Summary**

Make	GREE ELECTRIC AP	PLIANC	ES INC. OF ZHU	H <b>M</b> ake	GREE ELEC	CTRIC APPLIANCES	S INC. OF ZHUHAI
Trade	GREE			Trade	GREE		
Model	4LIV09HP230V1AO			Cond	4LIV09HP23	30V1AO	
AHRI ref	210278963			Coil	4LIV09HP23	30V1AH	
				AHRI ref	210278963		
Efficiency		8.8 F	HSPF2	Efficiency	11	1.3 EER2,19.5 SEEF	R2
Heating inpu	ut			Sensible co			) Btuh
Heating outp	out	10000	Btuh @ 47°F	Latent cooli		1820	) Btuh
Temperature		30	°F	Total coolin	a	9100	) Btuh
Actual air flo	)W	303	cfm	Actual air flo	о́w	303	s cfm
Air flow factor	or	0.062	cfm/Btuh	Air flow fact	or	0.040	) cfm/Btuh
Static press	ure	0	in H2O	Static press	ure	C	in H2O
Space thern	nostat				ole heat ratio	0.95	)

Capacity balance point = 16 °F

Backup:

Input = 1 kW, Output = 4680 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Job: J-10893 - C-1309 Date: Jun 06, 2024 LaNiika Stewart

# **Project Information**

COOLWATER/MCNUTT RESIDENCE For:

Columbia County, FL

# **Cooling Equipment**

### **Design Conditions**

Outdoor design DB:	92.4°F	Sensible gain:	7168	Btuh	Entering coil DB:	75.6°F
Outdoor design WB:	75.8°F	Latent gain:	806	Btuh	Entering coil WB:	62.8°F
Indoor design DB:	75.0°F	Total gain:	7973	Btuh	_	
Indoor RH:	50%	Estimated airflow:	303	cfm		

### Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: GREE ELECTRIC APPLI Model: 4LIV09HP230V1AO+4LIV09HP230V1AH

Actual airflow: 303 cfm

102% of load Sensible capacity: 7280 Btuh Latent capacity: 1820 Btuh 226% of load

Total capacity: 9100 114% of load SHR: 80% Btuh

### **Heating Equipment**

#### **Design Conditions**

Outdoor design DB: 33.3°F Heat loss: 4633 Btuh Entering coil DB: 69.7°F

Indoor design DB: 70.0°F

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP

Manufacturer: GREE ELECTRIC APPLI Model: 4LIV09HP230V1AO+4LIV09HP230V1AH

Actual airflow: 303 cfm

Output capacity: 10000 Btuh Capacity balance: 15 °F 216% of load Economic balance: Supplemental heat required: 0 Btuh -99 °F

Backup equipment type: Elec strip

Manufacturer: Model:

Actual airflow: 303 cfm

50 °F Output capacity: 1.3 kW 94% of load Temp. rise:

Meets all requirements of ACCA Manual S.

Job: J-10893 - C-1309 Date: Jun 06, 2024 LaNiika Stewart

## **Project Information**

COOLWATER/MCNUTT RESIDENCE For:

Columbia County, FL

# **Cooling Equipment**

### **Design Conditions**

Outdoor design DB:	92.4°F	Sensible gain:	7561	Btuh	Entering coil DB:	75.6°F
Outdoor design WB:	75.8°F	Latent gain:	388	Btuh	Entering coil WB:	62.8°F
Indoor design DB:	75.0°F	Total gain:	7949	Btuh	-	
Indoor RH:	50%	Estimated airflow:	303	cfm		

### Manufacturer's Performance Data at Actual Design Conditions

Split ASHP Equipment type:

Manufacturer: GREE ELECTRIC APPLI Model: 4LIV09HP230V1AO+4LIV09HP230V1AH

Actual airflow: 303 cfm

96% of load Sensible capacity: 7280 Btuh 470% of load Latent capacity: 1820 Btuh

Total capacity: 9100 114% of load SHR: 80% Btuh

### **Heating Equipment**

#### **Design Conditions**

Outdoor design DB: 33.3°F Heat loss: 4864 Btuh Entering coil DB: 69.7°F

Indoor design DB: 70.0°F

#### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP

Manufacturer: GREE ELECTRIC APPLI Model: 4LIV09HP230V1AO+4LIV09HP230V1AH

Actual airflow: 303 cfm

Output capacity: 10000 Btuh Capacity balance: 16 °F 206% of load Economic balance: Supplemental heat required: 0 Btuh -99 °F

Backup equipment type: Elec strip

Manufacturer: Model:

Actual airflow: 303 cfm

50 °F Output capacity: 1.4 kW 96% of load Temp. rise:

Meets all requirements of ACCA Manual S.