

NTERIOR BEARING WALLS SHALL BE CONSTRUCTED IN CPLIANCE WITH "UL Design U333", BATT INSULATION SHALL INCLUDED WHERE UNCONDITIONED AREA IS BEING SEPAFROM HEATED / COOLED AREA.

COM-L BE ARATED

ANY AND ALL DISPUTES ARISING FROM EVENTS ASSOCI. WITH THE CONSTRUCTION OF THIS PROJECT BETWEEN THE DWNER, CONTRACTOR(S) AND SUPPLIERS SHALL BE RES THROUGH BINDING ARBITRATION.

SOLVED

CHANGES TO FINAL PLAN SETS

FOOTINGS AND FOUNDATIONS
FOOting: 20"X|2" Cont. W/2-#5 Cont.

wire chairs a 48" O.C

BUILDING COMPONENTS & CLADDING LOADS
MEAN BUILDING HEIGHT = 300, EXPOSURE "B

RICANE UPLIFT CONNECTORS

Truss Anchors: Simpson H25a @ Ea. Truss End (Typ. U.O.N.)

Wall Tension: Wall Sheathing Nailing is Adequate - 8d @ 4" O.C.

Anchor Bolts: 1/2" A3ØT @ 48" O.C. - 1st Bolt 8" from corner

Corner Hold-down Device: Simpson HD2a, ea. corner

EASE DO NOT MAKE ANY STRUCTURAL CHANGES TO THESE PLANS WITHOUT NISULTING WITH THE ARCHITECT. THE OWNER SHALL ASSUME ANY AND ALL ABILITY FOR STRUCTURAL DAMAGE RESULTING FROM CHANGES MADE TO BE PLANS OR BY SUBSTITUTION OF MATERIALS DIFFERENT FROM PLANS.

ATED

DO NOT SCALE OFF THESE PLANS
AMPLE DIMENSIONS ARE SHOWN ON THE PLANS TO LOCATE ALL ITEMS.
SIMPLE ARITHMETIC MAY BE USED TO DETERMINE THE LOCATIONS OF THOSE ITEMS NOT DIMENSIONED.

CONSTRUCTION DOCUMENTS

THE CUSTOMER IS RESPONSIBLE FOR DELIVERING THE REQUIRED SETS OF CONSTRUCTION DOCUMENTS TO THE PERMIT ISSUING AUTHORITIES, FOR THE ISSUANCE OF CONSTRUCTION PERMITS. THE CONTRACTOR SHALL REVIEW THE CONSTRUCTION DOCUMENTS AND VERIFY ALL DIMENSIONS. ANY DISCREPANCIES SHALL BE REPORTED TO THE ARCHITECT PRIOR TO THE COMMENCEMENT OF ANY WORK OR FABRACATION OF ANY MATERIALS.

HEARWALLS

Material: 1/16" O.S.B. "WindSTORM": 48" X 97", 1009", 121" OR 145"

Sheet Size: 48"x97" (1009", 121" OR 145") Sheets Placed Vertical

Fasteners: 8d Ring Shank Nails & 4" O.C. Edges & 8" O.C. Interior

Dragstrut: Double Top Plate (5.Y.P.) W/2 - 16d Nails & 12" O.C.

Wall Studs: 2x4 SPF Studs & 16" O.C.

ELECTRICAL CODE: NATIONAL ELECTRICAL CODE - LATEST LIFE SAFETY: NFPA-101 - LATEST

BUILDING CODE: 2014 FLORIDA BUILDING CODE

LIVE LOADS: 1st FLOOR: 40PSF, 2nd FLOOR: 40PSF, ROOF: AS DETERMINED BY SHAPE FACTORS APPLIED TO THE WIND FORCE GENERATED BY THE DESIGN WIND SPEED.

SOIL DESIGN STATEMENT:
FOOTING DESIGN IS BASED UPON IØØØPSF SOIL BEARING PRESSURE PROVIDED BY CLEAN SAND, GRAYEL OR STONE. OTHER SOIL CONDITIONS
IC: CLAY, HIGH LEVEL OF ORGANICS OR OTHER UNDESIRABLE SOILS SHALL
REQUIRE FOUNDATION MODIFACATIONS.

TYPE OF CONSTRUCTION

г 0

<u>α</u>

Þ

W

<u>_</u>

Г

v S O

0 0

Ω

O 0

z o

0

0

3 C O

3

s S

Œ

RAMING

ANCHOR

SCHEDULE

Roof: Gable Construction, Wood Trusses © 24" O.C. Walls: 2x4 Wood Studs © 16" O.C. Floor: 4" Thk Concrete Slab W/ Fibermesh Concrete Foundation: Continuous Stemwall Footer

OOF DECKING

Material: 1/2" CD Plywood or 1/16" O.S.B. Sheet Size: 48"x96" Sheets Perpendicular to Roof Framing Fasteners: 8d Ring Shank Nails per schedule on sheet A.T

ALL WORK SHALL BE IN ACCORDANCE W/ APPLICABLE ENE AND LOCAL REGULATIONS, INCLUDING APPLICABLE ENE CODES. ALL COMPONENTS OF THE BUILDING SHALL MEE THE MINIMUM ENERGY REQUIREMENTS OF THE BUILDING O ANY DISCREPANCIES SHALL BE REPORTED TO THE ARC ANY DISCREPANCIES SHALL BE REPORTED TO THE WORK

. INSULATION SHALL BE LEFT EXPOSED AND ALL LABLES T INTACT ON THE WINDOWS AND DOORS UNTIL INSPECTED THE BUILDING OFFICIAL.

. WOOD IN CONTACT WITH CONCRETE OR MASONRY PRESSURE TREATED.

SHALL

THE OWNER SHALL FILE A "NOTICE OF COMMENCEMENT" PRIOR TO THE BEGINNING THE THE PROJECT AND THE CONTRACTOR(S) SHALL FILE "NOTICE TO OWNER" AND PROVIDE "RELEASE OF LIEN" FOR ALL PAYMENT REQUESTS PRIOR TO DISBURSEMENT OF ANY EINTIG

THE CONTRACTOR SHALL PAY FOR ALL PERMITS, LICENS IESTS AND THE LIKE THAT MAY BE REQUIRED BY THE VOUS AUTHORITIES HAVING JURISDICTION OVER THIS PROBE THEY CITY, COUNTY, STATE OR FEDERAL.

NTERIOR STUD WALLS SEPARATING LIVING AREA FROM AGE AREAS SHALL BE CONSTRUCTED IN COMPLIANCE U "UL Design U333", INCLUDING R-11 BATT INSULATION.

ETH GAR-

> Z $\boldsymbol{\Omega}$ ightharpoons**7**0 A ▶ $\boldsymbol{\omega}$ $\boldsymbol{\omega}$ 70 Ш < _ ➣ 0 S S

S

INTERIOR LAVATORY NSULATION

PLUS OR MINUS Z X X MAXIMUM AMINATED

CENTERLINE

THOUT

No. or Nr. д 0 MISCELL ASONRY

FIREDLOCKING NOTES:

TRATIONS

OFFIT/DROPPED CLG.

ONE INCH

PENNY

Ž

<u> 후</u>

ONE FOOT

BY OTHERS

CELING

IBLOCKING SHALL BE INSTALLED IN WOOD FRAME CONSTRUCTION IN THE

AT OPENINGS AROUND VENTS, PIPES, DUCTS, CHIMNEYS AND FIREPLACES AT CEILING AND FLOOR LEVELS WITH "PYROPANEL MULTIFLEX SEALANT"

AT ALL INTERCONNECTIONS BETWEEN CONCEALED VERTICAL AND HORIZONTAL SPACES SUCH AS OCCUR AT SOFFITS, DROP CEILINGS, COVE CEILINGS, ETC.

IN CONCEALED SPACES OF STUD WALLS SPACES AT CEILING AND FLOOR LEVELS.

AT ALL INTERCONNECTIONS BETWEEN CONCEALED VERTICAL STUD WALL OR PARTITION SPACES AND CONCEALED SPACES CREATED BY AN ASSEMBLY OF FLOOR JOISTS, FIREBLOCKING SHALL BE PROVIDED FOR THE FULL DEPTH OF THE JOISTS AT THE ENDS AND OVER THE SUPPORTS.

PLYWD. (ED)

IS. A CERTIFICATE OF COMPLIANCE MUST BE ISSUED TO THE BUILDING DEPARTMENT BY *LICENSED PEST CONTROL COMPANY BEFORE A CERTIFICATE OF OCCUPANCY WILL BE ISSUED. THE CERTIFICATE OF COMPLIANCE SHALL STATE:
"THE BUILDING HAS RECEIVED A COMPLETE TREATMENT FOR THE PREVENTION OF SUBTERRANEAN TERMITES. THE TREATMENT IS IN ACCORDANCE WITH THE RULES AND LAWS OF THE FLORIDA DEPARTMENT OF AGRICULTURE AND CONSUMER SERVICES". FBC 1816.1.7

「 で の

Stopping

LEVATION

-IDING GLAS

SS DOOR

ER LOG HOMES

RENCH (DOORS

SOIL CHEMICAL BARRIER METHOD:

XCEPTION: PAINT AND DECORATIVE CEMENTIOUS FINISH LESS THAN 5/8" HICK ADHERED DIRECTLY TO THE FOUNDATION WALL. FBC 1403.16 TO PROVIDE FOR INSPECTION FOR TERMITE INFESTATION, BETWEEN WALL OVERINGS AND FINAL EARTH GRADE SHALL NOT BE LESS THAN 6". IRRIGATION/SPRINKLER SYSTEMS INCLUDING ALL RISERS AND SPRAY ADS SHALL NOT BE INSTALLED WITHIN 1'-0" FROM BUILDING SIDE WALLS. C 1503.4.4

II. AN EXTERIOR VERTICAL CHEMICAL BARRIER MUST BE INSTALLED AFTER CONSTRUCTION IS COMPLETE INCLUDING LANDSCAPING AND IRRIGATION. ANY SOIL DISTURBED AFTER THE VERTICAL BARRIER IS APPLIED, SHALL BE RETREATED. FBC 186.16 8. MINIMUM 6 MIL VAPOR RETARDER MUST BE INSTALLED TO PROTECT AGAINST RAINFALL DILUTION. IF RAINFALL OCCURS BEFORE VAPOR RETARDER PLACEMENT, RETREATMENT IS REQUIRED. FBC 1816.1.4

9. CONCRETE OVERPOUR AND MORTAR ALONG THE FOUNDATION PERIMETER MUST BE REMOVED BEFORE EXTERIOR SOIL TREATMENT. FBC 1816.1.5

100. SOIL TREATMENT MUST BE APPLIED UNDER ALL EXTERIOR CONCRETE OR GRADE WITHIN 11-01" OF THE STRUCTURE SIDEWALLS. FBC 1816.1.6

2. ALL BUILDINGS ARE REQUIRED TO HAVE PER-CONSTRUCTION TREATMENT. -BC 1816.1.7

IB. NO WOOD, YEGETATION, STUMPS, CARDBOARD, TRASH, ETC., SHALL BE BURIED WITHIN IB'-O" OF ANY BUILDING OR PROPOSED BUILDING. FBC 2303.1.4

I. A PERMANENT SIGN WHICH IDENTIFIES THE TERMITE TREATMENT PROVIDER AND NEED FOR REINSPECTION AND TREATMENT CONTRACT RENEWAL SHALL BE PROVIDED. THE SIGN SHALL BE POSTED NEAR THE WATER HEATER OR ELECTRIC PANEL. FBC 104.26
2. CONDENSATE AND ROOF DOWNSPOUTS SHALL DISCHARGE AT LEAST 1'-0" AWAY FROM BUILDING SIDE WALLS. FBC 1503.4.4

5. INITIAL TREATMENT SHALL BE DONE AFTER ALL EXCAVATION AND BACKFILL IS COMPLETE. FBC 1816.1.1
6. SOIL DISTURBED AFTER THE INITIAL TREATMENT SHALL BE RETREATED INCLUDING SPACES BOXED OR FORMED. FBC 1816.1.2
1. BOXED AREAS IN CONCRETE FLOOR FOR SUBSEQUENT INSTALLATION OF TRAPS, ETC., SHALL BE MADE WITH PERMANENT METAL OR PLASTIC FORMS. PERMANENT FORMS MUST BE OF A SIZE AND DEPTH THAT WILL ELIMINATE THE DISTURBANCE OF SOIL AFTER THE INITIAL TREATMENT. FBC 1816.1.3

14. AFTER ALL WORK 16 COMPLETED, LOOSE WOOD AND FILL MUST BE REMOVED FROM BELOW AND WITHIN 1'-0" OF THE BUILDING. THIS INCLUDES ALL GRADE STAKES, TUB TRAP BOXES, FORMS, SHORING OR OTHER CELLULOSE CONTAINING MATERIAL. FBC 2303.13

VELLEY VELLEY

PROTECTION NOTES

	l		
्र _२ ८८ ज	HEIGHT BLDG	HEIGHT ≰ E	
	"B" EXPOSURE	ING COMPONEN	_
129 135	"C"	HEIGHT & EXPOSURE ADJUSTMENT COEFFICIE	-
<u> </u>	₽ <u>₩</u>	<i>\\</i> '' $\stackrel{\square}{\Box}$	

OSB SHEATHING, 7/16" THICK

 $\overset{\mathcal{O}}{\alpha}$

30" O.C.
32" O.C.
32" O.C.
4 STACGERRED 2 SEA ENDES
6" O.C. SEDGES
INTERNEDIATE
6" O.C. SEDGES
INTERNEDIATE
6" O.C. SEDGES
INTERNEDIATE
6" O.C. SEDGES
INTERNEDIATE
5" O.C. SEDGES
INTERNEDIATE
5" O.C. SEDGES
INTERNEDIATE
5" O.C. SEDGES
INTERNEDIATE
5" O.C. SEDGES
INTERNEDIATE

PLYWOOD

SUBFL

FIBERBOARD

PNITTATHO

AILS, BOLTS AND OTHER METAL CONNECTORS OCATIONS EXPOSED TO THE WEATHER SHALL THERWISE CORROSION RESISTANT.

GALVANIZED OR

STRUCTURAL DESIGN CRITERIA: 1. THE DESIGN COMPLIES WITH THE REQUIREMENTS OF THE 2014 FLORIDA 2. THE DESIGN COMPLIES WITH THE REQUIREMENTS OF THE 2014 FLORIDA
´ĭŏ

I. THE DESIGN COMPLIES WITH THE REQUIRE: LIVE COMES AND OTHER REFERENCED CODES AND SPECIFICATIONS SHALL BE LATES: AT TIME OF PERMIT. WIND LOAD CRITERIA: RISK CATAGORY: 2 NO EDITION

Ω

GLUNG SHALL NOT BE CONSIDERED LIEU OF THOSE SPECIFIED HEREIN.

AN ACCEPTABLE CONNECTOR IN

THERE SHALL BE NOT LESS THAN 2 NAILS PER CONNE

A GENERAL, NAILS SHALL PENETRATE THE SECOND MEMBER A D ANCE EQUAL TO THE THICKNESS OF THE MEMBER BEING NAILED HERETO, OR GREATER.

4. FLOOR DESIGN LOADS:
SUPERIMPOSED DEAD LOADS:
SUPERIMPOSED LIVE LOADS:
RESIDENTIAL
BALCONIES BASED ON ANSI/ASCE 1-10, 2014 FBC 1609-A WIND ... 25 PSF

WIND NET UPLIFT: ARE AS INDICATED ON TRUSS SHOP DRAWING

SYMBOLS ARE MOST OFTEN ENCOUNTERED IN THE FOLLOWING DRAWINGS: ELEVATIONS, DIMENSION PLANS, SECTIONS & STRUCTURAL PLANS YMBOLS

TYPE OF DETAIL MARK USED TO INDICATE A SECTION ie: SECTION "A" ON SHEET "A.5", TAIL INDICATES DIRECTION OF VIEW TYPE OF ELEVATION MARK USED TO INDICATE A PREFERRED TARGE ELEVATION - TRUE MEASUREMENT. TYPE OF DETAIL MARK USED TO INDICATE A SECTION OR DETAIL ASSOCIATED WITH A PLAN VIEW TYPE OF ELEVATION MARK USED TO INDICATE THE TOP OF A LOGWALL STACK - NOMINAL ONLY.

30 to 50 to	# th	ᇕᆂ	W.A	LL.	ROO	F 7° TO 27'		
0 0	HEIGHT BLDG		שטטט	444	ω ω ω	222		ZONE
		21112 11 * E	200	5000	5 6 6	5000	9 8 <u>0</u>	AREA
0000	EXPOSURE	* EXPOSURE .	21.8 / -29.1 20.8 / -27.2 19.5 / -24.6	21.8 / -23.6 20.8 / -22.6 19.5 / -21.3	12.5 / -51.3 11.4 /-47.9 10.0 / -43.5	12.5 / -34.7 11.4 / -31.9 10.0 / -28.2	12.0 / -19.9 11.4 / -19.4 10.0 / -18.6	Helk Øll
129 135 1.40	"C"	HEIGHT & EXPOSURE ADJUSTMENT COEFFICIENTS	25.9 / -34.7 24.7 / -32.4 23.2 / -29.3	25.9 / -34.7 24.7 / -26.9 23.2 / -25.4	14.9 / -61.0 13.6 / -57.1 11.9 / -51.8	14.9 / -41.3 13.6 / -38.0 11.9 / -33.6	14.9 / -23.7 13.6 / -23.0 11.9 / -22.2	Yult 120 MPH
14. 16. 16. 16. 16. 16.		T COEFFICIE	30.4 /-40.7 29.0 / -38.0 27.2 / -34.3	30,4 / -33,0 29,0 / -31,6 27,2 / -29,8	11.5 / -11.6 16.0 / -61.0 13.9 / -60.8	17.5 / -48.4 16.0 / -44.6 13.9 / -39.4	11.5 / -27.8 16.0 / -27.0 13.9 / -26.0	Yult 130 MPH
<i>6</i> − û ¬	"D"	ENTS	35.3 / -47.2 33.7 / -44.0 31.6 / -39.8	35.3 / -38.2 33.7 / -36.7 31.6 / -34.6	203 / -83. 18.5 / -71.7 16.1 / -70.5	203 / -562 185 / -51.7 16.1 / -45.7	20.3 / -32.3 18.5 / -31.4 16.1 / -30.2	Yult 140 MPH

GENERAL NAILING SCHEDULE:	
NUMBER OF NAILS FOR CONNECTING WOOD MEMBERS:	LOOD MEMBERS: COMMON NAILS Nr. / SP/
BRIDGING TO JOIST, TOE NAIL 160	2
2" SUBFLOOR TO JOIST, 160	N
BLOCKING	
FACE NAILED 160	<u> </u>
	2
STUD TO SOLE PLATE, TOE NAILED 8d	ω Q
	24"
	<u>e</u> =
TOP PLATES - LAPS & INTERSECTIONS FACE NAILED	12
TO MACH TOINT	
OF BEARING, FACE NAILED 8d	2
NAILED [6d]	30=
BUILT-UP GIRDERS & BEAMS 200	1 W 2 =
	J O

. 0 0

, END CO

724 = 70 70,000

NOTE: "SEMCO" PRODUCT APPROVAL: MIAMI/DADE COUNTY REPORT #35-0818.15 "SITPSON" PRODUCT APPROVALS: MIAMI/DADE COUNTY REPORT *91-0101.05, SBCCI NER-443, NER-393


REFER TO THE INCLUDED STRUCTURAL I ANCHORS SHALL BE SECURED W/ NAILS AS PRESCRIBED BY THE UFACTURER FOR MAXIMUM JOINT STRENGTH, UNLESS NOTED OTHERWISE. UNLISTED JOINTS IN THE LOAD PATH SHALL BE REINFORCED SON A34 FRAMING ANCHORS, TYPICAL T.O. DETAILS FOR ADDITIONAL ANCHORS/

APPLICATION

TRUSS TO WALL:
GIRDER TRUSS TO POST/HEADER:
HEADER TO KING STUD(S):
PLATE TO FOUNDATION:
PORCH BEAM TO POST:
PORCH POST TO FND.:
MISC. JOINTS MANUFR/MODEL
SIMPSON H2.5a
SIMPSON LGT, W/ 28 - 16
SIMPSON ST22
5/8"\$ THRU-BOLT
SIMPSON PC44/EPC44
SIMPSON ABU44
SIMPSON A34 CAP.
535*
1185*
1310*
1310*
1100*
2200*
315*/240* GENERAL NOTES:

DESIGN VALUES/LOADS & CODES WIND DESIGN SPEED: 130 MPH, UNLESS NOTED

PROJECT INFORMATION / NOTES:



TYPE OF SECTION MARK USED TO INDICATE A VIEW TAKEN IN THE DIRECTION OF THE ARROW IC: SECTION "A" FOUND ON "D6A" OF THE PROJECT MANUAL

0 *9*

20 AUG 2K2Ø6 2020 4


NICHOLAS
PAUL
GEISLER
ARCHITECT
I.C.A.R.B. Certified

1758 NW Brown Rd. Lake City, FL 32055 386-365-4355

NAILS PROJECTING BEYOND THE LAST WOOD MEMBER SHALL CLINCHED, WHEREVER POSSIBLE.

ORMED METAL CONNECTORS, AS PER THE SCHEDULE HEREN, SHALL IAVE THE NUMBER OF NAILS INSTALLED AS REQUIRED BY THE 1ANUFACTURER, OR AS DIRECTED BY THE PLANS.

NOTES IN THE "PLANS" PACKAGE OF THE CONSTRUCTION DOCUMENTS SUPERSEDE SIZES & SPACINGS OF NAILS CONTAINED HEREIN.



6 UNIT APARTMENT BUILDING for: CONSTRUCTION BLAKE LUNDY LAKE CITY, FLORIDA STRUCTURAL INFORMATION