

Mark Disosway, P.E.

163 SW Midtown Place, Suite 103 Lake City, FL 32025, Ph (386) 754-5419

1/18/2022

Columbia County Building Department

Re: Aaron Simque Homes / Bristol - Lot 14 & Lot 34 The Preserve / Lake City, FL

To whom it may concern:

This letter is in reference to inspection issues on the above referenced project.

1. The builder did not install a header over the dormer windows.
 - a. Because the load is so minimal the (2) 2X4 SPF #2 top plates can act as the header provided, they are continuous across opening.



THIS PDF HAS DIGITAL SIGNATURE
AND ELECTRONIC SEAL. PRINTED
COPIES ARE NOT CONSIDERED
SIGNED OR SEALED. YOU MUST
VERIFY SIGNATURE ON THIS PDF.
[CLICK HERE TO VERIFY.](#)



Mark Disosway, PE
Florida Professional Engineer #53915