


37071



Donald F. Lee & Associates, Inc.

140 NW Ridgewood Avenue
Lake City, Florida 32055
PH 386-755-6166 FAX 386-755-6167
email: donald@dfa.com
website: www.dfa.com

- Highway & Route Surveys
- Topographic Surveys
- Land & Subdivision Surveys
- Control Surveying

Since 1984

DATE: Monday, September 17, 2018

TO: Columbia County Building Department

FROM: Tim Delbene - Donald F. Lee & Associates

**RE: Floor Elevation Check – Mini-Storage & Records Storage of Lake City, Inc.
at 2529 State Road 47, Lake City, FL**

This is to Certify that elevations were obtained for two (2) commercial buildings (storage warehouses) under construction at the above referenced location. The results are as follows:

- #4 Westerly Building (slab): elev. 97.38
- #5 Easterly Building (slab): elev. 97.35

The construction plan for these buildings indicate a Minimum Floor Elevation (MFE) for both buildings as 97.3 feet.

Elevations are based on NAVD1988 datum.

