



**Project Summary**  
**Entire House**  
**Glenn I. Jones, Inc.**

14

Job:  
Date: July 29, 2012  
By:

552 NW Hilton Ave, Lake City, FL 32055 Phone: 386-752-5389 Fax: 386-755-3401 Email: byron@gijinc.com Web: www.glennijonesinc.com

## Project Information

For: John Pope  
397 NW Crawford Ct, White Springs, FL 32096  
Phone: 755-4757

Notes:

## Design Information

Weather: Gainesville, FL, US

### Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	37 °F

### Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	52 gr/lb

### Heating Summary

Structure	28060 Btuh
Ducts	8660 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	36720 Btuh

### Sensible Cooling Equipment Load Sizing

Structure	23750 Btuh
Ducts	10823 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh

Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	33536 Btuh

### Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	0

	Heating	Cooling
Area (ft <sup>2</sup> )	2275	2275
Volume (ft <sup>3</sup> )	18200	18200
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	97	49

### Latent Cooling Equipment Load Sizing

Structure	1706 Btuh
Ducts	2515 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	4221 Btuh

Equipment total load	37757 Btuh
Req. total capacity at 0.70 SHR	4.0 ton

### Heating Equipment Summary

Make Carrier  
Trade Base  
Model 50ZHB0483tp  
AHRI ref no3722573

Efficiency	7.7 HSPF
Heating input	
Heating output	46500 Btuh @ 47°F
Temperature rise	30 °F
Actual air flow	1425 cfm
Air flow factor	0.039 cfm/Btuh
Static pressure	0 in H <sub>2</sub> O
Space thermostat	

### Cooling Equipment Summary

Make Carrier	
Trade Base	
Cond 50ZHB0483tp	
Coil	
AHRI ref no3722573	
Efficiency	13.5 SEER
Sensible cooling	32550 Btuh
Latent cooling	13950 Btuh
Total cooling	46500 Btuh
Actual air flow	1425 cfm
Air flow factor	0.041 cfm/Btuh
Static pressure	0 in H <sub>2</sub> O
Load sensible heat ratio	0.89

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2012 12.0.04 RSU01086

R:\Wrightsoft HVAC\Project\Pope John.rup Calc = MJ8 Front Door faces: N

2012-Aug-06 11:02:46

Page 1

# Certificate of Product Ratings

AHRI Certified Reference Number: 3722573

Date: 8/6/2012

Product: Single-Package Heat Pump Air-Source

Model Number: 50ZHB048---30

Manufacturer: CARRIER AIR CONDITIONING

Trade/Brand name: CARRIER

Manufacturer responsible for the rating of this system combination is CARRIER AIR CONDITIONING

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	46500
EER Rating (Cooling):	11.50
SEER Rating (Cooling):	13.50
Heating Capacity(Btuh) @ 47 F:	46500
Region IV HSPF Rating (Heating):	7.70
Heating Capacity(Btuh) @ 17 F:	27000

\* Ratings followed by an asterisk (\*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

## DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

## TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

## CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.



Air-Conditioning, Heating,  
and Refrigeration Institute