

**COASTAL RESOURCES ENGINEERING, LLC.**

P.O. Box 1034, Perry, FL 32348  
Engineering Business # 30319  
Telephone: (850) 672-0145  
E-mail: johnkg6@comcast.net

July 14, 2021


Building Official  
Columbia County Building and Zoning Department  
135 NE Hernando Ave. #21  
Lake City FL 32055

Re: Todd Home  
Lake City, FL

Dear Sir or Madam,

The 2x6 /2x10 box beams install by the contractor may be substituted for the TPL 2x10 headers called for on sheet 7 of the plans. All other requirements to remain in effect.  
If you have any questions or require further information please contact me at 850/672-0145.

Sincerely,



John K. Gentry, P.E.

Cc: Christmill homes

