

Ajax Building Company, LLC 10365 Hood Road South Suite 203 Jacksonville., Florida 32257 Phone: (904) 262-8660

Project: 201807 - Columbia Jail 385 NW Quinten St Lake City, Florida 32055

John Cappadonna (Ajax Bullding Company,

10365 Hood Road SouthSuite 203

Jacksonville, Florida 32257

Closed on 01/12/21

01/13/2021

LLC)

FOOTING @ CELL & Corridor Conecti

FROM:

STATUS:

DUE DATE:

COST CODE:

REFERENCE:

SPEC SECTION:

SCHEDULE IMPACT:

TO:

Maida Huber (Dewberry)

Course of Construction

Barry Pujol (Kever McKee Engineering) Patrick McKee (Kever McKee Engineering) Kyle Sumner (Kever McKee Engineering)

Richard Novitsky (Dewberry)

DATE INITIATED:

01/06/2021

LOCATION:

PROJECT STAGE:

COST IMPACT:

DRAWING NUMBER: S-111, A-581

LINKED DRAWINGS:

RECEIVED FROM:


Michael McKnight (Ajax Building Company, LLC)

COPIES TO:

Mark Kraft (Ajax Building Company, LLC), Travis Mauldin (Ajax Building Company, LLC), Michael McKnight (Ajax Building Company, LLC)


Question from John Cappadonna (Ajax Building Company, LLC) at 10:29 AM on 01/06/2021	
There is no detail for the footing where the pre-cast cells but up to the corridor CMU leading from the rover station. E3/A-581 shows 1" between t cell and the CMU. We propose to extend the Footing out as shown on attached sketch SK-RFI-CC-48.	he
Attachments: SK-RFI-CC-48.pdf	
Official Response: Richard Novitsky (Dewberry) responded on Monday, January 11th, 2021 at 5:50PM EST Proposed detail is acceptable.	
RGN 01-11-21	
Attachments: SK-RFI-CC-48.pdf	


All Replies:				
Response from Richard Novitsky (D	Dewberry) at 05:50 PM on 01/11/2021			
Proposed detail is acceptable.				
RGN 01-11-21				
Attachments: SK-RFI-CC-48.pdf				
BY	DATE	COPIES TO		



APPROVED

RGN 01-11-21





SK-RFI-CC-48