

SHINGLE ROOFING
OVER SYNTHETIC ROOFING UNDERLAYMENT
PER MFGR. RECOMMENDATIONS OVER

7/16" O.S.B. ROOF SHEATHING INSTALLED
PERPENDICULAR TO ROOF TRUSSES
WITH STAGGERED END JOINTS, NAILED
PER WIND LOAD ENGINEERING

TRUSS TIE DOWN PER TRUSS ENGINEERING

7/16" OSB WALL SHEATHING W/ HOUSE WRAP

2 X6 *2 \$PRUCE CONST GRADE OR BTR, STUDS @ 16" O.C.

W/ 3" WASHER SPACED 32" O/C PER ENGINEERING & 6" FROM CORNERS

MONOLITHIC FTR SIZES AND BAR

12" MIN DISTANCE BELOW GRADE

ALUM DRIP EDGE 2X6 SUB FASCIA ALUM FASCIA ALUM SOFFIT

HORIZONTAL SIDING APPLIED TO

P.T. 2X6 BOTTOM PLATE

1/2"× 8" ANCHOR BOLT

SP4 AT EACH SIDE OF ALL OPENINGS

AS REQ'S

FASTEN PER WIND LOAD ENG.

R-19 OPEN CELL SPRAY FOAM INSULATION APPLIED TO UNDERSIDE OF ROOF SHEATHING |

5/8" GYP, BD, CEILING W/PLASTER FINISH

> HEADERS PER ENGINEERING

BORATE TREATMENT APPLIED DIRECTLY
TO STUDS OR OTHER CODE APPROVED
TERMITE TREATMENT

1/2" GYP. BD. W/PLASTER FINISH R-19 CELLULOSE

VAPOR BARRIER
W/ SEALED 6"LAPS OVER
CLEAN COMPACTED FILL

4" 3000 PSI CONCRETE MIX
W/6" WELDED WIRE MESH
W/ SUPPORTS OR
3000 PSI FIBERMESH
CONCRETE MIX

