




Cole Hoerner Reg# LI45057
1505 Village Green Dr.
Port St. Lucie, FL 34952
727.277.8913
December 27, 2023

Customer: Felix Cruz
242 NW Zack Dr,
Lake City, FL 32055

Florida Building Code – 8th Edition (2023)

Cole Hoerner



Per Manufacturer Specifications Gas-Tite Pg. 7 Inlet Pressure 10.0 psi, Pressure Drop 1.0 psi, Specific Gravity 1.52 (Polyethylene)

FBC Table 402.4 (28) Inlet Pressure 11.0 in. w.c. Pressure Drop .5 in. w.c. Specific Gravity 1.50 (Galvanized)