

Date: **June 23, 2021**



Black & Veatch Corp.
6800 W. 115th St., Suite 2292
Overland Park, KS 66211
(913) 458-6909

Structural Analysis Report

5 5

5 Co-Locate

Site Number: 585456
Site Name: LAKE CITY WEST - A

5 5

BU Number: 809328
Site Name: LAKE CITY W J-FL-012-058
JDE Job Number: 671598
Work Order Number: 1982212
Order Number: 565094 Rev. 0

5 5

Black & Veatch Corp. Project Number: 406642

5

555 Hackney Lane, Lake City, Columbia County, FL
Latitude 5 5 9 Longitude 5 5 9
250 Foot - Self Support Tower

Black & Veatch Corp. is pleased to submit this “**Structural Analysis Report**” to determine the structural integrity of the above-mentioned tower.

The purpose of the analysis is to determine acceptability of the tower stress level. Based on our analysis we have determined the tower stress level for the structure and foundation, under the following load case, to be:

LC5: Proposed Equipment Configuration

Sufficient Capacity

This analysis utilizes an ultimate 3-second gust wind speed of 118 mph as required by the 2020 Florida Building Code 7th Edition. Applicable Standard references and design criteria are listed in Section 2 - Analysis Criteria.


Structural analysis prepared by: Thanyaporn Yakhasem

Respectfully submitted by:

Ping Jiang, P.E.
Professional Engineer

Digitally signed by
Jiang, Ping
DN: CN="Jiang,
Ping", O=Black
Veatch, C=US
Date: 2021.06.24
20:43:29-05'00'

THIS ITEM HAS BEEN
ELECTRONICALLY SIGNED &
SEALED BY PING JIANG, P.E.,
ON THE TIME & DATE STAMP
SHOWN USING A DIGITAL
SIGNATURE. PRINTED COPIES
OF THIS DOCUMENT ARE NOT
CONSIDERED SIGNED &
SEALED & THE SIGNATURE
MUST BE VERIFIED ON ANY
ELECTRONIC COPIES.



N
h' DM N N N N N N N
N N D) (hW N) ' Dz (w N

ø N L v h D h W
x x % W N NK Dz L h K
N h

TABLE OF CONTENTS

1) INTRODUCTION

2) ANALYSIS CRITERIA

Table 1 - Proposed Equipment Configuration

Table 2 - Other Considered Equipment

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

3.1) Analysis Method

3.2) Assumptions

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary)

Table 5 - Tower Component Stresses vs. Capacity

4.1) Recommendations

5) APPENDIX A

tnxTower Output

6) APPENDIX B

Base Level Drawing

7) APPENDIX C

Additional Calculations

N
 $h' \frac{DM}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$

$\frac{\partial}{\partial} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $x \times \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 N

1) INTRODUCTION

This tower is a 250 ft Self Support tower designed by Rohn Industries, Inc.

2) ANALYSIS CRITERIA

TIA-222 Revision: TIA-222-H
Risk Category: II
Wind Speed: 118 mph
Exposure Category: C
Topographic Factor: 1
Service Wind Speed: 60 mph

Table 1 - Proposed Equipment Configuration

Mounting Level (ft)	Center Line Elevation (ft)	Number of Antennas	Antenna Manufacturer	Antenna Model	Number of Feed Lines	Feed Line Size (in)
231.0	231.0	3	ericsson	AIR 6449 w/ Mount Pipe	3	1-5/8
		3	ericsson	RRUS 4449 B5/B12		
		3	ericsson	RRUS 8843 B2/B66A		
		6	jma wireless	MX06FRO860-02 w/ Mount Pipe		
		3	raycap	RVZDC-6627-PF-48_CCIV2		
		3	site pro 1	VFA12-HD 12' Heavy Duty V-Frame		

Table 2 - Other Considered Equipment

Mounting Level (ft)	Center Line Elevation (ft)	Number of Antennas	Antenna Manufacturer	Antenna Model	Number of Feed Lines	Feed Line Size (in)
252.0	252.0	1	cci tower mounts (v2.1)	Sector Mount [SM 504-3]	10 3	1-5/8 1-1/4
	250.0	3	andrew	TMBXX-6517-A2M w/ Mount Pipe		
		3	nokia	FASB w/ Mount Pipe		
		3	nokia	FRBG		
		3	nokia	FRIG		
		3	raycap	ASU9338TYP01		

3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

Document	Reference	Source
4-GEOTECHNICAL REPORTS	121904	CCISITES
4-TOWER FOUNDATION DRAWINGS/DESIGN/SPECS	121914	CCISITES
4-TOWER MANUFACTURER DRAWINGS	13075	CCISITES

3.1) Analysis Method

tnxTower (version 8.1.1.0), a commercially available analysis software package, was used to create a three-dimensional model of the tower and calculate member stresses for various loading cases. Selected output from the analysis is included in Appendix A. When applicable, Crown Castle has calculated and provided the effective area for panel antennas using approved methods following the intent of the TIA-222 standard.

3.2) Assumptions

- 1) Tower and structures were maintained in accordance with the TIA-222 Standard.
- 2) The configuration of antennas, transmission cables, mounts and other appurtenances are as specified in Tables 1 and 2 and the referenced drawings.

This analysis may be affected if any assumptions are not valid or have been made in error. Black & Veatch Corp. should be notified to determine the effect on the structural integrity of the tower.

4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary) (Self Support Tower)

Section No.	Elevation (ft)	Component Type	Size	Critical Element	P (K)	SF*P_allow (K)	% Capacity	Pass / Fail
T1	250 - 240	Leg	ROHN 2.5 STD	2	-5.04	60.05	8.4	Pass
T2	240 - 220	Leg	ROHN 3 STD	29	-23.34	74.53	31.3	Pass
T3	220 - 200	Leg	ROHN 4 X-STR	67	-56.83	168.03	33.8	Pass
T4	200 - 180	Leg	ROHN 5 EH	106	-86.86	251.35	34.6	Pass
T5	180 - 160	Leg	ROHN 6 EH	145	-110.97	360.24	30.8	Pass
T6	160 - 140	Leg	ROHN 8 EHS	184	-130.09	413.33	31.5	Pass
T7	140 - 120	Leg	ROHN 8 EHS	211	-151.60	413.28	36.7	Pass
T8	120 - 100	Leg	ROHN 8 X-STR	238	-172.51	530.71	32.5	Pass
T9	100 - 80	Leg	ROHN 8 X-STR	265	-193.11	530.66	36.4	Pass
T10	80 - 60	Leg	ROHN 10 EH	292	-214.03	701.99	30.5	Pass
T11	60 - 40	Leg	ROHN 10 X-STR	319	-223.30	701.99	31.8	Pass
T12	40 - 20	Leg	ROHN 10 X-STR	352	-244.60	701.99	34.8	Pass
T13	20 - 0	Leg	ROHN 10 EH	385	-289.09	760.75	38.0	Pass
T1	250 - 240	Diagonal	ROHN 2 STD	8	-2.86	25.36	11.3	Pass
T2	240 - 220	Diagonal	ROHN 2 STD	32	-7.54	18.63	40.5	Pass
T3	220 - 200	Diagonal	ROHN 2 X-STR	71	-9.45	24.62	38.4	Pass
T4	200 - 180	Diagonal	ROHN 2 X-STR	110	-6.50	21.21	30.7	Pass
T5	180 - 160	Diagonal	ROHN 2 X-STR	149	-6.47	18.08	35.8	Pass
T6	160 - 140	Diagonal	ROHN 2.5 X-STR	188	-8.33	22.18	37.5	Pass
T7	140 - 120	Diagonal	ROHN 3 STD	215	-7.99	30.33	26.4	Pass
T8	120 - 100	Diagonal	ROHN 3 STD	242	-8.51	26.47	32.2	Pass
T9	100 - 80	Diagonal	ROHN 3 STD	269	-8.60	22.99	37.4	Pass
T10	80 - 60	Diagonal	ROHN 3 STD	296	-9.78	20.50	47.7	Pass
T11	60 - 40	Diagonal	ROHN 3 STD	323	-15.32	33.46	45.8	Pass
T12	40 - 20	Diagonal	ROHN 3 STD	356	-15.64	31.53	49.6	Pass
T13	20 - 0	Diagonal	ROHN 3 STD	389	-15.55	29.83	52.1	Pass
T1	250 - 240	Horizontal	ROHN 1.5 STD	7	-1.81	23.71	7.6	Pass

N
 $h' \frac{DM}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N(D) (hW) (N)' Dz (w) NDN$

$\emptyset$ $NhLwDhW$
 $x \times \frac{W}{N} N NKDzLhK$
 N

Section No.	Elevation (ft)	Component Type	Size	Critical Element	P (K)	SF*P_allow (K)	% Capacity	Pass / Fail
T2	240 - 220	Horizontal	ROHN 1.5 STD	31	-4.05	23.65	17.1	Pass
T3	220 - 200	Horizontal	ROHN 1.5 STD	70	-5.11	23.65	21.6	Pass
T4	200 - 180	Horizontal	ROHN 1.5 STD	109	-4.10	20.11	20.4	Pass
T5	180 - 160	Horizontal	ROHN 2 STD	148	-4.47	28.49	15.7	Pass
T6	160 - 140	Horizontal	ROHN 2 STD	187	-5.09	23.88	21.3	Pass
T7	140 - 120	Horizontal	ROHN 2 STD	214	-5.33	17.80	29.9	Pass
T8	120 - 100	Horizontal	ROHN 2.5 STD	241	-5.97	30.40	19.6	Pass
T9	100 - 80	Horizontal	ROHN 2.5 STD	268	-6.31	23.33	27.0	Pass
T10	80 - 60	Horizontal	ROHN 2.5 STD	295	-7.25	18.74	38.7	Pass
T11	60 - 40	Horizontal	ROHN 3 STD	322	-8.09	33.29	24.3	Pass
T12	40 - 20	Horizontal	ROHN 3 STD	355	-8.73	27.40	31.9	Pass
T13	20 - 0	Horizontal	ROHN 3 STD	388	-9.37	22.94	40.8	Pass
T1	250 - 240	Top Girt	ROHN 1.5 STD	4	-1.70	23.77	7.2	Pass
T11	60 - 40	Redund Horz 1 Bracing	ROHN 1.5 STD	324	-3.88	14.74	26.3	Pass
T12	40 - 20	Redund Horz 1 Bracing	ROHN 1.5 STD	357	-4.24	12.04	35.2	Pass
T13	20 - 0	Redund Horz 1 Bracing	ROHN 1.5 STD	390	-5.02	10.03	50.0	Pass
T11	60 - 40	Redund Diag 1 Bracing	ROHN 1.5 STD	325	-3.52	4.53	77.8	Pass
T12	40 - 20	Redund Diag 1 Bracing	ROHN 2.25 TUBE	358	-3.61	4.52	80.0	Pass
T13	20 - 0	Redund Diag 1 Bracing	ROHN 2.25 TUBE	410	-4.02	4.23	95.1	Pass
T11	60 - 40	Redund Hip 1 Bracing	ROHN 1.5 STD	347	-0.02	12.73	0.2	Pass
T12	40 - 20	Redund Hip 1 Bracing	ROHN 1.5 STD	380	-0.02	10.54	0.2	Pass
T13	20 - 0	Redund Hip 1 Bracing	ROHN 1.5 STD	413	-0.02	8.88	0.2	Pass
T11	60 - 40	Redund Hip Diagonal 1 Bracing	ROHN 2.5 STD	337	-0.06	11.01	0.6	Pass
T12	40 - 20	Redund Hip Diagonal 1 Bracing	ROHN 2.5 STD	370	-0.06	9.90	0.6	Pass
T13	20 - 0	Redund Hip Diagonal 1 Bracing	ROHN 3 STD	403	-0.07	17.65	0.4	Pass
T1	250 - 240	Inner Bracing	L2x2x1/8	18	-0.00	8.80	0.1	Pass
T2	240 - 220	Inner Bracing	L2x2x1/8	42	-0.00	8.65	0.1	Pass
T3	220 - 200	Inner Bracing	L2x2x1/8	79	-0.00	8.48	0.1	Pass
T4	200 - 180	Inner Bracing	L2x2x1/8	120	-0.00	6.27	0.1	Pass
T5	180 - 160	Inner Bracing	L2x2x1/8	159	-0.01	4.28	0.1	Pass
T6	160 - 140	Inner Bracing	L2x2x1/8	198	-0.01	3.24	0.2	Pass
T7	140 - 120	Inner Bracing	L2 1/2x2 1/2x3/16	225	-0.01	6.84	0.2	Pass
T8	120 - 100	Inner Bracing	L3x3x3/16	252	-0.01	9.02	0.2	Pass
T9	100 - 80	Inner Bracing	L3 1/2x3 1/2x1/4	279	-0.01	14.69	0.2	Pass
T10	80 - 60	Inner Bracing	L3 1/2x3 1/2x1/4	306	-0.01	11.72	0.2	Pass
T11	60 - 40	Inner Bracing	ROHN 3 STD	351	-0.01	30.98	0.2	Pass

Section No.	Elevation (ft)	Component Type	Size	Critical Element	P (K)	SF*P_allow (K)	% Capacity	Pass / Fail
T12	40 - 20	Inner Bracing	ROHN 3 STD	383	-0.01	25.66	0.3	Pass
T13	20 - 0	Inner Bracing	ROHN 3 STD	416	-0.01	21.61	0.3	Pass
							Summary	
						Leg (T13)	38.0	Pass
						Diagonal (T13)	52.1	Pass
						Horizontal (T13)	40.8	Pass
						Top Girt (T1)	7.2	Pass
						Redund Horz 1 Bracing (T13)	50.0	Pass
						Redund Diag 1 Bracing (T13)	95.1	Pass
						Redund Hip 1 Bracing (T13)	0.2	Pass
						Redund Hip Diagonal 1 Bracing (T12)	0.6	Pass
						Inner Bracing (T13)	0.3	Pass
						Bolt Checks	49.3	Pass
						Rating =	95.1	Pass

Table 5 - Tower Component Stresses vs. Capacity (Self Support Tower)

Notes	Component	Elevation (ft)	% Capacity	Pass / Fail
1	Anchor Rods	0	25.1	Pass
1, 2	Base Foundation (Compared w/ Design Loads)	0	36.6	Pass

Structure Rating (max from all components) =	95.1%
---	--------------

Notes:

- 1) See additional documentation in "Appendix C – Additional Calculations" for calculations supporting the % capacity. Rating per TIA-222-H Section 15.5.
- 2) Foundation capacity determined by comparing analysis reactions to original design reactions.

4.1) Recommendations

The tower and its foundation have sufficient capacity to carry the proposed load configuration. No modifications are required at this time.



N
 $h' \text{ } \overline{D} \text{ } N \text{ } N \text{ } N \text{ } N \text{ } N \text{ } N$
 $N \text{ } N \text{ } N \text{ } N \text{ } N \text{ } N \text{ } N$

$\emptyset \text{ } N \text{ } L \text{ } W \text{ } D \text{ } h \text{ } W$
 $x \text{ } x \text{ } N \text{ } N \text{ } K \text{ } D \text{ } z \text{ } L \text{ } h \text{ } K$
 $N \text{ } H$

APPENDIX A

TNXTOWER OUTPUT

Section	T13	T12	T11	T10	T9	T8	T7	T6	T5	T4	T3	T2	T1
Legs	ROHN 10 EH	ROHN 10 X-STR	ROHN 10 X-STR	ROHN 10 EH	ROHN 8 X-STR	ROHN 8 X-STR	ROHN 8 EHS	ROHN 6 EH	ROHN 6 EH	ROHN 5 EH	ROHN 4 X-STR	ROHN 3 STD	A
Leg Grade							A572-50					ROHN 2 STD	
Diagonals								ROHN 2.5 X-STR					
Diagonal Grade							A572-50						
Top Girts							N.A.						B
Red. Horizontals								ROHN 2 STD			ROHN 1.5 STD		
Red. Diagonals								N.A.					
Red. Hips								N.A.					
Inner Bracing													
Face Width (ft)	32.8333	30.3333	27.8333	25.3333	L3 1/2x3 1/2x1/4	L3x3x3/16	L2 1/2x2 1/2x3/16	15.1771	10.7917	8.70833	8.625	8.54167	8.5
# Panels @ (ft)	1 @ 19.9167	2 @ 20	2 @ 20	2 @ 20	2 @ 20	10 @ 10	17.6771	12.9271	12 @ 6.66667	12 @ 6.66667	12 @ 6.66667	12 @ 6.66667	2 @ 5
Weight (K)	52.6	6.5	6.3	6.2	6.3	5.3	3.9	3.7	3.2	2.4	1.3	0.7	



SYMBOL LIST

MARK	SIZE	MARK	SIZE
A	ROHN 2.5 STD	B	ROHN 1.5 STD

MATERIAL STRENGTH

GRADE	Fy	Fu	GRADE	Fy	Fu
A572-50	50 ksi	65 ksi			

TOWER DESIGN NOTES

1. Tower is located in Columbia County, Florida.
2. Tower designed for Exposure C to the TIA-222-H Standard.
3. Tower designed for a 118 mph basic wind in accordance with the TIA-222-H Standard.
4. Deflections are based upon a 60 mph wind.
5. Tower Risk Category II.
6. Topographic Category 1 with Crest Height of 0.00 ft
7. TOWER RATING: 95.1%



BLACK & VEATCH

Building a world of difference.®

6800 W. 115th St., Suite 2292

Overland Park, KS 66211

Phone: (913) 458-6909

FAX:

Job:

Project:

Client: Crown Castle

Drawn by: Thanyaporn Yakhasem

App'd:

Code: TIA-222-H

Date: 06/23/21

Scale: NTS

Path:

Dwg No. E-1

N
 $h' DM N N N N N N$
 $N N D) (h w N N) ' D z (w N N D N$

$\emptyset N L V H D h W$
 $x x \frac{W}{N} N N K D z L h K$
 $N K$

Tower Input Data

The main tower is a 3x free standing tower with an overall height of 250.00 ft above the ground line.

The base of the tower is set at an elevation of 0.00 ft above the ground line.

The face width of the tower is 8.50 ft at the top and 32.83 ft at the base.

This tower is designed using the TIA-222-H standard.

The following design criteria apply:


- ☐ Tower is located in Columbia County, Florida.
- ☐ Tower base elevation above sea level: 166.00 ft.
- ☐ Basic wind speed of 118 mph.
- ☐ Risk Category II.
- ☐ Exposure Category C.
- ☐ Simplified Topographic Factor Procedure for wind speed-up calculations is used.
- ☐ Topographic Category: 1.
- ☐ Crest Height: 0.00 ft.
- ☐ Deflections calculated using a wind speed of 60 mph.
- ☐ Pressures are calculated at each section.
- ☐ Stress ratio used in tower member design is 1.
- ☐ Tower analysis based on target reliabilities in accordance with Annex S.
- ☐ Load Modification Factors used: $K_{es}(F_w) = 0.95$.
- ☐ Maximum demand-capacity ratio is: 1.05.
- ☐ Local bending stresses due to climbing loads, feed line supports, and appurtenance mounts are not considered.

Options

Consider Moments - Legs	Distribute Leg Loads As Uniform	Use ASCE 10 X-Brace Ly Rules
Consider Moments - Horizontals	Assume Legs Pinned	✓ Calculate Redundant Bracing Forces
Consider Moments - Diagonals	✓ Assume Rigid Index Plate	Ignore Redundant Members in FEA
Use Moment Magnification	✓ Use Clear Spans For Wind Area	✓ SR Leg Bolts Resist Compression
✓ Use Code Stress Ratios	✓ Use Clear Spans For KL/r	All Leg Panels Have Same Allowable
✓ Use Code Safety Factors - Guys	Retension Guys To Initial Tension	Offset Girt At Foundation
Escalate Ice	✓ Bypass Mast Stability Checks	✓ Consider Feed Line Torque
Always Use Max Kz	✓ Use Azimuth Dish Coefficients	✓ Include Angle Block Shear Check
Use Special Wind Profile	✓ Project Wind Area of Appurt.	Use TIA-222-H Bracing Resist.
Include Bolts In Member Capacity	Autocalc Torque Arm Areas	Exemption
Leg Bolts Are At Top Of Section	Add IBC .6D+W Combination	Use TIA-222-H Tension Splice
✓ Secondary Horizontal Braces Leg	✓ Sort Capacity Reports By Component	Exemption
Use Diamond Inner Bracing (4 Sided)	Triangulate Diamond Inner Bracing	
✓ SR Members Have Cut Ends	Treat Feed Line Bundles As Cylinder	Poles
SR Members Are Concentric	Ignore KL/ry For 60 Deg. Angle Legs	Include Shear-Torsion Interaction
		Always Use Sub-Critical Flow
		Use Top Mounted Sockets
		Pole Without Linear Attachments
		Pole With Shroud Or No
		Appurtenances
		Outside and Inside Corner Radii Are
		Known

N
 $h' \frac{D}{N} N \quad N \quad N \quad N \quad N \quad N \quad N \quad N$
 $N \quad N \quad N \quad N \quad N \quad N \quad N \quad N$

$\phi \quad N \quad L \quad W \quad D \quad h \quad W$
 $x \quad x \quad W \quad N \quad N \quad K \quad D \quad z \quad L \quad h \quad K$
 N



Tower Section Geometry

N	N	N	N	N	N	N	N	N	N	N	N	N
N	N	N	N	N	N	N	N	N	N	N	N	N
N	N	N	N	N	N	N	N	N	N	N	N	N
N	N	N	N	N	N	N	N	N	N	N	N	N
T1	250.00-240.00							8.50	1		10.00	
T2	240.00-220.00							8.54	1		20.00	
T3	220.00-200.00							8.63	1		20.00	
T4	200.00-180.00							8.71	1		20.00	
T5	180.00-160.00							10.79	1		20.00	
T6	160.00-140.00							12.93	1		20.00	
T7	140.00-120.00							15.18	1		20.00	
T8	120.00-100.00							17.68	1		20.00	
T9	100.00-80.00							20.18	1		20.00	
T10	80.00-60.00							22.83	1		20.00	
T11	60.00-40.00							25.33	1		20.00	
T12	40.00-20.00							27.83	1		20.00	
T13	20.00-0.00							30.33	1		20.00	

Tower Section Geometry 6 O

N	N	N	N	N	N	N	N	N	N	N	N	N
N	N	N	N	N	N	N	N	N	N	N	N	N
N	N	N	N	N	N	N	N	N	N	N	N	N
N	N	N	N	N	N	N	N	N	N	N	N	N
T1	250.00-240.00	5.00	K Brace Down	No	Yes	0.0000	0.0000					
T2	240.00-220.00	6.67	K Brace Down	No	Yes	0.0000	0.0000					
T3	220.00-200.00	6.67	K Brace Down	No	Yes	0.0000	0.0000					
T4	200.00-180.00	6.67	K Brace Down	No	Yes	0.0000	0.0000					
T5	180.00-160.00	6.67	K Brace Down	No	Yes	0.0000	0.0000					
T6	160.00-140.00	10.00	K Brace Down	No	Yes	0.0000	0.0000					
T7	140.00-120.00	10.00	K Brace Down	No	Yes	0.0000	0.0000					
T8	120.00-100.00	10.00	K Brace Down	No	Yes	0.0000	0.0000					
T9	100.00-80.00	10.00	K Brace Down	No	Yes	0.0000	0.0000					
T10	80.00-60.00	10.00	K Brace Down	No	Yes	0.0000	0.0000					

Ø NtLvNtDhW
 x x 9W N NKDzLhK
 NND

Tower Section Geometry 6 0Tower Section Geometry 6 0tnxTower Report - version 8.1.1.0

Ø NiLVNiDhW
 x x %W N NKDzLhK
 NiLV

#	N N	N N	N N	N N	N N	N N	N N	N N
N Λ	Z Λ							
T10 80.00-60.00	None	Pipe			A618-50 (50 ksi)	Pipe	ROHN 2.5 STD	A572-50 (50 ksi)
T11 60.00-40.00	None	Pipe			A618-50 (50 ksi)	Pipe	ROHN 3 STD	A572-50 (50 ksi)
T12 40.00-20.00	None	Pipe			A618-50 (50 ksi)	Pipe	ROHN 3 STD	A572-50 (50 ksi)
T13 20.00-0.00	None	Pipe			A618-50 (50 ksi)	Pipe	ROHN 3 STD	A572-50 (50 ksi)

Tower Section Geometry 6 0

Item	Size	Material	Length	Angle	Weld	Notes
T1	250.00-240.00	Pipe	A618-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T2	240.00-220.00	Pipe	A618-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T3	220.00-200.00	Pipe	A618-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T4	200.00-180.00	Pipe	A618-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T5	180.00-160.00	Pipe	A618-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T6	160.00-140.00	Pipe	A618-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T7	140.00-120.00	Pipe	A618-50 (50 ksi)	Equal Angle	L2 1/2x2 1/2x3/16	A36 (36 ksi)
T8	120.00-100.00	Pipe	A618-50 (50 ksi)	Equal Angle	L3x3x3/16	A36 (36 ksi)
T9	100.00-80.00	Pipe	A618-50 (50 ksi)	Equal Angle	L3 1/2x3 1/2x1/4	A572-50 (50 ksi)
T10	80.00-60.00	Pipe	A618-50 (50 ksi)	Equal Angle	L3 1/2x3 1/2x1/4	A572-50 (50 ksi)
T11	60.00-40.00	Pipe	A618-50 (50 ksi)	Pipe	ROHN 3 STD	A572-50 (50 ksi)
T12	40.00-20.00	Pipe	A618-50 (50 ksi)	Pipe	ROHN 3 STD	A572-50 (50 ksi)
T13	20.00-0.00	Pipe	A618-50 (50 ksi)	Pipe	ROHN 3 STD	A572-50 (50 ksi)

Tower Section Geometry 6

#	N	V	N	N	N	N	M	N	N
	N	Z	N		N	N			
	Λ								
T11	60.00-40.00	A572-50 (50 ksi)		Horizontal (1) Diagonal (1) Hip (1) Hip Diagonal (1)	Pipe Pipe Pipe Pipe	ROHN 1.5 STD ROHN 1.5 STD ROHN 1.5 STD ROHN 2.5 STD	1 1 1 1		
T12	40.00-20.00	A572-50 (50 ksi)		Horizontal (1) Diagonal (1) Hip (1) Hip Diagonal (1)	Pipe Pipe Pipe Pipe	ROHN 1.5 STD ROHN 2.25 TUBE ROHN 1.5 STD ROHN 2.5 STD	1 1 1 1		
T13	20.00-	A572-50		Horizontal (1)	Pipe	ROHN 1.5 STD	1		

Ø NtLWtDhW
 x x %W N NKDzLhK
 NW

Tower Section Geometry 6	O
---------------------------------	----------

$$\overline{N}$$

Tower Section Geometry 6	O
---------------------------------	----------

tnxTower Report - version 8.1.1.0

N
 $h' DM N N N N N N N$
 $N N D) (h w N N) ' D z (w N N D N$

$\emptyset N L w D h W$
 $x x \% N N K D z L h K$
 $N W$

#	Λ	Λ	Λ	M ^W												
	N	x	N	x	N	N	N	N	N	Z	N	°	N	N	%	N
	N	N	N	N	N	V	N	V	N	q	N	N	N	N	N	N
	N	-	N	N	q	N	q	N	N	N	N	N	N	N	N	N
Λ				Λ	Λ	Λ	Λ	Λ	Λ	Λ	Λ	Λ	Λ	Λ	Λ	Λ
T8 120.00-100.00		Yes		Yes	1	1	1	1	1	1	1	1	1	1	1	1
T9 100.00-80.00		Yes		Yes	1	1	1	1	1	1	1	1	1	1	1	1
T10 80.00-60.00		Yes		Yes	1	1	1	1	1	1	1	1	1	1	1	1
T11 60.00-40.00		Yes		Yes	1	1	1	1	1	1	1	1	1	1	1	1
T12 40.00-20.00		Yes		Yes	1	1	1	1	1	1	1	1	1	1	1	1
T13 20.00-0.00		Yes		Yes	1	1	1	1	1	1	1	1	1	1	1	1
^w	$\frac{G}{N}$	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
^N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
^N																

Tower Section Geometry 6

#	N	N	q	N	N	V	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
T1 250.00-240.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T2 240.00-220.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T3 220.00-200.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T4 200.00-180.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	
T5 180.00-160.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	
T6 160.00-140.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T7 140.00-120.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T8 120.00-100.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T9 100.00-80.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	
T10 80.00-60.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T11 60.00-40.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T12 40.00-20.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	
T13 20.00-0.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	1	

#	N	N	°	N	q	N	q	N	g	°	N	g	N	N	q	N	N	N	N	N
T1 250.00-240.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75

$\emptyset$ $NhLWnDhW$
 $x \times \%W$ N $NKDzLhK$
 NW

N	N		N		N		N		N		N	
	°		q		q		°				q	
	q		q		q		q		q		q	
T2 240.00-220.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T3 220.00-200.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T4 200.00-180.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T5 180.00-160.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T6 160.00-140.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T7 140.00-120.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T8 120.00-100.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T9 100.00-80.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T10 80.00-60.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T11 60.00-40.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T12 40.00-20.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T13 20.00-0.00	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75

$$N$$

Tower Section Geometry 6 0

#	N				q		N		N		N		N		N	
	N		N		N		N		N		N		N		N	
	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
T1	250.00-240.00	Flange	0.7500	4	0.6250	3	0.6250	2	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T2	240.00-220.00	Flange	0.8750	4	0.6250	3	0.6250	0	0.6250	0	0.6250	0	0.6250	2	0.6250	0
T3	220.00-200.00	Flange	1.0000	4	0.6250	3	0.0000	0	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T4	200.00-180.00	Flange	1.0000	6	0.6250	3	0.6250	0	0.6250	0	0.6250	0	0.6250	2	0.6250	0
T5	180.00-160.00	Flange	1.0000	8	0.6250	3	0.0000	0	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T6	160.00-140.00	Flange	1.0000	8	0.6250	3	0.0000	0	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T7	140.00-120.00	Flange	1.0000	8	0.6250	3	0.0000	0	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T8	120.00-100.00	Flange	1.0000	8	0.6250	3	0.0000	0	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T9	100.00-80.00	Flange	1.0000	12	0.6250	3	0.0000	0	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T10	80.00-60.00	Flange	1.0000	12	0.6250	3	0.0000	0	0.0000	0	0.0000	0	0.6250	2	0.0000	0
T11	60.00-40.00	Flange	1.0000	12	0.7500	3	0.0000	0	0.0000	0	0.0000	0	0.7500	2	0.6250	1
T12	40.00-20.00	Flange	1.0000	12	0.7500	3	0.0000	0	0.0000	0	0.0000	0	0.7500	2	0.6250	1
T13	20.00-0.00	Flange	1.0000	0	0.7500	3	0.7500	0	0.7500	0	0.7500	0	0.7500	2	0.6250	1

$$N$$

N
h' DM N N N N N N N
N N D) (hW N) ' Dz (w NDN

ø N L W D h W
x x % N N K D z L h K
N W

Tower Section Geometry 6

O

#	N	°		q		q		°		N		N		q	
		V	N	I	N	V	N	I	N	V	N	I	N	V	N
		inΛ	Λ	inΛ	Λ	inΛ	Λ	inΛ	Λ	inΛ	Λ	inΛ	Λ	inΛ	Λ
T1	250.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	240.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T2	240.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	220.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T3	220.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	200.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T4	200.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	180.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T5	180.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	160.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T6	160.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	140.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T7	140.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	120.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T8	120.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	100.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T9	100.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	80.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T10	80.00-	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
	60.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T11	60.00-	0.6250	1	0.6250	1	0.6250	0	0.6250	0	0.6250	0	0.6250	1	0.6250	1
	40.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T12	40.00-	0.6250	1	0.6250	1	0.6250	0	0.6250	0	0.6250	0	0.6250	1	0.6250	1
	20.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T13	20.00-	0.6250	1	0.6250	1	0.6250	0	0.6250	0	0.6250	0	0.6250	1	0.6250	1
	0.00	A325N		A325N		A325N		A325N		A325N		A325N		A325N	

N

Feed Line/Linear Appurtenances - Entered As Round Or Flat

q	N/	I -	#	N x	I /	N	N	PN	PN	x	N	N	N
	N	N	I /	N	N	N	N	N	N	N	N	N	N
			x	I		θ	Ø	I	I	Λ	Λ	Λ	Λ
Safety Line	B	No	No	Ar (CaAa)	250.00 -	0.0000	0.5	1	1	0.3750	0.3750		0.22
3/8					0.00								

Feedline	C	No	No	Af (CaAa)	250.00 -	0.0000	-0.45	1	1	3.0000	3.0000		8.40
Ladder (Af)					0.00								
Feedline	C	No	No	Af (CaAa)	220.00 -	0.0000	0.45	1	1	3.0000	3.0000		8.40
Ladder (Af)					0.00								
Feedline	A	No	No	Af (CaAa)	180.00 -	0.0000	0.45	1	1	3.0000	3.0000		8.40
Ladder (Af)					0.00								

Feedline	B	No	No	Af (CaAa)	250.00 -	0.0000	0.45	1	1	3.0000	3.0000		8.40
Ladder (Af)					0.00								
LDF7-50A(1-	B	No	No	Ar (CaAa)	250.00 -	0.0000	0.46	10	10	0.5000	1.9800		0.82
5/8)					0.00								
ASU9323TY	B	No	No	Ar (CaAa)	250.00 -	0.0000	0.417	3	3	0.5000	1.2400		1.05
P01(1-1/4)					0.00								

Feedline	B	No	No	Af (CaAa)	231.00 -	0.0000	-0.45	1	1	3.0000	3.0000		8.40
Ladder (Af)					0.00								
MLE	B	No	No	Ar (CaAa)	231.00 -	0.0000	-0.45	3	3	0.5000	1.6250		1.07
HYBRID					0.00								
9POWER/18													
FIBER RL													
2(1-5/8)													

N
 $h' DM N N N N N N$
 $N N D) (h w N N) ' D z (w N D N$

$\emptyset N L w D h W$
 $x x \% N N K D z L h K$
 $N y$

Feed Line/Linear Appurtenances - Entered As Area

q	N	$/$	$I -$	$N \#$	$N x$	N	N	N	$x - N$	N
			N	$/$	N	N	N	N	N	N
			N	x	I				N	N

1/8" Detuning Wire	A	No	No	CaAa (Out Of Face)	213.00 - 0.00	1	No Ice	0.01	0.07	
1/8" Detuning Wire	B	No	No	CaAa (Out Of Face)	213.00 - 0.00	1	No Ice	0.01	0.07	
1/8" Detuning Wire	C	No	No	CaAa (Out Of Face)	213.00 - 0.00	1	No Ice	0.01	0.07	

Feed Line/Linear Appurtenances Section Areas

N	N	$/$	N	N	N	N	N	N
Λ	Λ		I	$h \Lambda$	$h \Lambda$	$\% M$	M	N
T1	250.00-240.00	A	0.000	0.000	0.000	0.000	0.000	0.00
		B	0.000	0.000	28.895	0.000	0.20	
		C	0.000	0.000	5.000	0.000	0.08	
T2	240.00-220.00	A	0.000	0.000	0.000	0.000	0.00	
		B	0.000	0.000	68.653	0.000	0.53	
		C	0.000	0.000	10.000	0.000	0.17	
T3	220.00-200.00	A	0.000	0.000	0.000	0.163	0.00	
		B	0.000	0.000	77.540	0.163	0.63	
		C	0.000	0.000	20.000	0.163	0.34	
T4	200.00-180.00	A	0.000	0.000	0.000	0.250	0.00	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T5	180.00-160.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T6	160.00-140.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T7	140.00-120.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T8	120.00-100.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T9	100.00-80.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T10	80.00-60.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T11	60.00-40.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T12	40.00-20.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	
T13	20.00-0.00	A	0.000	0.000	10.000	0.250	0.17	
		B	0.000	0.000	77.540	0.250	0.63	
		C	0.000	0.000	20.000	0.250	0.34	

N
 $h' \frac{DN}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N(D) (hW) (N)' Dz (w) NDN$

$\emptyset$ $NhLwDhW$
 $x \times \frac{N}{N} N NKDzLhK$
 NW

Feed Line Center of Pressure

N	N	#	NW	$x \frac{N}{N}$	$x \frac{N}{N}$	$x \frac{N}{N}$	$x \frac{N}{N}$
			N	N	N	$\% N$	$\% N$
			N	N	N	N	N
T1		250.00-240.00		17.9684	12.2372	17.9684	12.2372
T2		240.00-220.00		17.2845	7.8101	17.1819	7.7719
T3		220.00-200.00		12.5260	5.6446	12.1757	5.5117
T4		200.00-180.00		13.3431	6.0905	12.5812	5.7939
T5		180.00-160.00		14.0005	3.5795	12.8237	3.3173
T6		160.00-140.00		15.3036	3.9820	13.7190	3.6182
T7		140.00-120.00		16.6876	4.4034	14.9919	4.0056
T8		120.00-100.00		18.2333	4.8619	16.4296	4.4321
T9		100.00-80.00		19.9199	5.3530	17.9399	4.8755
T10		80.00-60.00		20.2916	5.5231	18.0739	4.9759
T11		60.00-40.00		22.9378	6.2403	20.2171	5.5702
T12		40.00-20.00		24.3173	6.6485	21.4513	5.9371
T13		20.00-0.00		25.8094	7.0829	22.7636	6.3224

Shielding Factor Ka

N	$/$	N	N	q	$/$	N	N	N	N
		N	N		$\#$	i	N	$\%$	$\%$
T1		1		Safety Line 3/8		240.00 -		0.6000	0.6000
						250.00			
T1		7		Feedline Ladder (Af)		240.00 -		0.6000	0.6000
						250.00			
T1		11		Feedline Ladder (Af)		240.00 -		0.6000	0.6000
						250.00			
T1		12		LDF7-50A(1-5/8)		240.00 -		0.6000	0.6000
						250.00			
T1		13		ASU9323TYP01(1-1/4)		240.00 -		0.6000	0.6000
						250.00			
T2		1		Safety Line 3/8		220.00 -		0.6000	0.6000
						240.00			
T2		7		Feedline Ladder (Af)		220.00 -		0.6000	0.6000
						240.00			
T2		11		Feedline Ladder (Af)		220.00 -		0.6000	0.6000
						240.00			
T2		12		LDF7-50A(1-5/8)		220.00 -		0.6000	0.6000
						240.00			
T2		13		ASU9323TYP01(1-1/4)		220.00 -		0.6000	0.6000
						240.00			
T2		15		Feedline Ladder (Af)		220.00 -		0.6000	0.6000
						231.00			
T2		16		MLE HYBRID		220.00 -		0.6000	0.6000
				9POWER/18FIBER RL		231.00			
				2(1-5/8)					
T3		1		Safety Line 3/8		200.00 -		0.6000	0.6000
						220.00			
T3		7		Feedline Ladder (Af)		200.00 -		0.6000	0.6000
						220.00			
T3		8		Feedline Ladder (Af)		200.00 -		0.6000	0.6000
						220.00			
T3		11		Feedline Ladder (Af)		200.00 -		0.6000	0.6000
						220.00			
T3		12		LDF7-50A(1-5/8)		200.00 -		0.6000	0.6000
						220.00			
T3		13		ASU9323TYP01(1-1/4)		200.00 -		0.6000	0.6000
						220.00			
T3		15		Feedline Ladder (Af)		200.00 -		0.6000	0.6000
						220.00			
T3		16		MLE HYBRID		200.00 -		0.6000	0.6000
				9POWER/18FIBER RL		220.00			
				2(1-5/8)					
T4		1		Safety Line 3/8		180.00 -		0.6000	0.6000

N
 $h' DM N N N N N N N$
 $N N D) (h w N N) ' D z (w N D N$

$\emptyset N L w D h W$
 $x x \frac{w}{N} N N K D z L h K$
 $N W K$

N	$/ N N$ $N 7$	q	$/ N N$ $\# ; N$	N $\%$	N $\%$
T4	7	Feedline Ladder (Af)	200.00 - 180.00 - 200.00	0.6000	0.6000
T4	8	Feedline Ladder (Af)	200.00 - 180.00 - 200.00	0.6000	0.6000
T4	11	Feedline Ladder (Af)	200.00 - 180.00 - 200.00	0.6000	0.6000
T4	12	LDF7-50A(1-5/8)	200.00 - 180.00 - 200.00	0.6000	0.6000
T4	13	ASU9323TYP01(1-1/4)	200.00 - 180.00 - 200.00	0.6000	0.6000
T4	15	Feedline Ladder (Af)	200.00 - 180.00 - 200.00	0.6000	0.6000
T4	16	MLE HYBRID 9POWER/18FIBER RL 2(1-5/8)	200.00 - 180.00 - 200.00	0.6000	0.6000
T5	1	Safety Line 3/8	160.00 - 180.00	0.6000	0.6000
T5	7	Feedline Ladder (Af)	160.00 - 180.00	0.6000	0.6000
T5	8	Feedline Ladder (Af)	160.00 - 180.00	0.6000	0.6000
T5	9	Feedline Ladder (Af)	160.00 - 180.00	0.6000	0.6000
T5	11	Feedline Ladder (Af)	160.00 - 180.00	0.6000	0.6000
T5	12	LDF7-50A(1-5/8)	160.00 - 180.00	0.6000	0.6000
T5	13	ASU9323TYP01(1-1/4)	160.00 - 180.00	0.6000	0.6000
T5	15	Feedline Ladder (Af)	160.00 - 180.00	0.6000	0.6000
T5	16	MLE HYBRID 9POWER/18FIBER RL 2(1-5/8)	160.00 - 180.00	0.6000	0.6000
T6	1	Safety Line 3/8	140.00 - 160.00	0.6000	0.6000
T6	7	Feedline Ladder (Af)	140.00 - 160.00	0.6000	0.6000
T6	8	Feedline Ladder (Af)	140.00 - 160.00	0.6000	0.6000
T6	9	Feedline Ladder (Af)	140.00 - 160.00	0.6000	0.6000
T6	11	Feedline Ladder (Af)	140.00 - 160.00	0.6000	0.6000
T6	12	LDF7-50A(1-5/8)	140.00 - 160.00	0.6000	0.6000
T6	13	ASU9323TYP01(1-1/4)	140.00 - 160.00	0.6000	0.6000
T6	15	Feedline Ladder (Af)	140.00 - 160.00	0.6000	0.6000
T6	16	MLE HYBRID 9POWER/18FIBER RL 2(1-5/8)	140.00 - 160.00	0.6000	0.6000
T7	1	Safety Line 3/8	120.00 - 140.00	0.6000	0.6000
T7	7	Feedline Ladder (Af)	120.00 - 140.00	0.6000	0.6000
T7	8	Feedline Ladder (Af)	120.00 - 140.00	0.6000	0.6000
T7	9	Feedline Ladder (Af)	120.00 - 140.00	0.6000	0.6000
T7	11	Feedline Ladder (Af)	120.00 - 140.00	0.6000	0.6000
T7	12	LDF7-50A(1-5/8)	120.00 - 140.00	0.6000	0.6000
T7	13	ASU9323TYP01(1-1/4)	120.00 - 140.00	0.6000	0.6000
T7	15	Feedline Ladder (Af)	120.00 -	0.6000	0.6000

N
 $h' DM N N N N N N$
 $N N D) (h w N) ' D z (w N D N$

$\emptyset N L v h D h W$
 $x x \% N N K D z L h K$
 $N \%$

N	$/ N N$	q	$/ N N$	N	N
	$N 7$		$\# ;$	$N\%$	$\%$
T7	16	MLE HYBRID 9POWER/18FIBER RL 2(1-5/8)	140.00 120.00 - 140.00	0.6000	0.6000
T8	1	Safety Line 3/8	100.00 - 120.00	0.6000	0.6000
T8	7	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T8	8	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T8	9	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T8	11	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T8	12	LDF7-50A(1-5/8)	100.00 - 120.00	0.6000	0.6000
T8	13	ASU9323TYP01(1-1/4)	100.00 - 120.00	0.6000	0.6000
T8	15	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.6000
T8	16	MLE HYBRID 9POWER/18FIBER RL 2(1-5/8)	100.00 - 120.00	0.6000	0.6000
T9	1	Safety Line 3/8	80.00 - 100.00	0.6000	0.6000
T9	7	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T9	8	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T9	9	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T9	11	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T9	12	LDF7-50A(1-5/8)	80.00 - 100.00	0.6000	0.6000
T9	13	ASU9323TYP01(1-1/4)	80.00 - 100.00	0.6000	0.6000
T9	15	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T9	16	MLE HYBRID 9POWER/18FIBER RL 2(1-5/8)	80.00 - 100.00	0.6000	0.6000
T10	1	Safety Line 3/8	60.00 - 80.00	0.6000	0.6000
T10	7	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T10	8	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T10	9	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T10	11	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T10	12	LDF7-50A(1-5/8)	60.00 - 80.00	0.6000	0.6000
T10	13	ASU9323TYP01(1-1/4)	60.00 - 80.00	0.6000	0.6000
T10	15	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T10	16	MLE HYBRID 9POWER/18FIBER RL 2(1-5/8)	60.00 - 80.00	0.6000	0.6000
T11	1	Safety Line 3/8	40.00 - 60.00	0.6000	0.6000
T11	7	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T11	8	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T11	9	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000

N
h' DM N N N N N N
N N D) (h w N) ' D z (w N D N

0 N L v h D h W
x x % N N K D z L h K
N h D

N	/	N	N	q	/	N	N	N	N
		N	7		#	i		%	%
T11			11	Feedline Ladder (Af)	40.00 -			0.6000	0.6000
					60.00				
T11			12	LDF7-50A(1-5/8)	40.00 -			0.6000	0.6000
					60.00				
T11			13	ASU9323TYP01(1-1/4)	40.00 -			0.6000	0.6000
					60.00				
T11			15	Feedline Ladder (Af)	40.00 -			0.6000	0.6000
					60.00				
T11			16	MLE HYBRID	40.00 -			0.6000	0.6000
				9POWER/18FIBER RL	60.00				
				2(1-5/8)					
T12			1	Safety Line 3/8	20.00 -			0.6000	0.6000
					40.00				
T12			7	Feedline Ladder (Af)	20.00 -			0.6000	0.6000
					40.00				
T12			8	Feedline Ladder (Af)	20.00 -			0.6000	0.6000
					40.00				
T12			9	Feedline Ladder (Af)	20.00 -			0.6000	0.6000
					40.00				
T12			11	Feedline Ladder (Af)	20.00 -			0.6000	0.6000
					40.00				
T12			12	LDF7-50A(1-5/8)	20.00 -			0.6000	0.6000
					40.00				
T12			13	ASU9323TYP01(1-1/4)	20.00 -			0.6000	0.6000
					40.00				
T12			15	Feedline Ladder (Af)	20.00 -			0.6000	0.6000
					40.00				
T12			16	MLE HYBRID	20.00 -			0.6000	0.6000
				9POWER/18FIBER RL	40.00				
				2(1-5/8)					
T13			1	Safety Line 3/8	0.00 - 20.00			0.6000	0.6000
T13			7	Feedline Ladder (Af)	0.00 - 20.00			0.6000	0.6000
T13			8	Feedline Ladder (Af)	0.00 - 20.00			0.6000	0.6000
T13			9	Feedline Ladder (Af)	0.00 - 20.00			0.6000	0.6000
T13			11	Feedline Ladder (Af)	0.00 - 20.00			0.6000	0.6000
T13			12	LDF7-50A(1-5/8)	0.00 - 20.00			0.6000	0.6000
T13			13	ASU9323TYP01(1-1/4)	0.00 - 20.00			0.6000	0.6000
T13			15	Feedline Ladder (Af)	0.00 - 20.00			0.6000	0.6000
T13			16	MLE HYBRID	0.00 - 20.00			0.6000	0.6000
				9POWER/18FIBER RL					
				2(1-5/8)					

Discrete Tower Loads

q	N	/	N	N	0	N	N	N	x - - N	x - - N	N
			N	N	N	N	N	N	/ N	N	N
			N		N	N	N	N	N	N	N
					N	N	N	N	N	N	N
					N	N	N	N	N	N	N
					N	N	N	N	N	N	N
					N	N	N	N	N	N	N
					N	N	N	N	N	N	N
					N	N	N	N	N	N	N
Flash Beacon Lighting	C	From Leg			0.00	0.0000	250.00	No Ice	2.70	2.70	0.05
					0.00						
					1.00						
Lighting Rod 4'x5/8" on 7' Extension	C	From Leg			0.00	0.0000	250.00	No Ice	2.26	2.26	0.06
					0.00						
					4.50						
7'x2" Mount Pipe	B	From Leg			0.00	0.0000	250.00	No Ice	1.66	1.66	0.03
					0.00						
					3.50						

Sector Mount [SM 504-3]	C	None				0.0000	252.00	No Ice	31.05	31.05	1.71
5'x2" Mount Pipe	A	From Leg			4.00	0.0000	252.00	No Ice	1.19	1.19	0.02
					0.00						
					-2.00						

$\emptyset$ $NhLwKhDhW$
 $x \times \frac{9}{16}$ N $NKDzLhK$
 NhW

q	N	/	N	N	0	-	N	N	N	x	-	N	x	-	N	N
			N	N	N	N	N	N	N	/	N	N	N	N	N	N
			N	N	N	N	N	N	N	N	N	N	N	N	N	N
					N	N	N	N	N	N	N	N	N	N	N	N
					N	N	N	N	N	N	N	N	N	N	N	N
					N	N	N	N	N	N	N	N	N	N	N	N
5'x2" Mount Pipe	B	From Leg	4.00	0.0000	252.00	No Ice	1.19	1.19	0.02							
5'x2" Mount Pipe	C	From Leg	4.00	0.0000	252.00	No Ice	1.19	1.19	0.02							
TMBXX-6517-A2M w/ Mount Pipe	A	From Leg	4.00	0.0000	252.00	No Ice	7.97	5.97	0.08							
TMBXX-6517-A2M w/ Mount Pipe	B	From Leg	4.00	0.0000	252.00	No Ice	7.97	5.97	0.08							
TMBXX-6517-A2M w/ Mount Pipe	C	From Leg	4.00	0.0000	252.00	No Ice	7.97	5.97	0.08							
FASB w/ Mount Pipe	A	From Leg	4.00	0.0000	252.00	No Ice	13.92	14.71	0.24							
FASB w/ Mount Pipe	B	From Leg	4.00	0.0000	252.00	No Ice	13.92	14.71	0.24							
FASB w/ Mount Pipe	C	From Leg	4.00	0.0000	252.00	No Ice	13.92	14.71	0.24							
ASU9338TYP01	A	From Leg	4.00	0.0000	252.00	No Ice	3.20	1.03	0.02							
ASU9338TYP01	B	From Leg	4.00	0.0000	252.00	No Ice	3.20	1.03	0.02							
ASU9338TYP01	C	From Leg	4.00	0.0000	252.00	No Ice	3.20	1.03	0.02							
FRBG	A	From Leg	4.00	0.0000	252.00	No Ice	2.40	1.25	0.05							
FRBG	B	From Leg	4.00	0.0000	252.00	No Ice	2.40	1.25	0.05							
FRBG	C	From Leg	4.00	0.0000	252.00	No Ice	2.40	1.25	0.05							
FRIG	A	From Leg	4.00	0.0000	252.00	No Ice	2.39	0.97	0.06							
FRIG	B	From Leg	4.00	0.0000	252.00	No Ice	2.39	0.97	0.06							
FRIG	C	From Leg	4.00	0.0000	252.00	No Ice	2.39	0.97	0.06							

Site Pro 1 VFA12-HD 12' Heavy Duty V-Frame	A	From Leg	0.00	0.0000	231.00	No Ice	13.20	9.20	0.66							
Site Pro 1 VFA12-HD 12' Heavy Duty V-Frame	B	From Leg	0.00	0.0000	231.00	No Ice	13.20	9.20	0.66							
Site Pro 1 VFA12-HD 12' Heavy Duty V-Frame	C	From Leg	0.00	0.0000	231.00	No Ice	13.20	9.20	0.66							
(2) MX06FRO860-02 w/ Mount Pipe	A	From Leg	4.00	0.0000	231.00	No Ice	8.84	7.49	0.11							
(2) MX06FRO860-02 w/	B	From Leg	4.00	0.0000	231.00	No Ice	8.84	7.49	0.11							

Ø NtLvNtDhW
 x x 9w N NKDzLhK
 Nth

Load Combinations	
-------------------	--

x	$\frac{N}{i\lambda}$	q	N
1	Dead Only		
2	1.2 Dead+1.0 Wind 0 deg - No Ice		
3	0.9 Dead+1.0 Wind 0 deg - No Ice		
4	1.2 Dead+1.0 Wind 30 deg - No Ice		
5	0.9 Dead+1.0 Wind 30 deg - No Ice		
6	1.2 Dead+1.0 Wind 60 deg - No Ice		
7	0.9 Dead+1.0 Wind 60 deg - No Ice		
8	1.2 Dead+1.0 Wind 90 deg - No Ice		
9	0.9 Dead+1.0 Wind 90 deg - No Ice		
10	1.2 Dead+1.0 Wind 120 deg - No Ice		
11	0.9 Dead+1.0 Wind 120 deg - No Ice		
12	1.2 Dead+1.0 Wind 150 deg - No Ice		
13	0.9 Dead+1.0 Wind 150 deg - No Ice		
14	1.2 Dead+1.0 Wind 180 deg - No Ice		

N
 $h' DM N N N N N N$
 $N N(D) (hW N) ' Dz (w N NDV$

$\emptyset N L w D h W$
 $x x \frac{W}{N} N N K D z L h K$
 $N L$

x	$\frac{N}{h}$	q	N
15	0.9 Dead+1.0 Wind 180 deg - No Ice		
16	1.2 Dead+1.0 Wind 210 deg - No Ice		
17	0.9 Dead+1.0 Wind 210 deg - No Ice		
18	1.2 Dead+1.0 Wind 240 deg - No Ice		
19	0.9 Dead+1.0 Wind 240 deg - No Ice		
20	1.2 Dead+1.0 Wind 270 deg - No Ice		
21	0.9 Dead+1.0 Wind 270 deg - No Ice		
22	1.2 Dead+1.0 Wind 300 deg - No Ice		
23	0.9 Dead+1.0 Wind 300 deg - No Ice		
24	1.2 Dead+1.0 Wind 330 deg - No Ice		
25	0.9 Dead+1.0 Wind 330 deg - No Ice		
26	Dead+Wind 0 deg - Service		
27	Dead+Wind 30 deg - Service		
28	Dead+Wind 60 deg - Service		
29	Dead+Wind 90 deg - Service		
30	Dead+Wind 120 deg - Service		
31	Dead+Wind 150 deg - Service		
32	Dead+Wind 180 deg - Service		
33	Dead+Wind 210 deg - Service		
34	Dead+Wind 240 deg - Service		
35	Dead+Wind 270 deg - Service		
36	Dead+Wind 300 deg - Service		
37	Dead+Wind 330 deg - Service		

Maximum Member Forces

N	#	N	x	N	x	N	Z	$\frac{N}{h}$	$-$	N	N	N	N
$\frac{N}{h}$							x	$\frac{N}{h}$	N	ξ	N	ξ	N
T1	250 - 240	Leg	Max Tension	15	2.27	0.10					0.03		
			Max. Compression	10	-5.04	-0.10					0.00		
			Max. Mx	6	1.80	0.10					-0.04		
			Max. My	18	0.27	0.05					0.12		
			Max. Vy	6	-1.43	0.00					0.00		
			Max. Vx	24	1.47	-0.00					-0.00		
		Diagonal	Max Tension	21	2.79	0.00					0.00		
			Max. Compression	20	-2.86	0.00					0.00		
			Max. Mx	2	2.28	0.02					0.00		
			Max. Vy	2	-0.01	0.00					0.00		
		Horizontal	Max Tension	20	1.85	-0.01					-0.00		
			Max. Compression	21	-1.81	-0.01					-0.00		
			Max. Mx	14	-0.06	-0.01					-0.00		
			Max. My	6	-0.30	-0.01					-0.00		
			Max. Vy	14	-0.01	-0.01					-0.00		
			Max. Vx	6	-0.00	-0.01					-0.00		
		Top Girt	Max Tension	7	1.70	0.00					0.00		
			Max. Compression	18	-1.70	-0.01					-0.00		
			Max. Mx	14	-0.83	-0.01					-0.00		
			Max. My	2	0.81	-0.01					0.00		
			Max. Vy	14	-0.01	-0.01					-0.00		
			Max. Vx	18	-0.00	-0.01					0.00		
		Inner Bracing	Max Tension	19	0.00	0.00					0.00		
			Max. Compression	6	-0.00	0.00					0.00		
			Max. Mx	2	-0.00	-0.00					0.00		
			Max. Vy	2	0.00	0.00					0.00		
T2	240 - 220	Leg	Max Tension	7	17.23	0.08					-0.06		
			Max. Compression	10	-23.34	-0.08					0.01		
			Max. Mx	22	9.07	1.15					-0.01		
			Max. My	4	-2.28	-0.00					1.18		
			Max. Vy	22	-0.79	-0.67					-0.01		
			Max. Vx	16	0.86	-0.00					0.73		
		Diagonal	Max Tension	21	7.47	0.00					0.00		
			Max. Compression	20	-7.54	0.00					0.00		
			Max. Mx	2	6.26	0.02					0.00		
			Max. Vy	2	-0.01	0.00					0.00		
		Horizontal	Max Tension	20	4.08	-0.01					-0.00		
			Max. Compression	21	-4.05	-0.01					-0.00		

$\emptyset$ $NhLvdhW$
 $xx \frac{9W}{N}$ $NKDzLhK$
 $Nh($

	#	N	x	N	x	N	Z	N	-	N	N	N	N
T3	220 - 200	Inner Bracing	Max. Mx	6	-0.90	-0.02	-0.01						
			Max. My	6	-0.90	-0.02	-0.01						
			Max. Vy	6	-0.01	-0.02	-0.01						
			Max. Vx	6	0.00	-0.02	-0.01						
			Max Tension	19	0.00	0.00	0.00						
			Max. Compression	6	-0.00	0.00	0.00						
		Leg	Max. Mx	2	-0.00	-0.00	0.00						
			Max. Vy	2	0.00	0.00	0.00						
			Max Tension	7	49.32	-0.13	-0.02						
			Max. Compression	18	-56.83	0.42	0.15						
			Max. Mx	18	-56.83	0.42	0.15						
			Max. My	4	-5.67	0.01	-0.48						
		Diagonal	Max. Vy	6	0.09	-0.22	-0.05						
			Max. Vx	4	0.14	0.01	-0.48						
			Max Tension	21	9.36	0.00	0.00						
			Max. Compression	20	-9.45	0.00	0.00						
			Max. Mx	2	7.81	0.03	0.00						
			Max. Vy	2	-0.01	0.00	0.00						
		Horizontal	Max Tension	20	5.15	-0.01	-0.00						
			Max. Compression	21	-5.11	-0.01	-0.00						
			Max. Mx	6	0.51	-0.03	-0.01						
Max. My	6		0.51	-0.03	-0.01								
Max. Vy	6		0.01	-0.03	-0.01								
Max. Vx	6		-0.00	0.00	0.00								
Inner Bracing	Max Tension	19	0.00	0.00	0.00								
	Max. Compression	6	-0.01	0.00	0.00								
	Max. Mx	2	-0.00	-0.00	0.00								
	Max. Vy	2	0.00	0.00	0.00								
	Max Tension	7	77.20	-0.38	-0.04								
	Max. Compression	18	-86.86	0.35	0.05								
T4	200 - 180	Leg	Max. Mx	18	-69.89	0.42	0.15						
			Max. My	4	-5.95	0.01	-0.48						
			Max. Vy	22	-0.07	-0.38	-0.03						
			Max. Vx	4	0.12	-0.01	-0.45						
			Max Tension	20	6.44	0.00	0.00						
			Max. Compression	20	-6.53	0.00	0.00						
		Diagonal	Max. Mx	2	5.37	0.04	0.00						
			Max. Vy	2	0.02	0.00	0.00						
			Max Tension	7	4.19	0.00	0.00						
			Max. Compression	18	-4.50	-0.02	-0.00						
			Max. Mx	6	-1.08	-0.02	-0.01						
			Max. My	18	0.32	0.00	0.01						
		Horizontal	Max. Vy	6	-0.01	-0.02	-0.01						
			Max. Vx	18	-0.00	0.00	0.01						
			Max Tension	19	0.00	0.00	0.00						
			Max. Compression	6	-0.01	0.00	0.00						
			Max. Mx	2	-0.00	-0.01	0.00						
			Max. Vy	2	0.01	0.00	0.00						
		Leg	Max Tension	7	98.65	-0.38	-0.01						
			Max. Compression	18	-110.97	1.05	0.11						
			Max. Mx	6	96.77	-1.08	-0.12						
Max. My	4		-8.90	-0.01	-1.16								
Max. Vy	6		0.17	-1.08	-0.12								
Max. Vx	4		0.21	-0.01	-1.16								
Diagonal	Max Tension	21	6.41	0.00	0.00								
	Max. Compression	20	-6.55	0.00	0.00								
	Max. Mx	2	5.32	0.05	0.00								
	Max. Vy	2	-0.02	0.00	0.00								
	Max Tension	7	4.47	0.00	0.00								
	Max. Compression	18	-4.47	-0.03	-0.00								
Horizontal	Max. Mx	6	-1.09	-0.04	-0.01								
	Max. My	18	1.14	-0.00	0.01								
	Max. Vy	6	0.02	-0.04	-0.01								
	Max. Vx	18	0.00	-0.00	0.01								
	Max Tension	19	0.00	0.00	0.00								
	Max. Compression	6	-0.01	0.00	0.00								
T5	180 - 160	Leg	Max. Mx	2	-0.00	-0.01	0.00						
			Max. Vy	2	0.01	0.00	0.00						
			Max Tension	7	98.65	-0.38	-0.01						
			Max. Compression	18	-110.97	1.05	0.11						
			Max. Mx	6	96.77	-1.08	-0.12						
			Max. My	4	-8.90	-0.01	-1.16						
		Diagonal	Max. Vy	6	0.17	-1.08	-0.12						
			Max. Vx	4	0.21	-0.01	-1.16						
			Max Tension	21	6.41	0.00	0.00						
			Max. Compression	20	-6.55	0.00	0.00						
			Max. Mx	2	5.32	0.05	0.00						
			Max. Vy	2	-0.02	0.00	0.00						
		Horizontal	Max Tension	7	4.47	0.00	0.00						
			Max. Compression	18	-4.47	-0.03	-0.00						
			Max. Mx	6	-1.09	-0.04	-0.01						
			Max. My	18	1.14	-0.00	0.01						
			Max. Vy	6	0.02	-0.04	-0.01						
			Max. Vx	18	0.00	-0.00	0.01						
		Inner Bracing	Max Tension	19	0.00	0.00	0.00						
			Max. Compression	6	-0.01	0.00	0.00						
			Max. Mx	2	-0.00	-0.01	0.00						
Max. Vy	2		0.01	0.00	0.00								
Max Tension	7		115.09	-0.99	-0.06								

$\emptyset$ $NhLWnDhW$
 $x \times \frac{9}{10} N$ $NKDzLhK$
 Nh'

	#	N	x	N	x	N	Z	N	-	N	N	N	N
		N		N			x	N	N	N	Λ	Λ	Λ
T7	140 - 120			Diagonal	Max. Compression	18	-130.09	1.14	0.09				
					Max. Mx	6	112.71	-1.17	-0.10				
					Max. My	4	-10.71	-0.01	-1.18				
					Max. Vy	22	0.14	-1.08	-0.04				
					Max. Vx	4	0.19	-0.01	-1.18				
					Max Tension	21	8.11	0.00	0.00				
					Max. Compression	20	-8.33	0.00	0.00				
					Max. Mx	2	6.88	0.12	0.00				
					Max. Vy	2	-0.04	0.00	0.00				
					Max Tension	7	5.07	0.00	0.00				
					Max. Compression	18	-5.09	-0.04	-0.00				
					Max. Mx	6	-1.38	-0.05	-0.01				
					Max. My	18	1.36	-0.01	0.01				
					Max. Vy	6	0.02	-0.05	-0.01				
					Max. Vx	18	0.00	-0.01	0.01				
					Max Tension	19	0.00	0.00	0.00				
					Max. Compression	6	-0.01	0.00	0.00				
					Max. Mx	2	-0.00	-0.01	0.00				
					Max. Vy	2	0.01	0.00	0.00				
					Max Tension	7	133.33	-1.01	-0.05				
					Max. Compression	18	-151.60	0.90	0.12				
					Max. Mx	6	122.44	-1.17	-0.10				
					Max. My	4	-11.19	-0.01	-1.18				
					Max. Vy	22	-0.14	-1.08	-0.04				
					Max. Vx	16	0.19	-0.01	1.17				
					Max Tension	21	7.72	0.00	0.00				
					Max. Compression	18	-7.99	0.00	0.00				
					Max. Mx	2	6.58	0.14	0.00				
					Max. Vy	2	-0.04	0.00	0.00				
					Max Tension	7	5.32	0.00	0.00				
					Max. Compression	18	-5.33	-0.05	-0.00				
					Max. Mx	6	-1.41	-0.06	-0.01				
					Max. My	18	1.62	-0.02	0.01				
					Max. Vy	6	-0.03	-0.06	-0.01				
					Max. Vx	18	0.00	-0.02	0.01				
					Max Tension	1	0.00	0.00	0.00				
Max. Compression	6	-0.01	0.00	0.00									
Max. Mx	2	-0.01	-0.03	0.00									
Max. Vy	2	0.02	0.00	0.00									
Max Tension	7	150.37	-0.93	-0.04									
Max. Compression	18	-172.51	0.98	0.06									
Max. Mx	6	146.86	-1.03	-0.07									
Max. My	4	-13.29	-0.03	-1.13									
Max. Vy	22	0.13	-0.95	-0.03									
Max. Vx	16	0.19	-0.03	1.12									
Max Tension	21	8.15	0.00	0.00									
Max. Compression	20	-8.51	0.00	0.00									
Max. Mx	2	6.93	0.17	0.00									
Max. Vy	2	-0.05	0.00	0.00									
Max Tension	6	6.01	0.00	0.00									
Max. Compression	19	-5.97	-0.08	-0.01									
Max. Mx	6	-1.44	-0.11	-0.01									
Max. My	18	-0.60	-0.05	0.01									
Max. Vy	6	-0.05	-0.11	-0.01									
Max. Vx	18	0.00	-0.05	0.01									
Max Tension	1	0.00	0.00	0.00									
Max. Compression	6	-0.01	0.00	0.00									
Max. Mx	2	-0.01	-0.05	0.00									
Max. Vy	2	0.02	0.00	0.00									
Max Tension	7	166.74	-0.97	-0.05									
Max. Compression	18	-193.11	0.51	0.03									
Max. Mx	6	155.50	-1.03	-0.07									
Max. My	4	-15.82	-0.03	-1.03									
Max. Vy	22	-0.15	-0.90	-0.02									
Max. Vx	4	-0.18	-0.03	-0.97									
Max Tension	21	8.14	0.00	0.00									
Max. Compression	20	-8.60	0.00	0.00									
Max. Mx	2	6.93	0.21	0.00									
Max. Vy	2	-0.05	0.00	0.00									

N
 $h' DM N N N N N N$
 $N N D) (h w N N) ' D z (w N D N$

$\emptyset$ $N L w D h W$
 $x x \frac{w}{N} N N K D z L h K$
 $(N h)$

N	$\#$	N	x	N	x	N	Z	N	$-$	N	N	N
$i \Lambda$		N		N			x	$i \Lambda$	Λ	$\xi \Lambda$	$\xi \Lambda$	N
T10	80 - 60				Horizontal	Max Tension	6		6.41	0.00	0.00	
						Max. Compression	19		-6.31	-0.09	-0.01	
						Max. Mx	6		-1.44	-0.13	-0.01	
						Max. My	18		-0.42	-0.07	0.01	
						Max. Vy	6		-0.05	-0.13	-0.01	
						Max. Vx	18		0.00	0.00	0.00	
					Inner Bracing	Max Tension	1		0.00	0.00	0.00	
						Max. Compression	6		-0.01	0.00	0.00	
						Max. Mx	2		-0.01	-0.10	0.00	
						Max. Vy	2		0.04	0.00	0.00	
					Leg	Max Tension	7		182.85	-1.98	0.04	
						Max. Compression	18		-214.02	-2.32	0.41	
						Max. Mx	18		-214.02	-2.32	0.41	
						Max. My	4		-20.79	-0.78	-4.46	
						Max. Vy	18		0.54	2.13	-0.05	
						Max. Vx	16		-0.54	-0.78	4.45	
					Diagonal	Max Tension	21		9.25	0.00	0.00	
						Max. Compression	20		-9.78	0.00	0.00	
						Max. Mx	2		7.79	0.24	0.00	
						Max. Vy	2		-0.06	0.00	0.00	
					Horizontal	Max Tension	20		7.61	-0.13	-0.00	
						Max. Compression	21		-7.25	-0.10	-0.00	
						Max. Mx	6		-0.97	-0.15	-0.01	
						Max. My	6		1.15	-0.13	-0.01	
						Max. Vy	6		-0.06	-0.15	-0.01	
						Max. Vx	6		0.00	-0.13	-0.01	
					Inner Bracing	Max Tension	1		0.00	0.00	0.00	
						Max. Compression	6		-0.01	0.00	0.00	
						Max. Mx	2		-0.01	-0.13	0.00	
						Max. Vy	2		0.04	0.00	0.00	
T11	60 - 40				Leg	Max Tension	7		189.26	1.11	-0.41	
						Max. Compression	18		-223.30	-6.49	0.86	
						Max. Mx	18		-222.90	8.51	-0.79	
						Max. My	16		-23.05	-1.51	6.23	
						Max. Vy	18		1.58	8.51	-0.79	
						Max. Vx	16		-1.14	-1.51	6.23	
					Diagonal	Max Tension	7		14.15	-0.12	0.06	
						Max. Compression	18		-15.32	0.00	0.00	
						Max. Mx	6		10.15	-0.15	0.02	
						Max. My	20		-14.21	-0.05	-0.07	
						Max. Vy	6		-0.05	-0.15	0.02	
						Max. Vx	20		-0.01	-0.05	-0.07	
					Horizontal	Max Tension	7		8.05	0.00	0.00	
						Max. Compression	18		-8.09	-0.22	-0.01	
						Max. Mx	6		0.55	-0.25	-0.02	
						Max. My	18		-0.44	-0.15	0.02	
						Max. Vy	6		0.08	-0.25	-0.02	
						Max. Vx	18		0.00	-0.16	0.02	
					Redund Horz 1 Bracing	Max Tension	6		2.13	0.00	0.00	
						Max. Compression	19		-1.70	0.00	0.00	
						Max. Mx	2		0.66	0.02	0.00	
						Max. Vy	2		-0.01	0.00	0.00	
					Redund Diag 1 Bracing	Max Tension	19		1.66	0.00	0.00	
						Max. Compression	6		-1.84	0.00	0.00	
						Max. Mx	2		-1.04	0.03	0.00	
						Max. Vy	2		-0.01	0.00	0.00	
					Redund Hip 1 Bracing	Max Tension	21		0.01	0.00	0.00	
						Max. Compression	8		-0.02	0.00	0.00	
						Max. Mx	2		-0.02	0.02	0.00	
						Max. Vy	2		-0.01	0.00	0.00	
					Redund Hip Diagonal 1 Bracing	Max Tension	4		0.06	0.00	0.00	
						Max. Compression	16		-0.06	0.00	0.00	
						Max. Mx	2		0.06	0.16	0.00	
						Max. Vy	2		-0.04	0.00	0.00	
					Inner Bracing	Max Tension	1		0.00	0.00	0.00	

N
 $h' \frac{DM}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N(D) (hW) (N)' Dz (w) NDV$

$\emptyset$ $NhLwH DhW$
 $x \times \frac{W}{N} N NKDzLhK$
 NhH

N	$\#$	N	x	N	x	N	Z	N	$-$	N	N	N	N
iA		N		N		N	x	iA	N	N	ξ	N	ξ
T12	40 - 20		Leg	Max. Compression	4	-0.01	0.00	0.00					
				Max. Mx	2	-0.01	0.19	0.00					
				Max. Vy	2	-0.06	0.00	0.00					
				Max Tension	7	205.76	4.19	-0.83					
			Diagonal	Max. Compression	18	-244.61	-6.44	0.82					
				Max. Mx	18	-244.02	8.89	-0.73					
				Max. My	16	-26.02	-1.57	6.23					
				Max. Vy	18	-1.61	8.89	-0.73					
				Max. Vx	16	-1.09	-1.57	6.23					
				Max Tension	7	14.35	-0.12	0.05					
				Max. Compression	18	-15.64	0.00	0.00					
				Max. Mx	6	8.98	-0.16	0.02					
				Max. My	20	-15.26	-0.07	-0.07					
				Max. Vy	6	-0.05	-0.16	0.02					
			Horizontal	Max. Vx	20	-0.01	0.00	0.00					
				Max Tension	7	8.60	0.00	0.00					
				Max. Compression	18	-8.73	-0.26	-0.01					
				Max. Mx	6	-2.15	-0.28	-0.02					
				Max. My	18	2.10	-0.20	0.02					
				Max. Vy	6	-0.09	-0.28	-0.02					
				Max. Vx	18	0.00	-0.20	0.02					
				Max Tension	6	2.40	0.00	0.00					
			Redund Horz 1 Bracing	Max. Compression	19	-1.87	0.00	0.00					
				Max. Mx	2	0.72	0.02	0.00					
				Max. Vy	2	-0.01	0.00	0.00					
			Redund Diag 1 Bracing	Max Tension	9	1.72	0.00	0.00					
				Max. Compression	6	-1.94	0.00	0.00					
				Max. Mx	2	-1.15	0.02	0.00					
			Redund Hip 1 Bracing	Max. Vy	2	-0.01	0.00	0.00					
				Max Tension	21	0.01	0.00	0.00					
			Redund Hip Diagonal 1 Bracing	Max. Compression	8	-0.02	0.00	0.00					
				Max. Mx	2	-0.02	0.02	0.00					
				Max. Vy	2	-0.01	0.00	0.00					
				Max Tension	4	0.06	0.00	0.00					
				Max. Compression	16	-0.06	0.00	0.00					
				Max. Mx	2	0.05	0.18	0.00					
				Max. Vy	2	-0.05	0.00	0.00					
			Inner Bracing	Max Tension	1	0.00	0.00	0.00					
				Max. Compression	2	-0.01	0.00	0.00					
				Max. Mx	2	-0.01	0.23	0.00					
T13	20 - 0		Leg	Max. Vy	2	-0.07	0.00	0.00					
				Max Tension	7	240.95	1.05	0.11					
				Max. Compression	18	-289.09	0.00	-0.00					
				Max. Mx	18	-266.23	8.18	-0.72					
				Max. My	16	-27.70	-1.57	6.23					
				Max. Vy	18	-13.48	0.00	-0.00					
			Diagonal	Max. Vx	16	-6.40	0.00	-0.00					
				Max Tension	21	14.41	-0.12	-0.01					
				Max. Compression	18	-15.55	0.00	0.00					
				Max. Mx	6	10.13	-0.17	0.02					
				Max. My	20	-14.68	-0.09	-0.06					
				Max. Vy	6	0.05	-0.17	0.02					
				Max. Vx	20	-0.00	0.00	0.00					
			Horizontal	Max Tension	7	9.20	0.00	0.00					
				Max. Compression	18	-9.37	-0.30	-0.01					
				Max. Mx	6	0.40	-0.32	-0.02					
				Max. My	18	-0.39	-0.24	0.02					
				Max. Vy	6	0.09	-0.32	-0.02					
				Max. Vx	18	-0.00	-0.24	0.02					
			Redund Horz 1 Bracing	Max Tension	8	1.71	0.00	0.00					
				Max. Compression	9	-1.37	0.00	0.00					
				Max. Mx	2	0.29	0.02	0.00					
			Redund Diag 1	Max. Vy	2	-0.01	0.00	0.00					
				Max Tension	8	1.26	0.00	0.00					

N
 $h' DM N N N N N N N$
 $N N D) (h W N) ' D z (w N D N$

$\emptyset N L W D h W$
 $x x \frac{W}{N} N N K D z L h K$
 $N h K$

N	#	N	x	N	x	N	Z	N	$-$	N	N	N	N
$i \Delta$		N		N		N	x	$i \Delta$	N	N	ξ	N	ξ
Bracing													
								Max. Compression	8	-1.26	0.00	0.00	
								Max. Mx	2	-0.80	0.03	0.00	
								Max. Vy	2	-0.01	0.00	0.00	
		Redund Hip 1						Max Tension	21	0.01	0.00	0.00	
		Bracing											
								Max. Compression	8	-0.02	0.00	0.00	
								Max. Mx	2	-0.02	0.02	0.00	
								Max. Vy	2	-0.01	0.00	0.00	
		Redund Hip						Max Tension	4	0.06	0.00	0.00	
		Diagonal 1 Bracing											
								Max. Compression	16	-0.07	0.00	0.00	
								Max. Mx	2	0.06	0.27	0.00	
								Max. Vy	2	-0.06	0.00	0.00	
		Inner Bracing						Max Tension	1	0.00	0.00	0.00	
								Max. Compression	2	-0.01	0.00	0.00	
								Max. Mx	2	-0.01	0.27	0.00	
								Max. Vy	2	-0.07	0.00	0.00	

Maximum Reactions

N	x	N	Z	N	N	$^{\circ}$	$W N$	$^{\circ}$	$W N$
			x	$i \Delta$	N	N	N	N	N
Leg C	Max. Vert		18		287.37		30.31		-16.00
	Max. H _x		18		287.37		30.31		-16.00
	Max. H _z		7		-239.42		-26.48		13.83
	Min. Vert		7		-239.42		-26.48		13.83
	Min. H _x		7		-239.42		-26.48		13.83
	Min. H _z		18		287.37		30.31		-16.00
Leg B	Max. Vert		10		263.40		-26.50		-15.83
	Max. H _x		21		-202.16		23.48		10.44
	Max. H _z		23		-209.78		22.61		13.55
	Min. Vert		23		-209.78		22.61		13.55
	Min. H _x		8		255.78		-27.37		-12.71
	Min. H _z		10		263.40		-26.50		-15.83
Leg A	Max. Vert		2		261.83		1.13		30.83
	Max. H _x		20		29.07		4.20		2.54
	Max. H _z		2		261.83		1.13		30.83
	Min. Vert		15		-210.96		-1.07		-26.38
	Min. H _x		9		21.80		-4.15		1.91
	Min. H _z		15		-210.96		-1.07		-26.38

Tower Mast Reaction Summary

x	N	N	N	N	N	N	N	N	N
	N	N	N	N	N	N	N	N	N
Dead Only		72.59	0.00	0.00	-0.72	-44.31	-0.00		
1.2 Dead+1.0 Wind 0 deg - No Ice		87.11	0.00	-48.50	-6619.37	-53.17	62.26		
0.9 Dead+1.0 Wind 0 deg - No Ice		65.33	0.00	-48.50	-6619.16	-39.88	62.26		
1.2 Dead+1.0 Wind 30 deg - No Ice		87.11	27.23	-47.17	-6402.59	-3749.21	103.05		
0.9 Dead+1.0 Wind 30 deg - No Ice		65.33	27.23	-47.17	-6402.38	-3735.92	103.05		
1.2 Dead+1.0 Wind 60 deg - No Ice		87.11	47.17	-27.23	-3696.90	-6454.90	72.74		
0.9 Dead+1.0 Wind 60 deg - No Ice		65.33	47.17	-27.23	-3696.69	-6441.61	72.74		

N
 $h' DM N N N N N N N$
 $N N D) (h W N N) ' D z (W N D N$
 $\emptyset N L W D h W$
 $x x \% N N K D z L h K$
 $N h z$

x	N	N	N	N	N	N	N
	N	N	N	N	N	N	N
1.2 Dead+1.0 Wind 90 deg - No Ice	87.11	54.46	0.00	-0.86	-7445.25	22.95	
0.9 Dead+1.0 Wind 90 deg - No Ice	65.33	54.46	0.00	-0.64	-7431.96	22.95	
1.2 Dead+1.0 Wind 120 deg - No Ice	87.11	42.00	24.25	3308.40	-5784.97	-25.24	
0.9 Dead+1.0 Wind 120 deg - No Ice	65.33	42.00	24.25	3308.61	-5771.68	-25.24	
1.2 Dead+1.0 Wind 150 deg - No Ice	87.11	22.09	38.26	5247.03	-3083.04	-29.09	
0.9 Dead+1.0 Wind 150 deg - No Ice	65.33	22.09	38.26	5247.25	-3069.75	-29.09	
1.2 Dead+1.0 Wind 180 deg - No Ice	87.11	0.00	48.50	6617.65	-53.17	-62.26	
0.9 Dead+1.0 Wind 180 deg - No Ice	65.33	0.00	48.50	6617.87	-39.88	-62.26	
1.2 Dead+1.0 Wind 210 deg - No Ice	87.11	-27.23	47.17	6400.87	3642.87	-103.05	
0.9 Dead+1.0 Wind 210 deg - No Ice	65.33	-27.23	47.17	6401.09	3656.17	-103.05	
1.2 Dead+1.0 Wind 240 deg - No Ice	87.11	-47.17	27.23	3695.18	6348.57	-72.74	
0.9 Dead+1.0 Wind 240 deg - No Ice	65.33	-47.17	27.23	3695.40	6361.86	-72.74	
1.2 Dead+1.0 Wind 270 deg - No Ice	87.11	-54.46	0.00	-0.86	7338.92	-22.95	
0.9 Dead+1.0 Wind 270 deg - No Ice	65.33	-54.46	0.00	-0.64	7352.21	-22.95	
1.2 Dead+1.0 Wind 300 deg - No Ice	87.11	-42.00	-24.25	-3310.12	5678.63	25.24	
0.9 Dead+1.0 Wind 300 deg - No Ice	65.33	-42.00	-24.25	-3309.90	5691.92	25.24	
1.2 Dead+1.0 Wind 330 deg - No Ice	87.11	-22.09	-38.26	-5248.75	2976.70	29.09	
0.9 Dead+1.0 Wind 330 deg - No Ice	65.33	-22.09	-38.26	-5248.54	2990.00	29.09	
Dead+Wind 0 deg - Service	72.59	0.00	-13.97	-1878.51	-44.31	16.94	
Dead+Wind 30 deg - Service	72.59	7.80	-13.50	-1809.26	-1088.47	28.04	
Dead+Wind 60 deg - Service	72.59	13.50	-7.80	-1044.88	-1852.85	19.80	
Dead+Wind 90 deg - Service	72.59	15.59	0.00	-0.72	-2132.63	6.25	
Dead+Wind 120 deg - Service	72.59	12.10	6.98	938.18	-1670.53	-6.87	
Dead+Wind 150 deg - Service	72.59	6.40	11.08	1493.80	-907.17	-7.92	
Dead+Wind 180 deg - Service	72.59	0.00	13.97	1877.08	-44.31	-16.94	
Dead+Wind 210 deg - Service	72.59	-7.80	13.50	1807.83	999.86	-28.04	
Dead+Wind 240 deg - Service	72.59	-13.50	7.80	1043.45	1764.24	-19.80	
Dead+Wind 270 deg - Service	72.59	-15.59	0.00	-0.72	2044.02	-6.25	
Dead+Wind 300 deg - Service	72.59	-12.10	-6.98	-939.61	1581.91	6.87	
Dead+Wind 330 deg - Service	72.59	-6.40	-11.08	-1495.24	818.56	7.92	

Solution Summary

N	N	N	N	N	N	N	N	N
x	N	N	N	N	N	N	N	N
1	0.00	-72.59	0.00	0.00	72.59	0.00	0.000%	
2	0.00	-87.11	-48.50	-0.00	87.11	48.50	0.000%	
3	0.00	-65.33	-48.50	-0.00	65.33	48.50	0.000%	
4	27.23	-87.11	-47.17	-27.23	87.11	47.17	0.000%	

N
h' DM N N N N N N N
N N D) (hW N) ' Dz (w NDN

ø N L w D h W
x x % N N K D z L h K
N L D

N	N	N	N N	N	N	N N	N	N
x	iΛ	Λ	Λ	Λ	Λ	Λ	Λ	m# N
5		27.23	-65.33	-47.17	-27.23	65.33	47.17	0.000%
6		47.17	-87.11	-27.23	-47.17	87.11	27.23	0.000%
7		47.17	-65.33	-27.23	-47.17	65.33	27.23	0.000%
8		54.46	-87.11	0.00	-54.46	87.11	0.00	0.000%
9		54.46	-65.33	0.00	-54.46	65.33	0.00	0.000%
10		42.00	-87.11	24.25	-42.00	87.11	-24.25	0.000%
11		42.00	-65.33	24.25	-42.00	65.33	-24.25	0.000%
12		22.09	-87.11	38.26	-22.09	87.11	-38.26	0.000%
13		22.09	-65.33	38.26	-22.09	65.33	-38.26	0.000%
14		0.00	-87.11	48.50	0.00	87.11	-48.50	0.000%
15		0.00	-65.33	48.50	0.00	65.33	-48.50	0.000%
16		-27.23	-87.11	47.17	27.23	87.11	-47.17	0.000%
17		-27.23	-65.33	47.17	27.23	65.33	-47.17	0.000%
18		-47.17	-87.11	27.23	47.17	87.11	-27.23	0.000%
19		-47.17	-65.33	27.23	47.17	65.33	-27.23	0.000%
20		-54.46	-87.11	0.00	54.46	87.11	0.00	0.000%
21		-54.46	-65.33	0.00	54.46	65.33	0.00	0.000%
22		-42.00	-87.11	-24.25	42.00	87.11	24.25	0.000%
23		-42.00	-65.33	-24.25	42.00	65.33	24.25	0.000%
24		-22.09	-87.11	-38.26	22.09	87.11	38.26	0.000%
25		-22.09	-65.33	-38.26	22.09	65.33	38.26	0.000%
26		0.00	-72.59	-13.97	0.00	72.59	13.97	0.000%
27		7.80	-72.59	-13.50	-7.80	72.59	13.50	0.000%
28		13.50	-72.59	-7.80	-13.50	72.59	7.80	0.000%
29		15.59	-72.59	0.00	-15.59	72.59	0.00	0.000%
30		12.10	-72.59	6.98	-12.10	72.59	-6.98	0.000%
31		6.40	-72.59	11.08	-6.40	72.59	-11.08	0.000%
32		0.00	-72.59	13.97	-0.00	72.59	-13.97	0.000%
33		-7.80	-72.59	13.50	7.80	72.59	-13.50	0.000%
34		-13.50	-72.59	7.80	13.50	72.59	-7.80	0.000%
35		-15.59	-72.59	0.00	15.59	72.59	0.00	0.000%
36		-12.10	-72.59	-6.98	12.10	72.59	6.98	0.000%
37		-6.40	-72.59	-11.08	6.40	72.59	11.08	0.000%

Maximum Tower Deflections - Service Wind

N	#	N	°	N	Z	N	N
N	N	Λ	q	Λ	x	iΛ	Λ
T1	250 - 240		4.125		29		0.1703
T2	240 - 220		3.763		29		0.1690
T3	220 - 200		3.056		29		0.1557
T4	200 - 180		2.422		29		0.1348
T5	180 - 160		1.897		29		0.1113
T6	160 - 140		1.457		29		0.0931
T7	140 - 120		1.095		29		0.0770
T8	120 - 100		0.801		29		0.0608
T9	100 - 80		0.563		29		0.0485
T10	80 - 60		0.374		29		0.0364
T11	60 - 40		0.221		29		0.0272
T12	40 - 20		0.112		35		0.0181
T13	20 - 0		0.039		35		0.0091

Critical Deflections and Radius of Curvature - Service Wind

#	N	-	N	Z	N	q	N	N	N	N
N	N			x	iΛ	Λ	Λ	Λ	Λ	x N
252.00	Sector Mount [SM 504-3]			29		4.125	0.1703	0.0881		623406
250.00	Flash Beacon Lighting			29		4.125	0.1703	0.0881		623406
231.00	Site Pro 1 VFA12-HD 12' Heavy			29		3.439	0.1647	0.0845		117056

N
 $h' DM N N N N N N N$
 $N N D) (h v N N) ' D z (w N D N$

$\emptyset N L v D h W$
 $x x \frac{W}{N} N N K D z L h K$
 $N L W$

#	N	-	N	Z	N	q	N	N	N	N	x	N	N
N	N			x	N	N	N	N	N	N		N	N

Duty V-Frame

Maximum Tower Deflections - Design Wind

N	#	N	°	N	Z	N	N	N	N
N	N	N	q	N	x	N	N	N	N
T1	250 - 240		14.588		8		0.6032		0.3234
T2	240 - 220		13.303		8		0.5987		0.3204
T3	220 - 200		10.794		8		0.5523		0.2907
T4	200 - 180		8.543		8		0.4778		0.2475
T5	180 - 160		6.680		8		0.3940		0.1979
T6	160 - 140		5.121		8		0.3288		0.1591
T7	140 - 120		3.845		8		0.2714		0.1303
T8	120 - 100		2.810		8		0.2137		0.1048
T9	100 - 80		1.973		8		0.1702		0.0849
T10	80 - 60		1.310		8		0.1275		0.0663
T11	60 - 40		0.775		8		0.0951		0.0488
T12	40 - 20		0.388		20		0.0634		0.0312
T13	20 - 0		0.132		20		0.0317		0.0152

Critical Deflections and Radius of Curvature - Design Wind

#	N	-	N	Z	N	q	N	N	N	N	x	N	N
N	N			x	N	N	N	N	N	N		N	N
252.00	Sector Mount [SM 504-3]			8		14.588		0.6032		0.3234		212388	
250.00	Flash Beacon Lighting			8		14.588		0.6032		0.3234		212388	
231.00	Site Pro 1 VFA12-HD 12' Heavy			8		12.156		0.5834		0.3103		34476	

Duty V-Frame

Bolt Design Data

N	#	N	x	N	V	N	V	N	I	N	N	N	N	N	N	N	N	N	N	N	N
N	N	N		N	Z	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
T1	250	Leg	A325N	0.7500	4	0.57	30.10	0.019	1.05	Bolt Tension											
		Diagonal	A325N	0.6250	3	0.95	13.81	0.069	1.05	Bolt Shear											
		Horizontal	A325N	0.6250	2	0.93	13.81	0.067	1.05	Bolt Shear											
		Top Girt	A325N	0.6250	2	0.85	13.81	0.062	1.05	Bolt Shear											
T2	240	Leg	A325N	0.8750	4	4.31	41.56	0.104	1.05	Bolt Tension											
		Diagonal	A325N	0.6250	3	2.51	13.81	0.182	1.05	Bolt Shear											
		Horizontal	A325N	0.6250	2	2.04	13.81	0.148	1.05	Bolt Shear											
T3	220	Leg	A325N	1.0000	4	12.33	54.52	0.226	1.05	Bolt Tension											
		Diagonal	A325N	0.6250	3	3.15	13.81	0.228	1.05	Bolt Shear											
		Horizontal	A325N	0.6250	2	2.58	13.81	0.187	1.05	Bolt Shear											
T4	200	Leg	A325N	1.0000	6	12.87	54.52	0.236	1.05	Bolt Tension											
		Diagonal	A325N	0.6250	3	2.18	13.81	0.158	1.05	Bolt Shear											
		Horizontal	A325N	0.6250	2	2.25	13.81	0.163	1.05	Bolt Shear											
T5	180	Leg	A325N	1.0000	8	12.33	54.52	0.226	1.05	Bolt Tension											
		Diagonal	A325N	0.6250	3	2.18	13.81	0.158	1.05	Bolt Shear											
		Horizontal	A325N	0.6250	2	2.24	13.81	0.162	1.05	Bolt Shear											
T6	160	Leg	A325N	1.0000	8	14.39	54.52	0.264	1.05	Bolt Tension											
		Diagonal	A325N	0.6250	3	2.78	13.81	0.201	1.05	Bolt Shear											
		Horizontal	A325N	0.6250	2	2.54	13.81	0.184	1.05	Bolt Shear											

N
 $h' DM N N N N N N N$
 $N N D) (h w N) ' D z (w N D N$

$\phi N L w D h W$
 $x x w N N K D z L h K$
 $N L h$

$\overline{N}$	$\#$	N	x	N	V	N	V	N	I	Λ	$\Lambda -$	N	$N -$	N	x	N
$\overline{N}$	N	N	N	Z	N	N	N	N	V	N	N	N	N	N	N	N
T7	140	Leg	A325N	1.0000	8	16.67	54.52	0.306	1.05	Bolt Tension						
		Diagonal	A325N	0.6250	3	2.66	13.81	0.193	1.05	Bolt Shear						
		Horizontal	A325N	0.6250	2	2.66	13.81	0.193	1.05	Bolt Shear						
T8	120	Leg	A325N	1.0000	8	18.80	54.52	0.345	1.05	Bolt Tension						
		Diagonal	A325N	0.6250	3	2.84	13.81	0.206	1.05	Bolt Shear						
		Horizontal	A325N	0.6250	2	3.01	13.81	0.218	1.05	Bolt Shear						
T9	100	Leg	A325N	1.0000	12	13.90	54.52	0.255	1.05	Bolt Tension						
		Diagonal	A325N	0.6250	3	2.87	13.81	0.208	1.05	Bolt Shear						
		Horizontal	A325N	0.6250	2	3.21	13.81	0.232	1.05	Bolt Shear						
T10	80	Leg	A325N	1.0000	12	15.24	54.52	0.279	1.05	Bolt Tension						
		Diagonal	A325N	0.6250	3	3.26	13.81	0.236	1.05	Bolt Shear						
		Horizontal	A325N	0.6250	2	3.81	13.81	0.276	1.05	Bolt Shear						
T11	60	Leg	A325N	1.0000	12	15.72	54.52	0.288	1.05	Bolt Tension						
		Diagonal	A325N	0.7500	3	5.11	19.88	0.257	1.05	Bolt Shear						
		Horizontal	A325N	0.7500	2	4.05	19.88	0.203	1.05	Bolt Shear						
		Redund Horz 1	A325N	0.6250	1	3.88	13.57	0.286	1.05	Member Bearing						
		Redund Diag 1	A325N	0.6250	1	3.52	13.57	0.260	1.05	Member Bearing						
		Redund Hip 1	A325N	0.6250	1	0.02	13.81	0.001	1.05	Bolt Shear						
		Redund Hip	A325N	0.6250	1	0.06	13.81	0.005	1.05	Bolt Shear						
		Diagonal 1														
		Bracing														
T12	40	Leg	A325N	1.0000	12	17.10	54.52	0.314	1.05	Bolt Tension						
		Diagonal	A325N	0.7500	3	5.21	19.88	0.262	1.05	Bolt Shear						
		Horizontal	A325N	0.7500	2	4.36	19.88	0.219	1.05	Bolt Shear						
		Redund Horz 1	A325N	0.6250	1	4.24	13.57	0.313	1.05	Member Bearing						
		Redund Diag 1	A325N	0.6250	1	3.61	7.77	0.465	1.05	Member Bearing						
		Redund Hip 1	A325N	0.6250	1	0.02	13.81	0.001	1.05	Bolt Shear						
		Redund Hip	A325N	0.6250	1	0.06	13.81	0.004	1.05	Bolt Shear						
		Diagonal 1														
		Bracing														
T13	20	Diagonal	A325N	0.7500	3	5.18	19.88	0.261	1.05	Bolt Shear						
		Horizontal	A325N	0.7500	2	4.68	19.88	0.236	1.05	Bolt Shear						
		Redund Horz 1	A325N	0.6250	1	5.02	13.57	0.370	1.05	Member Bearing						
		Redund Diag 1	A325N	0.6250	1	4.02	7.77	0.518	1.05	Member Bearing						
		Redund Hip 1	A325N	0.6250	1	0.02	13.81	0.001	1.05	Bolt Shear						
		Redund Hip	A325N	0.6250	1	0.07	13.81	0.005	1.05	Bolt Shear						
		Diagonal 1														
		Bracing														

5

Leg Design Data (Compression)

N	$\#$	N	N	N	N	N	N	N	N	N
N	N	N	N	N	N	N	N	N	N	N
T1	250 - 240	ROHN 2.5 STD	10.00	5.00	63.3	1.7040	-5.04	57.19	0.088 ¹	
T2	240 - 220	ROHN 3 STD	20.00	6.67	K=1.00 68.8	2.2285	-23.34	70.98	0.329 ¹	
T3	220 - 200	ROHN 4 X-STR	20.00	6.67	K=1.00 54.2	4.4074	-56.83	160.03	0.355 ¹	
T4	200 - 180	ROHN 5 EH	20.04	6.68	K=1.00 43.6	6.1120	-86.86	239.38	0.363 ¹	

$\emptyset$ $NhLWKhDhW$
 $x \times \frac{9}{16}$ $N \quad NKDzLhK$
 N/L

¹ $N_N / \square$ controls¹ $N_N / \square$ controls

N
 $h' \frac{D}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N(D) (h'w) (N)' Dz(w) NDN$

$\emptyset \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $x \times \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $NL($

Horizontal Design Data (Compression)

$\overline{N}$	$\#$	N	N	N	N	EN	$-N$	N	$\square$ N	N
	N		N	N	N	N	N	N	N	N
T1	250 - 240	ROHN 1.5 STD	8.52	4.14	79.8 K=1.00	0.7995	-1.81	22.58	0.080 ¹	
T2	240 - 220	ROHN 1.5 STD	8.60	4.15	80.0 K=1.00	0.7995	-4.05	22.52	0.180 ¹	
T3	220 - 200	ROHN 1.5 STD	8.68	4.15	80.0 K=1.00	0.7995	-5.11	22.52	0.227 ¹	
T4	200 - 180	ROHN 1.5 STD	10.10	4.82	92.8 K=1.00	0.7995	-4.10	19.16	0.214 ¹	
T5	180 - 160	ROHN 2 STD	12.22	5.83	88.9 K=1.00	1.0745	-4.47	27.13	0.165 ¹	
T6	160 - 140	ROHN 2 STD	14.05	6.66	101.6 K=1.00	1.0745	-5.09	22.75	0.224 ¹	
T7	140 - 120	ROHN 2 STD	16.43	7.85	119.7 K=1.00	1.0745	-5.33	16.95	0.314 ¹	
T8	120 - 100	ROHN 2.5 STD	18.93	9.10	115.3 K=1.00	1.7040	-5.97	28.95	0.206 ¹	
T9	100 - 80	ROHN 2.5 STD	21.51	10.39	131.6 K=1.00	1.7040	-6.31	22.21	0.284 ¹	
T10	80 - 60	ROHN 2.5 STD	24.08	11.59	146.8 K=1.00	1.7040	-7.25	17.85	0.406 ¹	
T11	60 - 40	ROHN 3 STD	25.33	12.22	126.0 K=1.00	2.2285	-8.09	31.70	0.255 ¹	
T12	40 - 20	ROHN 3 STD	27.83	13.47	138.9 K=1.00	2.2285	-8.73	26.09	0.334 ¹	
T13	20 - 0	ROHN 3 STD	30.33	14.72	151.8 K=1.00	2.2285	-9.37	21.85	0.429 ¹	

¹ $N_N / \square$ controls

Top Girt Design Data (Compression)

$\overline{N}$	$\#$	N	N	N	N	EN	$-N$	N	$\square$	N
N	N	N	N	N	N	N	N	N	N	N
T1	250 - 240	ROHN 1.5 STD	8.50	4.13	79.6 K=1.00	0.7995	-1.70	22.63	0.075 ¹	

¹ $N_N / \square$ controls

Redundant Horizontal (1) Design Data (Compression)

$\overline{N}$	$\#$	N	N	N	N	EN	$-N$	N	$\square$	N
N	N	N	N	N	N	N	N	N	N	N
T11	60 - 40	ROHN 1.5 STD	6.33	5.89	113.4 K=1.00	0.7995	-3.88	14.04	0.276 ¹	
T12	40 - 20	ROHN 1.5 STD	6.96	6.51	125.5 K=1.00	0.7995	-4.24	11.47	0.370 ¹	
T13	20 - 0	ROHN 1.5 STD	7.58	7.14	137.5 K=1.00	0.7995	-5.02	9.55	0.525 ¹	

¹ $N_N / \square$ controls

N
 $h' \frac{D}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N(D) (hW N)' Dz (w N) NDN$

$\phi \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $x x \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 NL'

Redundant Diagonal (1) Design Data (Compression)

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T11	60 - 40	ROHN 1.5 STD	11.52	10.62	204.7 K=1.00	0.7995	-3.52	4.31	0.817 ¹	
T12	40 - 20	ROHN 2.25 TUBE	11.84	11.01	172.3 K=1.00	0.5651	-3.61	4.30	0.840 ¹	
T13	20 - 0	ROHN 2.25 TUBE	12.16	11.37	178.0 K=1.00	0.5651	-4.02	4.03	0.998 ¹	

¹ $N_N / \square$ controls

Redundant Hip (1) Design Data (Compression)

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T11	60 - 40	ROHN 1.5 STD	6.33	6.33	122.1 K=1.00	0.7995	-0.02	12.12	0.002 ¹	
T12	40 - 20	ROHN 1.5 STD	6.96	6.96	134.1 K=1.00	0.7995	-0.02	10.04	0.002 ¹	
T13	20 - 0	ROHN 1.5 STD	7.58	7.58	146.2 K=1.00	0.7995	-0.02	8.45	0.002 ¹	

¹ $N_N / \square$ controls

Redundant Hip Diagonal (1) Design Data (Compression)

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T11	60 - 40	ROHN 2.5 STD	15.13	15.13	191.6 K=1.00	1.7040	-0.06	10.49	0.006 ¹	
T12	40 - 20	ROHN 2.5 STD	15.95	15.95	202.1 K=1.00	1.7040	-0.06	9.43	0.007 ¹	
T13	20 - 0	ROHN 3 STD	16.78	16.78	173.1 K=1.00	2.2285	-0.07	16.81	0.004 ¹	

¹ $N_N / \square$ controls

Inner Bracing Design Data (Compression)

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T1	250 - 240	L2x2x1/8	4.25	4.25	128.3 K=1.00	0.4844	-0.00	8.42	0.000 ¹	
T2	240 - 220	L2x2x1/8	4.30	4.30	129.8 K=1.00	0.4844	-0.00	8.23	0.001 ¹	
T3	220 - 200	L2x2x1/8	4.34	4.34	131.0 K=1.00	0.4844	-0.01	8.08	0.001 ¹	
T4	200 - 180	L2x2x1/8	4.35	4.35	131.4 K=1.00	0.4844	-0.01	8.03	0.001 ¹	
T5	180 - 160	L2x2x1/8	6.11	6.11	184.4 K=1.00	0.4844	-0.01	4.08	0.001 ¹	

$\emptyset$ $NhLWKhDhW$
 $x \times \%W$ N $NKDzLhK$
 $NL)$

$\overline{N}$	$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T6	160	- 140	L2x2x1/8	7.03	7.03	212.1 K=1.00	0.4844	-0.01	3.08	0.002	¹	
T7	140	- 120	L2 1/2x2 1/2x3/16	8.21	8.21	199.1 K=1.00	0.9020	-0.01	6.51	0.001	¹	
T8	120	- 100	L3x3x3/16	9.46	9.46	190.5 K=1.00	1.0900	-0.01	8.59	0.001	¹	
T9	100	- 80	L3 1/2x3 1/2x1/4	10.75	10.75	185.9 K=1.00	1.6900	-0.01	13.99	0.001	¹	
T10	80	- 60	L3 1/2x3 1/2x1/4	12.04	12.04	208.2 K=1.00	1.6900	-0.01	11.16	0.001	¹	
T11	60	- 40	ROHN 3 STD	12.67	12.67	130.6 K=1.00	2.2285	-0.01	29.50	0.000	¹	
T12	40	- 20	ROHN 3 STD	13.92	13.92	143.5 K=1.00	2.2285	-0.01	24.44	0.001	¹	
T13	20	- 0	ROHN 3 STD	15.17	15.17	156.4 K=1.00	2.2285	-0.01	20.58	0.001	¹	

¹ $N_N / \square$ controls

5

Leg Design Data (Tension)

$\mathcal{N}$	$\#$	N	N	N	N	EN	$-N$	N	$\square N$	N
		N	N	N	N	N	N	N	N	N
T1	250 - 240	ROHN 2.5 STD	10.00	5.00	63.3	7.7040	2.27	76.68	0.030	
T2	240 - 220	ROHN 3 STD	20.00	6.67	68.8	2.2285	17.23	100.28	0.172 ¹	
T3	220 - 200	ROHN 4 X-STR	20.00	6.67	54.2	4.4074	49.32	198.34	0.249 ¹	
T4	200 - 180	ROHN 5 EH	20.04	6.68	43.6	6.1120	77.20	275.04	0.281 ¹	
T5	180 - 160	ROHN 6 EH	20.04	6.68	36.5	8.4049	98.65	378.22	0.261 ¹	
T6	160 - 140	ROHN 8 EHS	20.04	10.02	40.6	9.8666	115.09	444.00	0.259 ¹	
T7	140 - 120	ROHN 8 EHS	20.05	10.03	40.6	9.8666	133.33	444.00	0.300 ¹	
T8	120 - 100	ROHN 8 X-STR	20.05	10.03	41.8	12.762	150.37	574.32	0.262 ¹	
T9	100 - 80	ROHN 8 X-STR	20.06	10.03	41.8	12.762	166.74	574.32	0.290 ¹	
T10	80 - 60	ROHN 10 EH	20.05	10.03	33.2	16.100	182.85	724.53	0.252 ¹	
T11	60 - 40	ROHN 10 X-STR	20.05	10.03	33.2	16.100	189.26	724.53	0.261 ¹	
T12	40 - 20	ROHN 10 X-STR	20.05	10.03	33.2	16.100	205.76	724.53	0.284 ¹	
T13	20 - 0	ROHN 10 EH	20.05	0.08	0.3	16.100	240.95	724.53	0.333 ¹	

¹ $N_N / \square$ controls

Diagonal Design Data (Tension)

$\overline{N}$	$\#$	N	N	N	N	EN	$-N$	N	$\square$	N
		N	N	N	N	N	N	N	N	N
		N					hN	N	N	$\square$
T1	250 - 240		ROHN 2 STD	6.58	6.39	97.4	1.0745	2.79	48.35	0.058 ¹
T2	240 - 220		ROHN 2 STD	7.94	7.67	117.0	1.0745	7.47	48.35	0.154 ¹
T3	220 - 200		ROHN 2 X-STR	7.96	7.62	119.3	1.4773	9.36	66.48	0.141 ¹
T4	200 - 180		ROHN 2 X-STR	8.16	7.79	122.0	1.4773	6.44	66.48	0.097 ¹

N
 $h' \frac{DN}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N(D) (hW) (N)' Dz (wN) NDN$

$\emptyset$ $NhLwDhW$
 $x \times \frac{N}{N} N NKDzLhK$
 NLH

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T5	180 - 160	ROHN 2 X-STR	9.04	8.65	135.4	1.4773	6.41	66.48	0.096 ¹	
T6	160 - 140	ROHN 2.5 X-STR	12.56	11.95	155.2	2.2535	8.11	101.41	0.080 ¹	
T7	140 - 120	ROHN 3 STD	13.35	12.80	132.0	2.2285	7.72	100.28	0.077 ¹	
T8	120 - 100	ROHN 3 STD	14.21	13.70	141.3	2.2285	8.15	100.28	0.081 ¹	
T9	100 - 80	ROHN 3 STD	15.18	14.70	151.6	2.2285	8.14	100.28	0.081 ¹	
T10	80 - 60	ROHN 3 STD	16.14	15.57	160.6	2.2285	9.25	100.28	0.092 ¹	
T11	60 - 40	ROHN 3 STD	24.38	12.19	125.7	2.2285	14.15	100.28	0.141 ¹	
T12	40 - 20	ROHN 3 STD	25.11	12.56	129.5	2.2285	14.35	100.28	0.143 ¹	
T13	20 - 0	ROHN 3 STD	25.82	12.91	133.1	2.2285	14.41	100.28	0.144 ¹	

¹ $N_N / \square$ controls

Horizontal Design Data (Tension)

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T1	250 - 240	ROHN 1.5 STD	8.52	4.14	79.8	0.7995	1.85	35.98	0.051 ¹	
T2	240 - 220	ROHN 1.5 STD	8.60	4.15	80.0	0.7995	4.08	35.98	0.114 ¹	
T3	220 - 200	ROHN 1.5 STD	8.68	4.15	80.0	0.7995	5.15	35.98	0.143 ¹	
T4	200 - 180	ROHN 1.5 STD	8.71	4.12	79.5	0.7995	4.19	35.98	0.117 ¹	
T5	180 - 160	ROHN 2 STD	12.22	5.83	88.9	1.0745	4.47	48.35	0.092 ¹	
T6	160 - 140	ROHN 2 STD	14.05	6.66	101.6	1.0745	5.07	48.35	0.105 ¹	
T7	140 - 120	ROHN 2 STD	16.43	7.85	119.7	1.0745	5.32	48.35	0.110 ¹	
T8	120 - 100	ROHN 2.5 STD	18.93	9.10	115.3	1.7040	6.01	76.68	0.078 ¹	
T9	100 - 80	ROHN 2.5 STD	21.51	10.39	131.6	1.7040	6.41	76.68	0.084 ¹	
T10	80 - 60	ROHN 2.5 STD	24.08	11.59	146.8	1.7040	7.61	76.68	0.099 ¹	
T11	60 - 40	ROHN 3 STD	25.33	12.22	126.0	2.2285	8.05	100.28	0.080 ¹	
T12	40 - 20	ROHN 3 STD	27.83	13.47	138.9	2.2285	8.60	100.28	0.086 ¹	
T13	20 - 0	ROHN 3 STD	30.33	14.72	151.8	2.2285	9.20	100.28	0.092 ¹	

¹ $N_N / \square$ controls

Top Girt Design Data (Tension)

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T1	250 - 240	ROHN 1.5 STD	8.50	4.13	79.6	0.7995	1.70	35.98	0.047 ¹

¹ $N_N / \square$ controls

Redundant Horizontal (1) Design Data (Tension)

$\frac{N}{N}$	#	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{EN}{N}$	$\frac{-N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$
T11	60 - 40	ROHN 1.5 STD	6.33	5.89	113.4	0.7995	3.88	35.98	0.108 ¹
T12	40 - 20	ROHN 1.5 STD	6.96	6.51	125.5	0.7995	4.24	35.98	0.118 ¹
T13	20 - 0	ROHN 1.5 STD	7.58	7.14	137.5	0.7995	5.02	35.98	0.139 ¹

¹ $N_N / \square$ controls

N
 $h' \frac{D}{N} N \quad N \quad N \quad N \quad N \quad N \quad N \quad N$
 $N \quad N \quad N \quad N \quad N \quad N \quad N \quad N$

$\phi \quad N \quad L \quad W \quad D \quad h \quad W$
 $x \times \frac{W}{N} \quad N \quad N \quad K \quad D \quad z \quad L \quad h \quad K$
 $N \quad L \quad K$

Redundant Diagonal (1) Design Data (Tension)

N	#	N	N	N	N	EN	$-N$	N	$\square$ N	N
N	N	N	N	N	N	N	N	N	N	N
T11	60 - 40		ROHN 1.5 STD	11.52	10.62	204.7	0.7995	3.52	35.98	0.098 ¹
T12	40 - 20		ROHN 2.25 TUBE	11.84	11.01	172.3	0.5651	3.61	25.43	0.142 ¹
T13	20 - 0		ROHN 2.25 TUBE	12.16	11.37	178.0	0.5651	4.02	25.43	0.158 ¹

¹ $N_N / \square$ controls

Redundant Hip (1) Design Data (Tension)

N	#	N	N	N	N	EN	$-N$	N	$\square$ N	N
N	N	N	N	N	N	N	N	N	N	N
T11	60 - 40		ROHN 1.5 STD	6.33	6.33	122.1	0.7995	0.01	35.98	0.000 ¹
T12	40 - 20		ROHN 1.5 STD	6.96	6.96	134.1	0.7995	0.01	35.98	0.000 ¹
T13	20 - 0		ROHN 1.5 STD	7.58	7.58	146.2	0.7995	0.01	35.98	0.000 ¹

¹ $N_N / \square$ controls

Redundant Hip Diagonal (1) Design Data (Tension)

N	#	N	N	N	N	EN	$-N$	N	$\square$ N	N
N	N	N	N	N	N	N	N	N	N	N
T11	60 - 40		ROHN 2.5 STD	15.13	15.13	191.6	1.7040	0.06	76.68	0.001 ¹
T12	40 - 20		ROHN 2.5 STD	15.95	15.95	202.1	1.7040	0.06	76.68	0.001 ¹
T13	20 - 0		ROHN 3 STD	16.78	16.78	173.1	2.2285	0.06	100.28	0.001 ¹

¹ $N_N / \square$ controls

Inner Bracing Design Data (Tension)

N	#	N	N	N	N	EN	$-N$	N	$\square$ N	N
N	N	N	N	N	N	N	N	N	N	N
T1	250 - 240		L2x2x1/8	4.25	4.25	81.4	0.4844	0.00	15.69	0.000 ¹
T2	240 - 220		L2x2x1/8	4.30	4.30	82.4	0.4844	0.00	15.69	0.000 ¹
T3	220 - 200		L2x2x1/8	4.34	4.34	83.2	0.4844	0.00	15.69	0.000 ¹
T4	200 - 180		L2x2x1/8	4.35	4.35	83.4	0.4844	0.00	15.69	0.000 ¹
T5	180 - 160		L2x2x1/8	5.40	5.40	103.4	0.4844	0.00	15.69	0.000 ¹
T6	160 - 140		L2x2x1/8	6.46	6.46	123.9	0.4844	0.00	15.69	0.000 ¹

¹ $N_N / \square$ controls

Section Capacity Table

S	Λ	#	N	x	N	N	x	N	N	N	mN	N
N	N	N	N	N	N	N	$\#$	Λ	N	N	x	N

N
 $h' DM N N N N N N N$
 $N N D) (h w N N) ' D z (w N D N$
 $\emptyset N L w D h W$
 $x x \% N N K D z L h K$
 $N L z$

S	Λ	#	N	x	N	N	x	N	N	N	mN	I	/	N
Λ	N		N		N		#	Λ	N		x		N	
T1		250 - 240		Leg		ROHN 2.5 STD	2		-5.04		60.05	8.4		Pass
T2		240 - 220		Leg		ROHN 3 STD	29		-23.34		74.53	31.3		Pass
T3		220 - 200		Leg		ROHN 4 X-STR	67		-56.83		168.03	33.8		Pass
T4		200 - 180		Leg		ROHN 5 EH	106		-86.86		251.35	34.6		Pass
T5		180 - 160		Leg		ROHN 6 EH	145		-110.97		360.24	30.8		Pass
T6		160 - 140		Leg		ROHN 8 EHS	184		-130.09		413.33	31.5		Pass
T7		140 - 120		Leg		ROHN 8 EHS	211		-151.60		413.28	36.7		Pass
T8		120 - 100		Leg		ROHN 8 X-STR	238		-172.51		530.71	32.5		Pass
T9		100 - 80		Leg		ROHN 8 X-STR	265		-193.11		530.66	36.4		Pass
T10		80 - 60		Leg		ROHN 10 EH	292		-214.03		701.99	30.5		Pass
T11		60 - 40		Leg		ROHN 10 X-STR	319		-223.30		701.99	31.8		Pass
T12		40 - 20		Leg		ROHN 10 X-STR	352		-244.60		701.99	34.8		Pass
T13		20 - 0		Leg		ROHN 10 EH	385		-289.09		760.75	38.0		Pass
T1		250 - 240		Diagonal		ROHN 2 STD	8		-2.86		25.36	11.3		Pass
T2		240 - 220		Diagonal		ROHN 2 STD	32		-7.54		18.63	40.5		Pass
T3		220 - 200		Diagonal		ROHN 2 X-STR	71		-9.45		24.62	38.4		Pass
T4		200 - 180		Diagonal		ROHN 2 X-STR	110		-6.50		21.21	30.7		Pass
T5		180 - 160		Diagonal		ROHN 2 X-STR	149		-6.47		18.08	35.8		Pass
T6		160 - 140		Diagonal		ROHN 2.5 X-STR	188		-8.33		22.18	37.5		Pass
T7		140 - 120		Diagonal		ROHN 3 STD	215		-7.99		30.33	26.4		Pass
T8		120 - 100		Diagonal		ROHN 3 STD	242		-8.51		26.47	32.2		Pass
T9		100 - 80		Diagonal		ROHN 3 STD	269		-8.60		22.99	37.4		Pass
T10		80 - 60		Diagonal		ROHN 3 STD	296		-9.78		20.50	47.7		Pass
T11		60 - 40		Diagonal		ROHN 3 STD	323		-15.32		33.46	45.8		Pass
T12		40 - 20		Diagonal		ROHN 3 STD	356		-15.64		31.53	49.6		Pass
T13		20 - 0		Diagonal		ROHN 3 STD	389		-15.55		29.83	52.1		Pass
T1		250 - 240		Horizontal		ROHN 1.5 STD	7		-1.81		23.71	7.6		Pass
T2		240 - 220		Horizontal		ROHN 1.5 STD	31		-4.05		23.65	17.1		Pass
T3		220 - 200		Horizontal		ROHN 1.5 STD	70		-5.11		23.65	21.6		Pass
T4		200 - 180		Horizontal		ROHN 1.5 STD	109		-4.10		20.11	20.4		Pass
T5		180 - 160		Horizontal		ROHN 2 STD	148		-4.47		28.49	15.7		Pass
T6		160 - 140		Horizontal		ROHN 2 STD	187		-5.09		23.88	21.3		Pass
T7		140 - 120		Horizontal		ROHN 2 STD	214		-5.33		17.80	29.9		Pass
T8		120 - 100		Horizontal		ROHN 2.5 STD	241		-5.97		30.40	19.6		Pass
T9		100 - 80		Horizontal		ROHN 2.5 STD	268		-6.31		23.33	27.0		Pass
T10		80 - 60		Horizontal		ROHN 2.5 STD	295		-7.25		18.74	38.7		Pass
T11		60 - 40		Horizontal		ROHN 3 STD	322		-8.09		33.29	24.3		Pass
T12		40 - 20		Horizontal		ROHN 3 STD	355		-8.73		27.40	31.9		Pass
T13		20 - 0		Horizontal		ROHN 3 STD	388		-9.37		22.94	40.8		Pass
T1		250 - 240		Top Girt		ROHN 1.5 STD	4		-1.70		23.77	7.2		Pass
T11		60 - 40		Redund Horz 1 Bracing		ROHN 1.5 STD	324		-3.88		14.74	26.3		Pass
T12		40 - 20		Redund Horz 1 Bracing		ROHN 1.5 STD	357		-4.24		12.04	35.2		Pass
T13		20 - 0		Redund Horz 1 Bracing		ROHN 1.5 STD	390		-5.02		10.03	50.0		Pass
T11		60 - 40		Redund Diag 1 Bracing		ROHN 1.5 STD	325		-3.52		4.53	77.8		Pass
T12		40 - 20		Redund Diag 1 Bracing		ROHN 2.25 TUBE	358		-3.61		4.52	80.0		Pass
T13		20 - 0		Redund Diag 1 Bracing		ROHN 2.25 TUBE	410		-4.02		4.23	95.1		Pass
T11		60 - 40		Redund Hip 1 Bracing		ROHN 1.5 STD	347		-0.02		12.73	0.2		Pass
T12		40 - 20		Redund Hip 1 Bracing		ROHN 1.5 STD	380		-0.02		10.54	0.2		Pass
T13		20 - 0		Redund Hip 1 Bracing		ROHN 1.5 STD	413		-0.02		8.88	0.2		Pass
T11		60 - 40		Redund Hip Diagonal 1 Bracing		ROHN 2.5 STD	337		-0.06		11.01	0.6		Pass
T12		40 - 20		Redund Hip Diagonal 1 Bracing		ROHN 2.5 STD	370		-0.06		9.90	0.6		Pass
T13		20 - 0		Redund Hip Diagonal 1 Bracing		ROHN 3 STD	403		-0.07		17.65	0.4		Pass
T1		250 - 240		Inner Bracing		L2x2x1/8	18		-0.00		8.80	0.1		Pass
T2		240 - 220		Inner Bracing		L2x2x1/8	42		-0.00		8.65	0.1		Pass
T3		220 - 200		Inner Bracing		L2x2x1/8	79		-0.00		8.48	0.1		Pass
T4		200 - 180		Inner Bracing		L2x2x1/8	120		-0.00		6.27	0.1		Pass
T5		180 - 160		Inner Bracing		L2x2x1/8	159		-0.01		4.28	0.1		Pass
T6		160 - 140		Inner Bracing		L2x2x1/8	198		-0.01		3.24	0.2		Pass

$\frac{N}{h' D M N N N N N N N}$
 $\frac{\phi N L W D h W}{x x \frac{N}{W} N N K D z L h K N D}$


S	$\frac{N}{h'}$	#	$\frac{N}{N}$	$\frac{x}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{x}{\#}$	$\frac{N}{h'}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{N}{N}$	$\frac{m N}{x}$	$\frac{I}{/}$	$\frac{N}{N}$
T7		140 - 120		Inner Bracing	L2 1/2x2 1/2x3/16		225	-0.01	6.84	0.2	Pass			
T8		120 - 100		Inner Bracing	L3x3x3/16		252	-0.01	9.02	0.2	Pass			
T9		100 - 80		Inner Bracing	L3 1/2x3 1/2x1/4		279	-0.01	14.69	0.2	Pass			
T10		80 - 60		Inner Bracing	L3 1/2x3 1/2x1/4		306	-0.01	11.72	0.2	Pass			
T11		60 - 40		Inner Bracing	ROHN 3 STD		351	-0.01	30.98	0.2	Pass			
T12		40 - 20		Inner Bracing	ROHN 3 STD		383	-0.01	25.66	0.3	Pass			
T13		20 - 0		Inner Bracing	ROHN 3 STD		416	-0.01	21.61	0.3	Pass			
												Summary		
												Leg (T13)	38.0	Pass
												Diagonal (T13)	52.1	Pass
												Horizontal (T13)	40.8	Pass
												Top Girt (T1)	7.2	Pass
												Redund Horz 1 Bracing (T13)	50.0	Pass
												Redund Diag 1 Bracing (T13)	95.1	Pass
												Redund Hip 1 Bracing (T13)	0.2	Pass
												Redund Hip Diagonal 1 Bracing (T12)	0.6	Pass
												Inner Bracing (T13)	0.3	Pass
												Bolt Checks	49.3	Pass
												RATING =	95.1	Pass

N
 $h' \quad D \quad N \quad N \quad N \quad N \quad N \quad N$
 $N \quad N \quad (D) \quad (h \quad N \quad N) \quad ' \quad D \quad z \quad (\quad w \quad N \quad N \quad N$

$\emptyset \quad N \quad L \quad w \quad D \quad h \quad W$
 $x \quad x \quad w \quad N \quad N \quad K \quad D \quad z \quad L \quad h \quad K$
 $N \quad W$

APPENDIX B

BASE LEVEL DRAWING



N
 $h' \frac{D}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$

$\emptyset$ $N \frac{L}{N} \frac{D}{N} \frac{W}{N}$
 $x \times \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$
 $N \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N} \frac{N}{N}$

APPENDIX C

ADDITIONAL CALCULATIONS

Self Support Anchor Rod Capacity



Site Info		
BU #	809328	
Site Name	KE CITY W J-FL-012-03	
Order #	565094 Rev. 0	


Analysis Considerations		
TIA-222 Revision	H	
Grout Considered:	Yes	
l_{ar} (in)	1.75	

Applied Loads		
	Comp.	Uplift
Axial Force (kips)	287.37	239.42
Shear Force (kips)	34.27	29.87

*TIA-222-H Section 15.5 Applied

Considered Eccentricity		
Leg Mod Eccentricity (in)	0.000	
Anchor Rod N.A Shift (in)	0.000	
Total Eccentricity (in)	0.000	

*Anchor Rod Eccentricity Applied



Connection Properties

Analysis Results

Anchor Rod Data

(16) 1" ϕ bolts (A354-BC N; $F_y=109$ ksi, $F_u=125$ ksi)
 l_{ar} (in): 1.75

Anchor Rod Summary

(units of kips, kip-in)

$P_{u,t} = 14.96$	$\phi P_{n,t} = 56.81$	Stress Rating
$V_u = 1.87$	$\phi V_n = 36.82$	25.1%
$M_u = n/a$	$\phi M_n = n/a$	Pass

 BLACK & VEATCH Building a world of difference. 6800 W. 115th St., Suite 2292 Overland Park, KS 66211 Phone: (913) 458-6909	Client:	Crown Castle	Design:	TYM
	Project:	406642 (809328.1982212)	Date:	6/23/2021
	Site:	LAKE CITY W J-FL-012-058	Verify:	
	Title:	Foundation Design Reaction Comparison	Date:	6/23/2021
			Code:	TIA-222-H

Template Version 1.8

FOUNDATION ANALYSIS:

Original Tower Design Reactions:

Drilled Caisson:

Uplift:	662.0	Kip
Shear:	135.1	Kip
Compression:	747.2	Kip
Shear:	135.1	Kip

Note: Design reactions are multiplied by 1.35 for comparison as allowed by TIA-222-H Section 15.6.2.

TnxTower Reactions:

Drilled Caisson:

Uplift:	239.4	Kip
Shear:	29.9	Kip
Compression:	287.4	Kip
Shear:	34.3	Kip

Stress Ratio:

Drilled Caisson:

Uplift:	34.4%
Shear:	21.1%
Compression:	36.6%
Shear:	24.2%

Note: Ratings per TIA-222-H Section 15.5.

Conclusion:

When the calculated reactions are compared to the original design reactions, the existing foundation is considered to have been designed and constructed with adequate capacity to support the existing and proposed loads.

Controlling Foundation Stress Ratio:



36.6%

ASCE 7 Hazards Report

Address:
No Address at This
Location

Standard: ASCE/SEI 7-16
Risk Category: II
Soil Class: D - Default (see
Section 11.4.3)

Elevation: 166.05 ft (NAVD 88)
Latitude: 30.182344
Longitude: -82.660558



Wind

Results:

Wind Speed:	118 Vmph
10-year MRI	75 Vmph
25-year MRI	84 Vmph
50-year MRI	90 Vmph
100-year MRI	97 Vmph

Data Source: ASCE/SEI 7-16, Fig. 26.5-1B and Figs. CC.2-1–CC.2-4, and Section 26.5.2

Date Accessed: Fri Jun 18 2021

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (annual exceedance probability = 0.00143, MRI = 700 years).





Site is in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2. Glazed openings need not be protected against wind-borne debris.

Site Soil Class: D - Default (see Section 11.4.3)

Results:

S_S :	0.085	S_{D1} :	0.081
S_1 :	0.051	T_L :	8
F_a :	1.6	PGA :	0.041
F_v :	2.4	PGA _M :	0.065
S_{MS} :	0.137	F_{PGA} :	1.6
S_{M1} :	0.121	I_e :	1
S_{DS} :	0.091	C_v :	0.7

Seismic Design Category B



Data Accessed:

Fri Jun 18 2021

Date Source:

USGS Seismic Design Maps based on ASCE/SEI 7-16 and ASCE/SEI 7-16 Table 1.5-2. Additional data for site-specific ground motion procedures in accordance with ASCE/SEI 7-16 Ch. 21 are available from USGS.

Results:

Ice Thickness: 0.25 in.
Concurrent Temperature: 25 F
Gust Speed: 30 mph

Data Source: Standard ASCE/SEI 7-16, Figs. 10-2 through 10-8

Date Accessed: Fri Jun 18 2021

Ice thicknesses on structures in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

Values provided are equivalent radial ice thicknesses due to freezing rain with concurrent 3-second gust speeds, for a 500-year mean recurrence interval, and temperatures concurrent with ice thicknesses due to freezing rain. Thicknesses for ice accretions caused by other sources shall be obtained from local meteorological studies. Ice thicknesses in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

The ASCE 7 Hazard Tool is provided for your convenience, for informational purposes only, and is provided "as is" and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE 7 standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE 7 standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE 7 Hazard Tool.