



13618 NW 270th Ave.
Alachua, FL 32615
(386) 418-4387
dwpest@windstream.net

NOTICE OF TREATMENT

Date 4/16/2012 Time 11:00

Treatment Address 366 SW Mountain St

Subdivision Three Rivers

Lot # _____

Type of Treatment: Soil or Wood

Square Feet 1350 Linear Feet 140

Chemical Procon .05 %

Gallons Applied 135gal

Area Treated main body

Remarks _____

Technician [Signature]

Per Florida Building Code 104.2.6 – If soil chemical barrier method for termite prevention is used, final exterior treatment shall be completed prior to final building approval.

DW Pest – White

Permit File – Yellow

Permit Holder - Pink