

**April 1, 2022**

William Dalton  
368 SW Upstate Glen  
Lake City, FL 32024

**Subject: Permit #43946, Lot 41, Oaks of Lake City, Phase 1, Columbia County - Elevation Letter**

Dear William:

Daniel & Gore, LLC has performed a vertical survey on Lot 41, Oaks of Lake City, Phase 1 (Parcel #09280-114), Columbia County, Florida from a benchmark being a concrete monument (P.R.M.) at the P.C. of Lot 75, Oaks of Lake City Phase 2 (elevation – 91.745', NAVD 1988) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 75.0'.
- The top of the concrete foundation is at 78.7', being 3.7' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

