

911 - BLDG. (ADDITION)
(RENOVATIONS)

✓ Occupancy Classification - BUSINESS
(CHAPTER 3)

ASSY. AREA < 50 occupants considered
in CONF. AREA.

✓ TYPE Construction - V (5) - (WOOD)
(CHAPTER 6)

✓ AREA OF BUILDING (EXISTING) - 9,935 ⁴
" " " (PROPOSED) - 10,817 ⁴ (922 ⁴ ADDITION)
(CHAPTER 5)

✓ DETAILED Occupancy Reqs
(CHAPTER 4)



✓ EXISTING Building Code Provisions/Reqs
(SEPARATE CODE) HAVE 2 ALTERNATIONS, PER B. FREEMAN -
(TO DOCUMENT FOR THE RECORD!)

✓ Interior Finishes - CLASS "B" (CORRIDORS)
(CHAPTER 8) CLASS "C" (ROOMS)

✓ Fire Rated Const. - NON-RATED (TYPE V-B)
(CHAPTER 7)

NOTE! → SEE FIRE MARSHAL'S

911 BLDG.

Fire Protection Systems

CHAPTER 9

Per FBC. & NFPA (Fire Marshal's Review)
907.2.2

MEANS OF EGRESS

CHAPTER 10

SEE LIFE SAFETY 101 - (Fire Marshal) OK

ACCESSIBILITY CODE

CHAPTER 11

INTERIOR ENVIRONMENT - SEE Fire Marshal's Comments

CHAPTER 12

ENERGY [CODE]

CHAPTER 13

ELECTRICAL CODE - N.E.C. 2008, CHAPTER 34 EX. BLDG. CODE

CHAPTER 27

MECHANICAL CODE (SEE Fire Marshal's Comments)



911 BLDG.

PLUMBING CODE
Chapter 29

