



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM (OSTDS)

PERMIT NO. 24-0909
DATE PAID: 12/16/24
FEE PAID: 210.00
RECEIPT #: 2182087

APPLICATION FOR CONSTRUCTION PERMIT

APPLICATION FOR:

- New System Existing System Holding Tank Innovative
 Repair Abandonment Temporary

APPLICANT: Cecil Whitehead

AGENT: Kameron Keen

EMAIL: _____

MAILING ADDRESS: 474 NE 628th St. Old Town, FL 32680 TELEPHONE: 352-356-1333

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3) (a) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: 1 BLOCK: _____ SUBDIVISION: Falling Creek Farms Unrec OSTDS REMEDIATION PLAN? [Y /] PLATTED: _____

PROPERTY ID #: 31-2S-17-04804-101 ZONING: _____ I/M OR EQUIVALENT: [Y /]

PROPERTY SIZE: 11.71 ACRES WATER SUPPLY: PRIVATE PUBLIC [<=2000GPD] >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? [Y /] DISTANCE TO SEWER: _____ FT

PROPERTY ADDRESS: NW Falling Creek Rd. Lake City 32055

DIRECTIONS TO PROPERTY: Take 41 N, TR on Falling Creek Rd, property on R.

BUILDING INFORMATION

Unit No	Type of Establishment	<input checked="" type="checkbox"/> RESIDENTIAL		<input type="checkbox"/> COMMERCIAL	
		No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table I, Chapter 62-6, FAC	
1	<u>SFR-MH</u>	<u>5</u>	<u>2136</u>		
2					
3					
4					

Floor/Equipment Drains Other (Specify) _____

SIGNATURE: Kameron Keen

232064

DATE: 12-11-24

DEF 4015, 05-21-2022 (Obsoletes previous editions which may not be used)
Incorporated 62-6.004, FAC



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

PERMIT #: **12-SC-3054542**
APPLICATION #: **AP2182087**
DATE PAID: **12/16/24**
FEE PAID: **310.00**
RECEIPT #:
DOCUMENT #: **PR2201084**

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: CECIL**24-0908 WHITEHEAD
PROPERTY ADDRESS: NW FALLING CREEK Rd Lake City, FL 32024
LOT: 1 BLOCK: _____ SUBDIVISION: Falling Creek Farms Unrec
PROPERTY ID #: 04804-101 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.


SYSTEM DESIGN AND SPECIFICATIONS

T [1,200] GALLONS / GPD New Multi-Chambered Septic CAPACITY
A [] GALLONS / GPD N/A CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [575] SQUARE FEET Drainfield SYSTEM
R [] SQUARE FEET N/A SYSTEM
A TYPE SYSTEM: [] STANDARD [] FILLED [x] MOUND []
I CONFIGURATION: [x] TRENCH [] BED []

F LOCATION OF BENCHMARK: Nail with orange ribbon in pine N of site
I ELEVATION OF PROPOSED SYSTEM SITE [20.50] [INCHES] FT [ABOVE / BELOW] BENCHMARK/REFERENCE POINT
E BOTTOM OF DRAINFIELD TO BE [14.50] [INCHES] FT [ABOVE / BELOW] BENCHMARK/REFERENCE POINT
L
D FILL REQUIRED: [24.00] INCHES EXCAVATION REQUIRED: [] INCHES

The system is sized for 5 bedrooms with a maximum occupancy of 10 persons (2 per bedroom), for a total estimated flow of 460 gpd.

SPECIFICATIONS BY: (Joshua) Kameron Keen TITLE: CEHP
APPROVED BY:  TITLE: Environmental Specialist I Columbia CHD
DATE ISSUED: 12/20/2024 EXPIRATION DATE: 06/20/2026

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)
Incorporated 62-6.004, FAC

KM

NOTICE OF RIGHTS

A party whose substantial interest is affected by this order may petition for an administrative hearing pursuant to sections 120.569 and 120.57, Florida Statutes. Such proceedings are governed by Rule 28-106, Florida Administrative Code. A petition for administrative hearing must be in writing and must be received by the Agency Clerk for the Department, within twenty-one (21) days from the receipt of this order. The address of the agency clerk is 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. The Agency Clerk's email is agency_clerk@FloridaDEP.gov.


Mediation is not available as an alternative remedy.

Your failure to submit a petition for hearing within 21 days from receipt of this order will constitute a waiver of your right to an administrative hearing, and this order shall become a 'final order'.

Should this order become a final order, a party who is adversely affected by it is entitled to judicial review pursuant to Section 120.68, Florida Statutes. Review proceedings are governed by the Florida Rules of Appellate Procedure. Such proceedings may be commenced by filing one copy of a Notice of Appeal with the Agency Clerk of the Department of Environmental Protection and a second copy, accompanied by the filing fees required by law, with the Court of Appeal in the appropriate District Court. The notice must be filed within 30 days of rendition of the final order.

24-0908

Cecil Whitehead
Lot 1 Falling Creek Farms
NW Falling Creek Rd.
Lake City



James Keel
23-2064
12-11-24



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM

PERMIT NO. 24-0908

SITE EVALUATION AND SYSTEM SPECIFICATIONS

APPLICANT: Cecil Whitehead AGENT: K. Keen
LOT: 1 BLOCK: _____ SUBDIVISION: Falling Creek Farms Unrec
PROPERTY ID #: 31-2S-17-04804-101 [Section/Township/Parcel No. or Tax ID Number]

TO BE COMPLETED BY ENGINEER, HEALTH DEPARTMENT EMPLOYEE, OR OTHER QUALIFIED PERSON. ENGINEERS MUST PROVIDE REGISTRATION NUMBER AND SIGN AND SEAL EACH PAGE OF SUBMITTAL. COMPLETE ALL ITEMS.

PROPERTY SIZE CONFORMS TO SITE PLAN: YES NO NET USABLE AREA AVAILABLE: 1 ACRES
TOTAL ESTIMATED SEWAGE FLOW: 460 GALLONS PER DAY [TABLE J / OTHER]
AUTHORIZED SEWAGE FLOW: 1500 GALLONS PER DAY [500 GPD/ACRE OR 2500 GPD/ACRE]
UNOBSTRUCTED AREA AVAILABLE: 2000 SQFT UNOBSTRUCTED AREA REQUIRED: 863 SQFT

BENCHMARK/REFERENCE POINT LOCATION: Nail with orange ribbon in pine N of site
ELEVATION OF PROPOSED SYSTEM SITE IS 20.5 [INCHES/FT] [ABOVE/BELOW] BENCHMARK/REFERENCE POINT

THE MINIMUM SETBACK WHICH CAN BE MAINTAINED FROM THE PROPOSED SYSTEM TO THE FOLLOWING FEATURES
SURFACE WATER: NA FT DITCHES/SWALES: NA FT NORMALLY WET? YES NO
WELLS: PUBLIC: NA FT LIMITED USE: NA FT PRIVATE: 85 FT NON-POTABLE: NA FT
BUILDING FOUNDATIONS: 10 FT PROPERTY LINES: 16 FT POTABLE WATER LINES: 32 FT

SITE SUBJECT TO FREQUENT FLOODING: YES NO 10 YEAR FLOODING? YES NO
YEAR FLOOD ELEVATION FOR SITE: _____ FT MSL/NGVD SITE ELEVATION: _____ FT MSL/NGVD

SOIL PROFILE INFORMATION SITE 1 20.5" B

MUNSELL #/COLOR	TEXTURE	DEPTH
10YR 5/1	FS	0 TO 12
10YR 6/3	FS	12 TO 24
10YR 7/3	FS	24 TO 42
10YR 6/4	SL	42 TO 54
10YR 6/6	SCL	54 TO 72
		TO
CMN/DST RF		TO
10YR 6/6	FS	18 TO 24
		TO
USDA SOIL SERIES: Mapped <u>Ocilla</u>		

SOIL PROFILE INFORMATION SITE 2 22" B

MUNSELL #/COLOR	TEXTURE	DEPTH
10YR 5/1	FS	0 TO 10
10YR 6/3	FS	10 TO 24
10YR 7/3	FS	24 TO 42
10YR 6/4	SL	42 TO 60
10YR 6/6	SCL	60 TO 72
		TO
CMN/DST RF		TO
10YR 6/6	FS	18 TO 24
		TO
USDA SOIL SERIES: Mapped <u>Ocilla</u>		

OBSERVED WATER TABLE: NA INCHES [ABOVE / BELOW] EXISTING GRADE. TYPE: [PERCHED / APPARENT]
ESTIMATED WET SEASON WATER TABLE ELEVATION: 18 INCHES [ABOVE / BELOW] EXISTING GRADE
HIGH WATER TABLE VEGETATION: YES NO WSWT INDICATOR: YES NO DEPTH: 18 INCHES

SOIL TEXTURE/LOADING RATE FOR SYSTEM SIZING: FS (8) DEPTH OF EXCAVATION: _____ INCHES
DRAINFIELD CONFIGURATION: TRENCH BED OTHER (SPECIFY) _____
REMARKS/ADDITIONAL CRITERIA: _____

SITE EVALUATED BY: K. Keen 23-2064 DATE: 12-11-24

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)

Incorporated: 62-6.004, FAC

