

---

**Britt Surveying and Mapping, LLC**

2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

10/26/2021

Permit # 000041982

L-28080


Stanley Crawford Construction, Inc.

Re: Lot 22 Rose Pointe

To Whom It May Concern:

The top of the finished slab on said Lot 22 is 104.37 feet. The centerline of SW Cherry Blossom Way is determined to be 102.42 feet. The minimum floor elevation per the building permit is to be 1 foot above the road. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt

LS 5757

