

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

April 28, 2022

Chris Cox

Cornerstone Developers

386.292.2076

chris@hplumbing.net

re: ELEVATION LETTER – 194 SW GUINEVERE WAY, LAKE CITY, FL

As requested, I inspected the building site for the proposed construction at the above referenced site. The home was constructed at the time of the inspection. The photo was taken from SW Guinevere Way looking southwest. The topography of the property slopes to the west. Per the SRWMD Flood Report, there are no flood zones on the site.



The minimum finished floor elevation shown on the plat is 101.8'; however, per the attached letter by Britt Surveying and Mapping dated April 25, 2022, the actual finished floor elevation is 100.53'. The finished floor elevation of 100.53' is sufficient to protect the home from water damage in a base flood event.

□

I certify that the minimum finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Digitally signed by
Carol Chadwick
DN: c=US,
o=Florida,
dnQualifier=A014
10D0000017EB6D
924CE0005954C,
cn=Carol
Chadwick
Date: 2022.04.28
07:41:51 -04'00'

Carol Chadwick, P.E.

attachments: SRWMD Flood Report, Elevation Certification by Britt Surveying and Mapping dated April 25, 2022



Britt Surveying and Mapping, LLC
1438 SW Main Boulevard • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

04/25/2022

Permit # 000043312

L-28527

Cornerstone Development

Re: Lot 9 Stonehenge Phase 2

To Whom It May Concern:

The top of the finished slab on Lot 9 is found to be 100.53 feet. The building permit shows the minimum floor elevation to be 101.8 feet (plat is in NGVD 29 datum) 100.99 feet NAVD 88. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt
LS 5757



EFFECTIVE FLOOD INFORMATION REPORT



Location Information

County: COLUMBIA
Parcel: 23-4S-16-03099-209
Flood Zone: X
Flood Risk: LOW

1% Annual Chance Base Flood Elev* Not Applicable
10% Annual Chance Flood Elev* Not Applicable
50% Annual Chance Flood Elev* Not Applicable

* Flood Elevations shown on this report are in NAVD 88 and are derived from FEMA flood mapping products, rounded to the nearest tenth of a foot. For more information, please see the note below

Legend with Flood Zone Designations

	1% Flood -Floodway (High Risk)		Area Not Included		CrossSections		Wetlands
	1% Flood - Zone AE (High Risk)		SFHA Decrease		County Boundaries		
	1% Flood - Zone A (HighRisk)		SFHA Increase		FIRM Panel Index		
	1% Flood - Zone VE (HighRisk)		Depressions		Parcels		
	0.2% Flood-Shaded Zone X (Moderate Risk)		BaseFlood Elevations (BFE)		River Marks		

Supplemental Information

Watershed	Santa Fe	Map Effective Date	11/2/2018	Special Flood Hazard Area	No
FIRM Panel(s)	12023C0289D				

Anywhere it can rain, it can flood.
Know your risk.



www.srwmdfloodreport.com

The information herein represents the best available data as of the effective map date shown. The Federal Emergency Management Agency (FEMA) Flood Map Service Center (<https://msc.fema.gov>) maintains the database of Flood Insurance Studies and Digital Flood Insurance Rate Maps, as well as additional information such as how the Base Flood Elevations (BFEs) and/or floodways have been determined and previously issued Letters of Map Change. Requests to revise flood information may be provided to the District during the community review period on preliminary maps, or through the appropriate process with FEMA Change Your Flood Zone Designation. | FEMA.gov. Information about flood insurance may be obtained at (<https://www.floodsmart.com>)

Base Flood Elevation (BFE)

The elevation shown on the Flood Insurance Rate Map for Zones AE, AH, A1-A30, AR, AO, V1-V30, and VE that indicates the water surface elevation resulting from a flood that has a one percent chance of equaling or exceeding that level in any given year.

A

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. Because detailed analyses are not performed for such areas; no depths or base flood elevations are shown within these zones.

AE, A1-A30

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. In most instances, base flood elevations derived from detailed analyses are shown at selected intervals within these zones.

AH

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. Usually areas of ponding with flood depths of 1 to 3 feet. Base Flood Elevations are determined.

AO

Areas with a 1% annual chance of flooding and a 26% chance of flooding over the life of a 30-year mortgage. Usually areas of sheet flow on sloping terrain with flood depths of 1 to 3 feet. Base Flood Elevations are determined.

Supplemental Information:

10%-chance flood elevations (10-year flood-risk elevations) and 50%-chance flood elevations (2-year flood-risk elevations), are calculated during detailed flooding studies but are not shown on FEMA Digital Flood Insurance Rate Maps (FIRMs). They have been provided as supplemental information in

AE FW (FLOODWAYS)

The channel of a river or other watercourse and the adjacent land areas that must be reserved in order to discharge the base flood (1% annual chance flood event). The floodway must be kept open so that flood water can proceed downstream and not be obstructed or diverted onto other properties.

Please note, if you develop within the regulatory floodway, you will need to contact your Local Government and the Suwannee River Water Management District prior to commencing with the activity. Please contact the District at 800.226.1066.

VE

Areas with a 1% annual chance of flooding over the life of a 30-year mortgage with additional hazards due to storm-induced velocity wave action. Base Flood Elevations (BFEs) derived from detailed analyses.

X 0.2 PCT (X Shaded, 0.2 PCT ANNUAL CHANCE FLOOD HAZARD)

Same as Zone X; however, detailed studies have been performed, and the area has been determined to be within the 0.2 percent annual chance floodplain (also known as the 500-year flood zone). Insurance purchase is not required in this zone but is available at a reduced rate and is recommended.

X

All areas outside the 1-percent annual chance floodplain are Zone X. This includes areas of 1% annual chance sheet flow flooding where average depths are less than 1 foot, areas of 1% annual chance stream flooding where the contributing drainage area is less than 1 square mile, or areas protected from the 1% annual chance flood by levees. No Base Flood Elevations or depths are shown within this zone. Insurance purchase is not required in these zones.

LINKS FEMA:

<http://www.fema.gov>

SRWMD:

<http://www.srwmd.state.fl.us>

CONTACT

SRWMD
9225 County Road 49
Live Oak, FL 32060
(386) 362-1001

Toll Free:
(800) 226-1066