

This combination qualifies for a Federal Energy Efficiency Tax Credit when placed in service between Feb 17, 2009 and Dec 31, 2011.

Certificate of Product Ratings

AHRI Certified Reference Number: 3595782

Date: 9/6/2012

Product: Single-Package Heat Pump Air-Source

Model Number: 50VT-A42---31

Manufacturer: CARRIER AIR CONDITIONING

Trade/Brand name: CARRIER

Manufacturer responsible for the rating of this system combination is CARRIER AIR CONDITIONING

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):

40500

EER Rating (Cooling):

12.00

SEER Rating (Cooling):

14.50

Heating Capacity(Btuh) @ 47 F:

41500

Region IV HSPF Rating (Heating): 8.00

Heating Capacity(Btuh) @ 17 F:

23000

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed below.

Air-Conditioning, Heating, and Refrigeration Institute

©2012 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.: 129914144457761346

^{*} Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.



Project Summary Entire House

Precision Tech Heating & Air LLC

Job:

Date: August 06, 2012

By:

PO Box 877, Alachua, FL 32616-0877 Phone: 352-378-5111 Fax: 386-462-0714 Email: Dave@PrecisionTechInfo.com Web: www.PrecisionTechInfo.com

Project Information

For:

Shaun Fergus

516 SW Hawthorne TERR, Fort White, FL 32038 Phone: 352-872-2761

Notes:

Double Wide Mobile Home.

Design Information

Weather: Gainesville Regional AP, FL, US

Winter Design Conditions

Summer Design Conditions

Outside db	33	°F	Outside db	92	°F
Inside db	70	°F	Inside db	75	°F
Design TD	37	°F	Design TD	17	°F
managa en			Daily range	M	
			Relative humidity	50	%
			Moisture difference	47	ar/lb

Heating Summary

Sensible Cooling Equipment Load Sizing

Structure Ducts Central vent (0 cfm) Humidification	20623 Btuh	Structure	19664 Btuh
	6315 Btuh	Ducts	10675 Btuh
	0 Btuh	Central vent (0 cfm)	0 Btuh
	0 Btuh	Blower	0 Btuh
Piping 0 Btuh Equipment load 26938 Btuh		Use manufacturer's data Rate/swing multiplier Equipment sensible load	n 0.97 29429 Btuh

Infiltration

Method Construction quality		Simplified Average	Latent Cooling Equipment Load Sizing		
Fireplaces		0	Structure Ducts	2454 1803	Btuh Btuh
	Heating	Cooling	Central vent (0 cfm)	0	Btuh
Area (ft²) Volume (ft³)	1512 13608	1512 13608	Equipment latent load	4257	Btuh
Air changes/hour Equiv. AVF (cfm)	0.38 86	0.20 45	Equipment total load Req. total capacity at 0.70 SHR	33686 3.5	Btuh ton

Heating Equipment Summary		Cooling Equipment Summary		
Make Trade	Carrier CARRIER 50/T 442 31	Make Trade	Carrier CARRIER	

AHRI ref no3595782		Coil 50V 1-A4231	
Efficiency	8 HSPF	AHRI ref no3595782 Efficiency 12.0 EER, 14.5	5 SEER
Heating input	41500 Btuh @ 47°F	Sensible cooling	28350 Btuh
Heating output		Latent cooling	12150 Btuh
Temperature rise Actual air flow	28 °F	Total cooling	40500 Btuh
	1350 cfm	Actual air flow	1350 cfm
Air flow factor	0.050 cfm/Btuh	Air flow factor	0.044 cfm/Btuh
Static pressure	0 in H2O	Static pressure	0 in H2O
Space thermostat	0 11/11/20	Load sensible heat ratio	0.88

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



2012-Sep-06 10:12:45