



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

02/06/2020

Permit # 000038354

L-26349

Re: Lot 22 Southern Meadows Phase 3

Aleksey Shatalov

To Whom It May Concern:

The top of the building slab on lot 22 is found to be at 86.96 feet. The lowest adjacent grade is 86.2 feet and the highest adjacent grade is 86.5 feet. The building permit shows the minimum floor elevation is 86.00 feet. The elevations are shown in plat datum.

Sincerely,


L. Scott Britt
LS 5757

