

GEO-TECH, INC.

Engineering Consultants in Geotechnical • Environmental • Construction Materials Testing

FIELD DENSITY WORKSHEET

CLIENT America Home Place DATE 12-7-21
 PROJECT NO. _____
 PROJECT NAME 437 Peacock Terr Lake City PERMIT NO. _____
 EARTH CONTRACTOR _____ TESTED BY CO
 COMPACTION REQUIREMENT (%) 95 ☐ Standard Proctor ☒ Modified Proctor FIELD CONTACT _____
 TOTAL ON-SITE TIME _____ MILES FROM OFFICE _____
☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☒ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
Approx 15' NE of SW corner	1106	116	EG	12"	40	114.2	109.8	97.3
Approx 15' SW of NE corner	1	1	1	1	33	112.0	108.4	98.0
Approx 1/4 of East Footing	1	1	1	1	37	112.9	108.8	98.4

REMARKS _____

* Density failed to meet minimum project requirement
 ** Retest indicates minimum density requirement was obtained.
 () Client is aware of unsatisfactory test results.