



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

10/04/2023

L-29876

Re: Lots 38 Rolling Meadows

Exceptions Realty

To Whom It May Concern:

The finished floor elevation on said lot 38 is found to be 108.43 feet. The plat of record shows the minimum floor elevation (MFE) to be 108.00 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Scott Britt", is written over the printed name.

L. Scott Britt
LS 5757