

P.O. Box 1501 Lake City, Florida 32056

June 2, 2014

**Aaron Simque Homes** Lake City, FL 32025

Subject: Lots 63 & 64 Preserve at Laurel Lakes Elevation Letter

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lots 63 & 64. Preserve at Laurel Lakes, Unit 1, Columbia County, Florida from a benchmark being a stamped nail & disk at the intersection of SW Bellflower Drive and SW Rosemary Drive (elevation – 115.55', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation for Lot 63 to be 118.3' and the minimum finish floor elevation for Lot 64 to be 117.8'.
- The top of stem wall of the foundation is at 118.7', being the 0.4' above the highest minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM