

General Notes

A. CONCRETE & FOUNDATION DESIGN:

1. ALL CONCRETE GRADE BEAMS AND FOOTINGS SHALL BE 3000 PSI MINIMUM

2. ALL CONCRETE FILLED SUPPORTED SLABS SHALL BE 2500 PSI MINIMUM, 3 1/2" NOMINAL THICKNESS.

3. FIBERMESH (3/4" PER CUBIC YARD MIN.) MEETING APPROPRIATE ACI AND ASTM REQUIREMENTS MAY BE USED IN LIEU OF WELDED WIRE MESH

4. ALL SLABS ON GRADE SHALL BE 4" THICK WITH FIBERMESH.

5. ALL REINFORCING SHALL CONFORM TO ASTM A615, BE GRADE 60 (60 KSI MIN.) DEFORMED BARS, #3 BARS MAY BE GRADE 40

6. ALL OVER POUR CONCRETE FILLED SUPPORTED SLABS SHALL BE 3000 PSI MIN., 2" MINIMUM THICKNESS.

7. SOIL BEARING PRESSURE SHALL BE A MINIMUM OF 1500 PSF

8. THE CONCRETE SHALL CONFORM TO ASTM C94 FOR THE FOLLOWING:  
OPC (PORTLAND CEMENT TYPE I, - ASTM C 150)  
AGGREGATES - #6 STONE, ASTM C 33 SIZE NO. 67 LESS THAN 3/4".

AIR ENTRAINING +/- 1% - ASTM C 260  
WATER REDUCING AGENT - ASTM C 494.  
CLEAN POTABLE WATER.  
OTHER ADMIXTURES SHALL NOT BE PERMITTED.

9. METAL WELDED WIRE SHALL CONFORM TO ASTM A 185.

10. PREPARE & PLACE CONCRETE ACCORDING TO AMERICAN CONCRETE INSTITUTE MANUAL STANDARD PRACTICE, PART 1, 2, & 3 ALONG WITH HOT WEATHER CONDITIONS RECOMMENDATIONS.

11. IF UTILIZING EXISTING CONCRETE FOR FOUNDATION, CONCRETE SHALL BE A MINIMUM OF 4" IN THICKNESS, VISIBLY FREE OF ANY STRUCTURAL EXCESSIVE CRACKING, SPALLING OR OTHER DETERIORATION.
- B. MASONRY:**

1. CONCRETE MASONRY UNITS (CMU) SHALL BE STANDARD HOLLOW UNITS AND SHALL BE 1900 PSI MINIMUM BASED ON TYPE M OR S MORTAR

2. ALL MORTAR SHALL BE OF TYPE M OR S.

3. ALL GROUT SHALL BE 2000 PSI MINIMUM AND HAVE MAXIMUM COARSE AGGREGATE SIZE OF 3/8".

4. PROVIDE CLEAN-OUTS FOR REINFORCED CELLS CONTAINING REINFORCEMENT WHEN GROUT POUR EXCEEDS 5'-0" IN HEIGHT.
- C. ALUMINUM:**

1. ALL STRUCTURAL ALUMINUM SHALL CONFORM TO THE MINIMUM REQUIREMENTS OF 6005-T5 FOR ALLOY WITH A MINIMUM THICKNESS OF 0.040" FOR SUPPORTING MEMBERS.

2. WHERE KICK PLATES ARE USED A MINIMUM THICKNESS OF 0.024" SHALL APPLY.

3. STRUCTURAL ALUMINUM DESIGN CONFORMS TO "PART 1-A - SPECIFICATIONS FOR ALUMINUM STRUCTURES - ALLOWABLE STRESS DESIGN" OR "PART 1-B - SPECIFICATIONS FOR ALUMINUM STRUCTURES - BUILDING LOAD AND RESISTANCE FACTOR DESIGN" OF THE ALUMINUM DESIGN MANUAL PREPARED BY THE ALUMINUM ASSOCIATION, INC. WASHINGTON D.C. THE FLORIDA BUILDING CODE 6TH EDITION ( CHAPTER 16 STRUCTURAL DESIGN & CHAPTER 20 ALUMINUM)

4. WHERE ALUMINUM COMES INTO CONTACT WITH STEEL, OR PRESSURE TREATED LUMBER PROVIDE DIELECTRIC SEPARATION.

5. ALUMINUM MEMBERS SHALL BE STITCHED WITH NO LESS THAN #10 SMS 6" FROM THE ENDS AND 12" ON CENTER, IF USING #12 SPACING MAY BE 24" ON CENTER.

6. VINYL/ACRYLIC/GLASS PANELS SHALL BE REMOVABLE. THEY SHALL BE IDENTIFIED WITH A DECAL ESSENTIALLY STATING "REMOVABLE PANEL SHALL BE REMOVED WHEN WIND SPEEDS EXCEED 75 MPH". DECAL SHALL BE PLACED SO IT IS VISIBLE WHEN PANEL IS INSTALLED

(ACRYLIC/GLASS WINDBREAKERS INCLUDED)
- D. FASTENERS:**

1. ALL LAG BOLTS SHALL CONFORM TO STAINLESS STEEL TYPE 300 18-8, WITH STANDARD FLAT WASHER UNLESS MANUFACTURER GALVANIZES BOLTS SPECIFIES FOR USE WITH ACQ PRESSURE TREATED WOOD

2. HEX BOLTS HAS TO BE ASTM A 325, PLATED WITH STANDARD FLAT WASHERS AND NUTS.

3. ALL CONCRETE SCREWS SHALL BE, SIMPSON, HILTI, RAWL, TAPCON, REDHEAD, DYNABOLT, OR APPROVED EQUAL.

4. ALL METAL TIES AND ASSOCIATED ACCESSORIES SHALL BE
- HOT DIPPED GALVANIZED.

5. ALL LAG BOLTS SHALL HAVE A MINIMUM EMBEDMENT OF 8X BOLT DIAMETER INTO STRUCTURAL FRAMING (G-42 MIN.).

6. LAG BOLTS AND SCREWS INTO WOOD FRAMING SHALL BE PROVIDED WITH PILOT HOLES HAVING A DIAMETER NOT GREATER THAN 70 PERCENT OF THE THREAD DIAMETER OF THE BOLT OR SCREW. ALL LAG BOLTS AND SCREWS SHALL BE INSERTED IN PILOT HOLES BY TURNING AND UNDER NO CIRCUMSTANCES BY DRIVING WITH A HAMMER.

7. ALL EXPANSION ANCHORS SHALL BE DESIGNED IN ACCORDANCE WITH THE SPECIFIC MANUFACTURER'S REQUIREMENTS AND ALLOWABLE LOADS AND SHALL ONLY BE APPLIED IN CONDITIONS ACCEPTABLE TO MANUFACTURER. FASTENERS SHALL BE A MINIMUM OF SAE GRADE #5 OR BETTER ZINC PLATED.

8. ALL FASTENERS CONNECTING ALUMINUM COMPONENTS OR PRESSURE TREATED LUMBER ARE STAINLESS STEEL TYPE 300 18-8, UNLESS MANUFACTURER GALVANIZED BOLTS SPECIFIES FOR USE WITH ACQ PRESSURE TREATED WOOD, OR OTHERWISE NOTED ON PLANS.

9. ALL FASTENERS SHALL COMPLY WITH ASTM A153.

10. ALL CONNECTORS SHALL COMPLY WITH ASTM A653 CLASS G-185.

11. FOR SMS, THE MINIMUM CENTER-TO-CENTER SPACING SHALL BE 3/4" AND MINIMUM CENTER-TO-EDGE SHALL BE 1/2" UNLESS NOTED OTHER WISE.
- E. REFERENCE STANDARDS:**

ASTM E 119  
ASTM E 1300  
ASCE 7 -10  
AA AS35, AND SPEC. FOR ALUMINUM PART 1-A, & 1-B  
ASTM C94  
ASTM C150  
ASTM C150  
ASTM C150  
ASTM C260  
ASTM C494  
ASTM A615  
ASTM A185  
FLORIDA BUILDING CODE (CHAPTERS 16, 20 AND 23) 6TH EDITION  
CURRENT ALUMINUM DESIGN MANUAL

- F. ABBREVIATIONS:**

THE FOLLOWING LIST OF ABBREVIATIONS IS NOT INTENDED TO REPRESENT ALL THOSE USED ON THESE DRAWINGS, BUT TO SUPPLEMENT THE MORE COMMON ABBREVIATIONS.

1. TYP -- TYPICAL

2. SIM -- SIMILAR

3. UN -- UNLESS OTHERWISE NOTED

4. CONT -- CONTINUOUS

5. VIF -- VERIFY IN FIELD
- G. RESPONSIBILITY:**

1. ALL SITE WORK SHALL BE PERFORMED BY A LICENSED CONTRACTOR IN ACCORDANCE WITH APPLICABLE BUILDING CODES, LOCAL ORDINANCES, ETC.

2. CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND DETAILS, NOTIFYING ENGINEER OF ANY DISCREPANCIES BETWEEN DRAWINGS, FABRICATED ITEMS, OR ACTUAL FIELD CONDITIONS.

3. THESE DRAWINGS REPRESENT THE ACCEPTABILITY OF THE SUNROOM ROOM ADDITION ELEMENTS AS PROVIDED BY THE CONTRACTOR.

4. ALL DETAILS ON THESE DRAWINGS ARE ENGINEERED BASED ON INFORMATION PROVIDED BY THE CONTRACTOR AND MANUFACTURER.

5. ANY DETAILS NOT SHOWN ARE TO BE ENGINEERED BY A LICENSED P.E. IN ACCORDANCE WITH STANDARD ENGINEERING PRACTICES.
- H. MISCELLANEOUS:**

1. ALUMINUM ADDITIONS ARE NOT TO BE INSTALLED ON A MANUFACTURED HOME, TRAILER HOME, OR PRE-FAB HOME. IF THE EXISTING STRUCTURE IS ONE OF THESE, A SEPARATE 4TH WALL SUPPORT SYSTEM MUST BE ENGINEERED SO THAT NO ADDITIONAL LOADING IS PLACED ON THE MANUFACTURED HOME.

2. IF ENCLOSURE CONTAINS A SWIMMING POOL OR SPA, THE ENCLOSURE SHALL COMPLY WITH RESIDENTIAL SWIMMING BARRIER REQUIREMENTS OF THE FBC 6TH EDITION R 4501.17.1 IN ITS ENTIRETY.

3. EMERGENCY ESCAPE & RESCUE OPENING PER FBC R310.1 SHALL BE VERIFIED BY CONTRACTOR & BUILDING OFFICIAL

4. DOOR LOCATIONS MAY BE DETERMINED BY CONTRACTOR.
5. IF PAVERS ARE UNDER ALUMINUM, HAVE EPOXY ADHESIVE TO CONCRETE TO ENSURE BONDING AGENT IS USED
6. SCREENING MATERIAL SHALL BE EQUIVALENT DENSITY SCREEN MATERIAL ON DRAWING S-2.
7. 1"x2"x.045 NON-STRUCTURAL MESH TO HOST WITH 1/4" DIAMETER X 1/2" MASONRY SCREW FOR CONCRETE WHEN IN WOOD & #10 X 1/2" EMBED IN ALUMINUM MEMBERS TYPICAL.

JOB DESCRIPTION: SCREENING

DESIGN DATA:

1. ULTIMATE DESIGN WIND SPEED: 115 MPH  
NOMINAL DESIGN WIND SPEED: 90 MPH
2. RISK CATEGORY : 2
3. WIND EXPOSURE : 3
4. WIND LOADS:  
SCREEN ROOF:  
SCREEN WALLS:  
SOLID ROOF (MWFRS):
5. FACTOR APPLIED TO SCREEN OR EQUIVALENT DENSITY SCREENING
6. FACTOR APPLIED TO SCREENING
7. LIVE LOAD:  
300 lb. VERTICAL DOWN  
200 lb. VERTICAL DOWN
8. EXISTING CONCRETE SLAB AND TO RESIST THE UPLIFTS FOR
9. SCREEN ROOF TYPE: GABLE
10. SOLID ROOF TYPE: N/A

ALUMINUM STRUCTURES

HOLLOW SECTIONS

- 2 x 2:
- 2 x 2:
- 2 x 3:
- 2 x 3:
- 2 x 4:
- 2 x 4:
- 2 x 5:

OPEN BACK SECTIONS

- 1 x 2:
- 1 x 3:

SNAP SECTIONS

- 2 x 2 Snap:
- 2 x 3 Snap:
- 2 x 4 Snap:

SELF MATING

- 2 x 4 SMB:
- 2 x 5 SMB:
- 2 x 6 SMB:
- 2 x 7 SMB:
- 2 x 8 SMB:
- 2 x 9 SMB:
- 2 x 10 SMB: