

70

Notice of Treatment

Applicator: Florida Pest Control & Chemical Co. (www.flapest.com)

Address: 536 SE BAYVIEW

City: LAKE CITY

Phone: 386 7521703

Site Location: Subdivision _____

Lot # _____

Block# _____

Permit # 303/7

Address: 636 NW COUNTRY LAKE DR

Product used

Active Ingredient

% Concentration

- | | | |
|---|----------------------------------|-------|
| <input checked="" type="checkbox"/> Premise | Imidacloprid | 0.1% |
| <input type="checkbox"/> Termidor | Fipronil | 0.12% |
| <input type="checkbox"/> Bora-Care | Disodium Octaborate Tetrahydrate | 23.0% |

Type treatment:

☒ Soil

☐ Wood

Area Treated

Square feet

Linear feet

Gallons Applied

DWELLING

3424

359

350

As per Florida Building Code 104.2.6 – If soil chemical barrier method for termite prevention is used, final exterior treatment shall be completed prior to final building approval.

If this notice is for the final exterior treatment, initial this line _____.

8.13.12

Date

8.16

Time

DAVID FULLER

Print Technician's Name

Remarks: _____

Applicator - White

Permit File - Canary

Permit Holder - Pink

10/05

©