



Affine Engineering and Surveying, Inc.

---

Date: 5/4/2021

Ms. Angela Burch

307.686.8080

Re: **Elevation Letter—188 NW Castlewood Court, Lake City, FL.**

SUBJECT:

FINISH FLOOR HEIGHT VERIFICATION

To whom it may concern,

During a field survey conducted 5/4/2021 on Lot 14 of Suwannee Valley Farms Unit I – Parcel 29-2S-16-01777-114-7350, the finish floor of the existing structure was measured. According to an elevation letter prepared by Carol Chadwick PE - Job#FL21053 signed 2-27-2021, the elevation of the extension of the south property line to the centerline of NW Castlewood Court is at elevation 92.0'. Based on that elevation and after measuring the elevation of the Finish Floor, it was found that the Finish Floor is at elevation 89.18 feet.



Victor O. Marrero, PE, PSM

Florida PSM 6586

