



City of Lake City Accessibility Letter Required before Building Permit Issuance



Service Representatives :

Growth Management: growthmanagement@lcfla.com,

Utilities: PelhamS@lcfla.com, MedearisK@lcfla.com, McGhinB@lcfla.com

Date: 9/2/2025

County Application # 73007

Applicant Name: MARTIN LUTOV

Phone: (352) 213-9577

Email: MLUTOV1@YAHOO.COM

Site Address: 1391 SW BIRLEY AVE LAKE CITY, FL 32024

Parcel: 05-4S-16-02775-002

Acres: 1.64

Project Description: Remodel

Existing Structures on Property:

Any tree removal:

Number of trees removed:

Trees remaining:

Utilities:

Utility Accessibility: Water: Unavailable Sewer: Unavailable Gas: Unavailable City Letter of Accessibility Required: No

Utility Active: Water: Inactive Sewer: Inactive Gas: Inactive Has Impact Fee: No Impact Fees paid:

Customer service official's name: **Shasta Pelham**

Reviewed: 9/11/2025

Requires Tap Inspection: No

Customer service official's notes: The City of Lake City does not provide utilities to this location.

Zoning:

Minimum Setback Requirements: Font: Side: Rear:

Landscape Requirements:

Flood Zone: B.F.E.: Finished Floor Elevation Requirement:

Site Approval Plan:

Special Exception: Variance:

Documents Required:

Needed Before Power: No

Needed Before CO: No

Zoning official clearance

Date Reviewed:

Access:

Permit Issued: Needed Before CO:

Access official clearance

Date Reviewed:

Code Enforcement:

Code Enforcement Cases: None Case Notes:

Code Enforcement clearance

Date Reviewed:

Special Notes to be noted on permit