

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

March 20, 2025

Jordan Dejesus

Creative Concepts

386.289.8999

dejesusjordan2012@gmail.com

re: ENGINEER'S REPORT: 281 SW MARKS DRIVE, LAKE CITY, FL

Two trusses and the wall were damaged by a fallen tree. The damaged trusses shall be completely replaced. The damaged walls shall be reconstructed using full height 2x4 SYP #2 studs. Wall and roof sheathing shall be replaced in full sheets. Damaged electric and HVAC shall be repaired in the walls and attic. Siding shall match existing siding. All fasteners shall comply with FBC-Residential, 8th Edition.

In my professional opinion, these repairs meet the specifications in the 2023 Florida Building Code - Residential, 8th Edition. Should you have any questions, please don't hesitate to contact me.

Respectfully,

Digitally signed by
Carol Chadwick
DN: c=US,
o=Florida,
dnQualifier=A014
10D0000018D463
B4E7500032FEE,
cn=Carol
Chadwick
Date: 2025.03.20
16:35:41 -04'00'

Carol Chadwick, P.E.

This item has been digitally signed and sealed by Carol Chadwick, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

CC Job FL25143

