


23-0269



- SURVEYOR'S NOTES:**
1. BOUNDARY BASED ON MONUMENTA)
 2. THE ORIGINAL SURVEY FOR SAID BEARINGS ARE BASED ON SAID P
 3. IT IS APPARENT THAT THIS PAR THE 500 YEAR FLOOD PLAIN AS PANEL NUMBER 1202300459C. HD TO CHANGE.
 4. THE IMPROVEMENTS, IF ANY, INCL DATE OF FIELD SURVEY AS SHL
 5. IF THEY EXIST, NO UNDERGROUN. THIS SURVEY EXCEPT AS SHOWN
 6. THIS SURVEY WAS COMPLETED 1
 7. POLICY.
 7. DIMENSIONS SHOWN HEREON ARE

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
APPLICATION FOR CONSTRUCTION PERMIT

1"=40'

Permit Application Number 23-0369

----- PART II - SITEPLAN ----- Thigpen

See Att.

Notes: _____

Site Plan submitted by: Robert Ford 999 Date: 5-15-2023

Plan Approved Not Approved Date 5/19/23
By [Signature] [Signature] County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)
Incorporated: 62-6.004, F.A.C.



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

PERMIT #: 12-SC-2708316
APPLICATION #: AP1965985
DATE PAID: 5/16/23
FEE PAID: 3000
RECEIPT #: _____
DOCUMENT #: PR1939193

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: WAYNE**23-0369 THIGPEN
PROPERTY ADDRESS: 1073 SW CENTRAL Fort White, FL 32038
LOT: 71,72 BLOCK: _____ SUBDIVISION: 3 Rivers Est U-19
PROPERTY ID #: 01201-000 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [900] GALLONS / GPD _____ Septic Tank _____ CAPACITY
A [] GALLONS / GPD _____ N/A _____ CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @[] DOSES PER 24 HRS #Pumps []
D [375] SQUARE FEET _____ Drainfield _____ SYSTEM
R [] SQUARE FEET _____ N/A _____ SYSTEM
A TYPE SYSTEM: [X] STANDARD [] FILLED [] MOUND [] _____
I CONFIGURATION: [X] TRENCH [] BED [] _____

F LOCATION OF BENCHMARK: oak tree E. of site.
I ELEVATION OF PROPOSED SYSTEM SITE [24.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT
E BOTTOM OF DRAINFIELD TO BE [54.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT
L
D FILL REQUIRED: [0.00] INCHES EXCAVATION REQUIRED: [0.00] INCHES

O The system is sized for 3 bedrooms with a maximum occupancy of 6 persons (2 per bedroom), for a total estimated flow of 300 gpd.
T
H
E
R

Keep system on lot 71

SPECIFICATIONS BY: Robert W Ford TITLE: _____
APPROVED BY: Dustin W Jones TITLE: Environmental Specialist II Columbia CHD
DATE ISSUED: 05/19/2023 EXPIRATION DATE: 11/19/2024
DH 4016, 08/09 (Obsoletes all previous editions which may not be used)
Incorporated: 64E-6.003, FAC



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM (OSTDS)

PERMIT NO. 23-0369
DATE PAID: 5/14/23
FEE PAID: 310.00
RECEIPT #: 1965985

APPLICATION FOR CONSTRUCTION PERMIT

APPLICATION FOR:

New System Existing System Holding Tank Innovative
 Repair Abandonment Temporary

APPLICANT: WAYNE THIGPEN (C & G) EMAIL: nflsepticTank@comcast.net

AGENT: ROBERT FORD III- NORTH FLORIDA SEPTIC TANK INC TELEPHONE: 386-755-6372

MAILING ADDRESS: 741 SE STATE ROAD 100, LAKE CITY FL 32025

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3) (m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION Septic is on lot 71 OSTDS REMEDIATION PLAN? [Y / N]

LOT: 71 & 72 BLOCK: U-19 SUBDIVISION: THREE RIVERS ESTATES PLATTED: _____

PROPERTY ID #: 00-00-00-01201-000 ZONING: _____ I/M OR EQUIVALENT: [Y / N]

PROPERTY SIZE: 1.836 Lot 71 = .91A ACRES WATER SUPPLY: PRIVATE PUBLIC [] <=2000GPD [] >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? [Y /] DISTANCE TO SEWER: _____ FT

PROPERTY ADDRESS: 1073 SW CENTRAL TER, FORT WHITE FL

DIRECTIONS TO PROPERTY: SR 47 S. to SR 27 turn Right follow to Riverside Rd turn Left / turn Left on Utah St. Turn Right on Central Terr. Cross Montana St. 800' or left.

BUILDING INFORMATION RESIDENTIAL COMMERCIAL

Unit No.	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table I, Chapter 62-6, FAC
1	MH	3	1780	
2				
3				
4				

Floor/Equipment Drains Other (Specify) _____

SIGNATURE: Robert Ford III DATE: 5-15-2023

23-0369

Thigpen Job
1"=40'
Robert Ford
5-15-2023

SW Central Terr.

- 200 -

