

DATE 07/16/2004

Columbia County Building Permit

PERMIT

This Permit Expires One Year From the Date of Issue

000022089

APPLICANT MARY ANN CRAWFORD PHONE 752-5152  
ADDRESS 885 SW SISTERS WELCOME RD LAKE CITY FL 32025  
OWNER STANLEY CRAWFORD PHONE 752-5152  
ADDRESS 219 SW FANTASY GLN LAKE CITY FL 32024  
CONTRACTOR STANLEY CRAWFORD PHONE 752-5152  
LOCATION OF PROPERTY 90 W, L 247, R UPCHURCH, L VISTA LANE, LOT ON RIGHT

TYPE DEVELOPMENT SFD, UTILITY ESTIMATED COST OF CONSTRUCTION 109400.00  
HEATED FLOOR AREA 2188.00 TOTAL AREA 2928.00 HEIGHT 21.60 STORIES 1  
FOUNDATION CONCRETE WALLS FRAMED ROOF PITCH 7/12 FLOOR SLAB  
LAND USE & ZONING RSF-1 MAX. HEIGHT 35  
Minimum Set Back Requirments: STREET-FRONT 25.00 REAR 15.00 SIDE 10.00  
NO. EX.D.U. 0 FLOOD ZONE X PP DEVELOPMENT PERMIT NO.

PARCEL ID 16-4S-16-03025-105 SUBDIVISION MEADOW VISTA  
LOT 5 BLOCK PHASE UNIT TOTAL ACRES 1.00

000000360 N RG0042896  
Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor  
PERMIT 04-0764-N BK RJ N  
Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: NOC ON FILE, FLOOR 1 FOOT ABOVE THE ROAD  
Check # or Cash 1232

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power Foundation Monolithic  
date/app. by date/app. by date/app. by  
Under slab rough-in plumbing Slab Sheathing/Nailing  
date/app. by date/app. by date/app. by  
Framing Rough-in plumbing above slab and below wood floor  
date/app. by date/app. by  
Electrical rough-in Heat & Air Duct Peri. beam (Lintel)  
date/app. by date/app. by date/app. by  
Permanent power C.O. Final Culvert  
date/app. by date/app. by date/app. by  
M/H tie downs, blocking, electricity and plumbing Pool  
date/app. by date/app. by  
Reconnection Pump pole Utility Pole  
date/app. by date/app. by date/app. by  
M/H Pole Travel Trailer Re-roof  
date/app. by date/app. by date/app. by

BUILDING PERMIT FEE \$ 550.00 CERTIFICATION FEE \$ 14.64 SURCHARGE FEE \$ 14.64  
MISC. FEES \$ .00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ WASTE FEE \$  
FLOOD ZONE DEVELOPMENT FEE \$ CULVERT FEE \$ 25.00 TOTAL FEE 654.28

INSPECTORS OFFICE CLERKS OFFICE

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

This Permit Must Be Prominently Posted on Premises During Construction

PLEASE NOTIFY THE COLUMBIA COUNTY BUILDING DEPARTMENT AT LEAST 24 HOURS IN ADVANCE OF EACH INSPECTION, IN ORDER THAT IT MAY BE MADE WITHOUT DELAY OR INCONVIENCE, PHONE 758-1008. THIS PERMIT IS NOT VALID UNLESS THE WORK AUTHORIZED BY IT IS COMMENCED WITHIN 6 MONTHS AFTER ISSUANCE.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.



## Columbia County Building Permit Application

JLW 7-12-04  
22089 / 360

For Office Use Only

Application # 0407-27

Permit #

Application Approved by - Zoning Official BLK Date 16.07.04 Plans Examiner \_\_\_\_\_ Date \_\_\_\_\_  
Flood Zone Xppld Development Permit NIA Zoning RSF-1 Land Use Plan Map Category RES. U. L. DEN.  
Comments \_\_\_\_\_

Applicants Name Stanley Crawford Construction, Inc. Phone (386) 752-5152Address 885 SW Sisters Welcome Rd. Lake City, FL 32025Owners Name Stanley Crawford Phone (386) 752-5152

911 Address \_\_\_\_\_

Contractors Name Stanley Crawford Phone (386) 752-5152Address Same as above

Fee Simple Owner Name &amp; Address \_\_\_\_\_

Bonding Co. Name &amp; Address \_\_\_\_\_

Architect/Engineer Name & Address Nick Geisler 591 Custard St. Lake City, FL 32055

Mortgage Lenders Name &amp; Address \_\_\_\_\_

Property ID Number 16-45-16-03025-105 Estimated Cost of Construction \$80,000.00Subdivision Name Meadow Vista Lot 5 Block \_\_\_\_\_ Unit \_\_\_\_\_ Phase \_\_\_\_\_Driving Directions Highway 90 West, Left on Co. Rd. 247, Turn right on Upchurch, Turn Left on Vista Lane - Lot is on the Right.Type of Construction New Custom Residential House Number of Existing Dwellings on Property 0Total Acreage 1 acre Lot Size 1 acre Do you need a Culvert Permit or Culvert Waiver or Have an Existing DriveActual Distance of Structure from Property Lines - Front 50 Side 44 ~~20~~ Side 30 Rear 198Total Building Height 21'6" Number of Stories 1 Heated Floor Area 2185.5 Roof Pitch 12/7

Application is hereby made to obtain a permit to do work and installations as indicated. I certify that no work or installation has commenced prior to the issuance of a permit and that all work be performed to meet the standards of all laws regulating construction in this jurisdiction.

OWNERS AFFIDAVIT: I hereby certify that all the foregoing information is accurate and all work will be done in compliance with all applicable laws and

**WARNING TO OWNER:** YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOU PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT.

Stanley Crawford  
Owner Builder or Agent (Including Contractor)


STATE OF FLORIDA  
COUNTY OF COLUMBIA

Sworn to (or affirmed) and subscribed before me  
this 12<sup>th</sup> day of July 2004.

Personally known ✓ or Produced Identification \_\_\_\_\_

Stanley Crawford  
Contractor Signature  
Contractors License Number RG-0042896  
Competency Card Number 5225

NOTARY STAMP/SEAL




Janet Cheek  
Notary Signature

**Application for Onsite Sewage Disposal System  
Construction Permit. Part II Site Plan**  
 Permit Application Number: 04-0764N

**ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH UNIT**

CRAWFORD/CR 03-2170



Site Plan Submitted By Paul Lloyd Date 4/24/04  
 Plan Approved ☒ Not Approved ☐ Date 6/24/04  
 By Paul Lloyd Jakob Brook C CPHU 7-13-04

Notes: \_\_\_\_\_

NOTICE OF COMMENCEMENT FORM  
COLUMBIA COUNTY, FLORIDA

THE UNDERSIGNED hereby gives notice that improvement will be made to certain real property, and in accordance with Chapter 713, Florida Statutes, the following information is provided in this Notice of Commencement.

Tax Parcel ID Number 16-45-16-03025-105

1. Description of property: (legal description of the property and street address or 911 address)  
Meadow Vista Lot 5  
219 SW Fantasy Glen Lake City, FL 32024
2. General description of improvement: Construction of Dwelling
3. Owner Name & Address Stanley Crawford 885 S.W. Sisters Welcome  
Rd. Lake City, FL 32025 Interest in Property Fee Simple
4. Name & Address of Fee Simple Owner (if other than owner): N/A
5. Contractor Name Stanley Crawford Construction, INC. Phone Number (386) 752-5152  
Address 885 S.W. Sisters Welcome Rd. Lake City, FL 32025
6. Surety Holders Name N/A Phone Number \_\_\_\_\_  
Address \_\_\_\_\_  
Amount of Bond \_\_\_\_\_ Inst: 2004016126 Date: 07/12/2004 Time: 12:32  
YMK DC, P. DeWitt Cason, Columbia County B: 1020 P: 1815
7. Lender Name N/A  
Address \_\_\_\_\_
8. Persons within the State of Florida designated by the Owner upon whom notices or other documents may be served as provided by section 718.13 (1)(a) 7; Florida Statutes:  
Name None Phone Number \_\_\_\_\_  
Address \_\_\_\_\_
9. In addition to himself/herself the owner designates N/A of \_\_\_\_\_  
to receive a copy of the Lienor's Notice as provided in Section 713.13 (1) -  
(a) 7. Phone Number of the designee \_\_\_\_\_
10. Expiration date of the Notice of Commencement (the expiration date is 1 (one) year from the date of recording, (Unless a different date is specified) \_\_\_\_\_

**NOTICE AS PER CHAPTER 713, Florida Statutes:**

The owner must sign the notice of commencement and no one else may be permitted to sign in his/her stead.

Stanley Crawford  
Signature of Owner

Sworn to (or affirmed) and subscribed before  
day of July 12<sup>th</sup>, 2004



Janet L. Cheek  
Signature of Notary

MEADOW VISTA LOT 5

VISTA LANE

134'

50'

SEPTIC

70'

30'

4'

E 1/2


WELL

198'

133'

334'

NORTH  
↓





**Columbia County Building Department  
Culvert Permit**

**Culvert Permit No.  
000000360**

DATE 07/16/2004 PARCEL ID # 16-4S-16-03025-105  
APPLICANT MARY ANN CRAFTORD PHONE 752-5152  
ADDRESS 885 SW SISTERS WELCOME RD LAKE CITY FL 32025  
OWNER STANLEY CRAWFORD PHONE 752-5152  
ADDRESS 219 SW FANTASY GLN LAKE CITY FL 32024  
CONTRACTOR STANLEY CRAWFORD PHONE 752-5152  
LOCATION OF PROPERTY 90 WEST, L 247, R UPCHURCH, L VISTA LN, LOT ON RIGHT

SUBDIVISION/LOT/BLOCK/PHASE/UNIT MEADOW VISTA 5

SIGNATURE *Mary Ann Crawford*

**INSTALLATION REQUIREMENTS**



Culvert size will be 18 inches in diameter with a total length of 32 feet, leaving 24 feet of driving surface. Both ends will be mitered 4 foot with a 4 : 1 slope and poured with a 4 inch thick reinforced concrete slab.

INSTALLATION NOTE: Turnouts will be required as follows:

- a) a majority of the current and existing driveway turnouts are paved, or;
- b) the driveway to be served will be paved or formed with concrete.

Turnouts shall be concrete or paved a minimum of 12 feet wide or the width of the concrete or paved driveway, whichever is greater. The width shall conform to the current and existing paved or concreted turnouts.



Culvert installation shall conform to the approved site plan standards.



Department of Transportation Permit installation approved standards.



Other \_\_\_\_\_

ALL PROPER SAFETY REQUIREMENTS SHOULD BE FOLLOWED  
DURING THE INSTALLATION OF THE CULVERT.

135 NE Hernando Ave., Suite B-21  
Lake City, FL 32055  
Phone: 386-758-1008 Fax: 386-758-2160

**Amount Paid 25.00**



# FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Florida Department of Community Affairs  
Residential Whole Building Performance Method A

Project Name: <b>MEADOW VISTA #6</b>	Builder: <b>STANLY CRAWFORD</b>
Address:	Permitting Office: <i>Columbia Co.</i>
City, State:	Permit Number: <i>22089</i>
Owner:	Jurisdiction Number: <i>221000</i>
Climate Zone: <b>North</b>	

1. New construction or existing	New	---
2. Single family or multi-family	Single family	---
3. Number of units, if multi-family	1	---
4. Number of Bedrooms	4	---
5. Is this a worst case?	Yes	---
6. Conditioned floor area (ft <sup>2</sup> )	2186.9 ft <sup>2</sup>	---
7. Glass area & type	Single Pane Double Pane	---
a. Clear glass, default U-factor	0.0 ft <sup>2</sup> 233.0 ft <sup>2</sup>	---
b. Default tint	0.0 ft <sup>2</sup> 0.0 ft <sup>2</sup>	---
c. Labeled U or SHGC	0.0 ft <sup>2</sup> 0.0 ft <sup>2</sup>	---
8. Floor types		---
a. Slab-On-Grade Edge Insulation	R=0.0, 223.0(p) ft	---
b. N/A		---
c. N/A		---
9. Wall types		---
a. Frame, Wood, Exterior	R=11.0, 1860.0 ft <sup>2</sup>	---
b. Frame, Wood, Adjacent	R=11.0, 270.0 ft <sup>2</sup>	---
c. N/A		---
d. N/A		---
e. N/A		---
10. Ceiling types		---
a. Under Attic	R=30.0, 2186.9 ft <sup>2</sup>	---
b. N/A		---
c. N/A		---
11. Ducts		---
a. Sup: Unc. Ret: Unc. AH: Garage	Sup. R=6.0, 145.0 ft	---
b. N/A		---
12. Cooling systems		---
a. Central Unit	Cap: 48.0 kBtu/hr SEER: 10.00	---
b. N/A		---
c. N/A		---
13. Heating systems		---
a. Electric Heat Pump	Cap: 46.0 kBtu/hr HSFP: 7.00	---
b. N/A		---
c. N/A		---
14. Hot water systems		---
a. Electric Resistance	Cap: 50.0 gallons EF: 0.88	---
b. N/A		---
c. Conservation credits	(HR-Heat recovery, Solar DHP-Dedicated heat pump)	---
15. HVAC credits	(CF-Ceiling fan, CV-Cross ventilation, HF-Whole house fan, PT-Programmable Thermostat, MZ-C-Multizone cooling, MZ-H-Multizone heating)	PT, ---

Glass/Floor Area: 0.11

Total as-built points: 34190

Total base points: 35298

**PASS**

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code. *CM*

PREPARED BY: SUNCOAST INSULATORSDATE: 7/1/04

I hereby certify that this building, as designed, is in compliance with the Florida Energy Code.

OWNER/AGENT: \_\_\_\_\_

DATE: \_\_\_\_\_

Review of the plans and specifications covered by this calculation indicates compliance with the Florida Energy Code. Before construction is completed this building will be inspected for compliance with Section 553.908 Florida Statutes.



BUILDING OFFICIAL: \_\_\_\_\_

DATE: \_\_\_\_\_

# Code Compliance Checklist

## Residential Whole Building Performance Method A - Details

ADDRESS: , , ,

PERMIT #:

**6A-21 INFILTRATION REDUCTION COMPLIANCE CHECKLIST**

COMPONENTS	SECTION	REQUIREMENTS FOR EACH PRACTICE	CHECK
Exterior Windows & Doors	606.1.ABC.1.1	Maximum: .3 cfm/sq. ft. window area; .5 cfm/sq. ft. door area.	
Exterior & Adjacent Walls	606.1.ABC.1.2.1	Caulk, gasket, weatherstrip or seal between: windows/doors & frames, surrounding wall; foundation & wall sole or sill plate; joints between exterior wall panels at corners; utility penetrations; between wall panels & top/bottom plates; between walls and floor. EXCEPTION: Frame walls where a continuous infiltration barrier is installed that extends from, and is sealed to, the foundation to the top plate.	
Floors	606.1.ABC.1.2.2	Penetrations/openings >1/8" sealed unless backed by truss or joint members. EXCEPTION: Frame floors where a continuous infiltration barrier is installed that is sealed to the perimeter, penetrations and seams.	
Ceilings	606.1.ABC.1.2.3	Between walls & ceilings; penetrations of ceiling plane of top floor; around shafts, chases, soffits, chimneys, cabinets sealed to continuous air barrier; gaps in gyp board & top plate; attic access. EXCEPTION: Frame ceilings where a continuous infiltration barrier is installed that is sealed at the perimeter, at penetrations and seams.	
Recessed Lighting Fixtures	606.1.ABC.1.2.4	Type IC rated with no penetrations, sealed; or Type IC or non-IC rated, installed inside a sealed box with 1/2" clearance & 3" from insulation; or Type IC rated with < 2.0 cfm from conditioned space, tested.	
Multi-story Houses	606.1.ABC.1.2.5	Air barrier on perimeter of floor cavity between floors.	
Additional Infiltration reqts	606.1.ABC.1.3	Exhaust fans vented to outdoors, dampers; combustion space heaters comply with NFPA, have combustion air.	

**6A-22 OTHER PRESCRIPTIVE MEASURES (must be met or exceeded by all residences.)**

COMPONENTS	SECTION	REQUIREMENTS	CHECK
Water Heaters	612.1	Comply with efficiency requirements in Table 6-12. Switch or clearly marked circuit breaker (electric) or cutoff (gas) must be provided. External or built-in heat trap required.	
Swimming Pools & Spas	612.1	Spas & heated pools must have covers (except solar heated). Non-commercial pools must have a pump timer. Gas spa & pool heaters must have a minimum thermal efficiency of 78%.	
Shower heads	612.1	Water flow must be restricted to no more than 2.5 gallons per minute at 80 PSIG.	
Air Distribution Systems	610.1	All ducts, fittings, mechanical equipment and plenum chambers shall be mechanically attached, sealed, insulated, and installed in accordance with the criteria of Section 610. Ducts in unconditioned attics: R-8 min. insulation.	
HVAC Controls	607.1	Separate readily accessible manual or automatic thermostat for each system.	
Insulation	604.1, 602.1	Ceilings-Min. R-19. Common walls-Frame R-11 or CBS R-3 both sides. Common ceiling & floors R-11.	



# WATER HEATING & CODE COMPLIANCE STATUS

## Residential Whole Building Performance Method A - Details

ADDRESS: , , ,

PERMIT #:

BASE				AS-BUILT					
WATER HEATING									
Number of Bedrooms	X	Multiplier	= Total	Tank Volume	EF	Number of Bedrooms	X Tank X Ratio	Multiplier X Credit	= Total Multiplier
4		2746.00	10984.0	50.0	0.88	4	1.00	2746.00	1.00 10984.0
				As-Built Total:					
				10984.0					

CODE COMPLIANCE STATUS							
BASE				AS-BUILT			
Cooling Points	+ Heating Points	+ Hot Water Points	= Total Points	Cooling Points	+ Heating Points	+ Hot Water Points	= Total Points
12539	11775	10984	35298	11303	11903	10984	34190

PASS



**WINTER CALCULATIONS****Residential Whole Building Performance Method A - Details**

ADDRESS: , , ,

PERMIT #:

<b>BASE</b>				<b>AS-BUILT</b>							
<b>Winter Base Points:</b>		<b>18768.6</b>		<b>Winter As-Built Points:</b>						<b>20582.3</b>	
Total Winter Points	X System Multiplier	=	Heating Points	Total Component	X Cap Ratio	X Duct Multiplier (DM x DSM x AHU)	X System Multiplier	X Credit Multiplier	=	Heating Points	
<b>18768.6</b>	<b>0.6274</b>		<b>11775.4</b>	<b>20582.3</b>	<b>1.00</b>	<b>1.250</b>	<b>0.487</b>	<b>0.950</b>		<b>11903.3</b>	
				<b>20582.3</b>	<b>1.00</b>	<b>1.250</b>	<b>0.487</b>	<b>0.950</b>		<b>11903.3</b>	

# WINTER CALCULATIONS

## Residential Whole Building Performance Method A - Details

ADDRESS: , , ,

PERMIT #:

BASE				AS-BUILT							
<b>GLASS TYPES</b>											
.18 X Conditioned X BWPM = Points Floor Area				Type/SC	Overhang Omt Len Hgt		Area X WPM X WOF = Points				
.18	2186.9	12.74	5015.0	Double, Clear	W	2.0	6.0	70.0	20.73	1.04	1513.0
				Double, Clear	E	2.0	6.0	115.0	18.79	1.06	2292.0
				Double, Clear	S	2.0	6.0	18.0	13.30	1.28	301.2
				Double, Clear	N	2.0	6.0	30.0	24.58	1.00	740.8
				As-Built Total:				233.0	4847.0		
<b>WALL TYPES</b> Area X BWPM = Points				Type	R-Value		Area X WPM = Points				
Adjacent	270.0	3.60	972.0	Frame, Wood, Exterior	11.0		1860.0	3.70	6882.0		
Exterior	1860.0	3.70	6882.0	Frame, Wood, Adjacent	11.0		270.0	3.60	972.0		
Base Total:				2130.0		7864.0		As-Built Total:			
						2130.0		7854.0			
<b>DOOR TYPES</b> Area X BWPM = Points				Type	R-Value		Area X WPM = Points				
Adjacent	20.0	11.50	230.0	Exterior Insulated			40.0	8.40	336.0		
Exterior	40.0	12.30	492.0	Adjacent Insulated			20.0	8.00	160.0		
Base Total:				60.0		722.0		As-Built Total:			
						60.0		496.0			
<b>CEILING TYPES</b> Area X BWPM = Points				Type	R-Value		Area X WPM X WCM = Points				
Under Attic	2186.9	2.05	4483.1	Under Attic	30.0		2186.9	2.05 X 1.00	4483.1		
Base Total:				2186.9		4483.1		As-Built Total:			
						2186.9		4483.1			
<b>FLOOR TYPES</b> Area X BWPM = Points				Type	R-Value		Area X WPM = Points				
Slab	223.0(p)	8.9	1984.7	Slab-On-Grade Edge Insulation	0.0		223.0(p)	18.80	4192.4		
Raised	0.0	0.00	0.0								
Base Total:				1984.7		4192.4		As-Built Total:			
						223.0		4192.4			
<b>INFILTRATION</b> Area X BWPM = Points				Area X WPM = Points							
2186.9 -0.59 -1290.3				2186.9 -0.59 -1290.3							



# SUMMER CALCULATIONS

## Residential Whole Building Performance Method A - Details

ADDRESS: , , ,

PERMIT #:

BASE				AS-BUILT							
Summer Base Points:		29392.2		Summer As-Built Points:				27883.2			
Total Summer Points	X	System Multiplier	= Cooling Points	Total Component	X	Cap Ratio	X Duct Multiplier (DM x DSM x AHU)	X System Multiplier	X Credit Multiplier	= Cooling Points	
29392.2		0.4266	12538.7	27883.2		1.00	(1.090 x 1.147 x 1.00)	0.341	0.950	11303.0	
				27883.2		1.00	1.250	0.341	0.950	11303.0	

## SUMMER CALCULATIONS

## Residential Whole Building Performance Method A - Details

ADDRESS: , , ,

PERMIT #:

BASE				AS-BUILT							
GLASS TYPES											
.18 X Conditioned X BSPM = Points Floor Area				Type/SC	Overhang Omt Len Hgt			Area X SPM X SOF = Points			
.18	2186.9	20.04	7888.8	Double, Clear	W	2.0	8.0	70.0	38.52	0.85	2290.5
				Double, Clear	E	2.0	8.0	115.0	42.06	0.85	4102.2
				Double, Clear	S	2.0	8.0	18.0	35.87	0.78	501.0
				Double, Clear	N	2.0	8.0	30.0	19.20	0.90	518.5
				As-Built Total:			233.0			7412.2	
WALL TYPES Area X BSPM = Points				Type	R-Value			Area X SPM = Points			
Adjacent	270.0	0.70	189.0	Frame, Wood, Exterior	11.0			1660.0	1.70	3182.0	
Exterior	1860.0	1.70	3182.0	Frame, Wood, Adjacent	11.0			270.0	0.70	189.0	
Base Total:				2130.0			3351.0				
				As-Built Total:			2130.0			3351.0	
DOOR TYPES Area X BSPM = Points				Type				Area X SPM = Points			
Adjacent	20.0	2.40	48.0	Exterior Insulated				40.0	4.10	164.0	
Exterior	40.0	6.10	244.0	Adjacent Insulated				20.0	1.60	32.0	
Base Total:				60.0			292.0				
				As-Built Total:			60.0			196.0	
CEILING TYPES Area X BSPM = Points				Type	R-Value			Area X SPM X SCM = Points			
Under Attic	2186.9	1.73	3783.3	Under Attic	30.0			2186.9	1.73 X 1.00	3783.3	
Base Total:				2186.9			3783.3				
				As-Built Total:			2186.9			3783.3	
FLOOR TYPES Area X BSPM = Points				Type	R-Value			Area X SPM = Points			
Slab	223.0(p)	-37.0	-8251.0	Slab-On-Grade Edge Insulation	0.0			223.0(p)	-41.20	-9187.6	
Raised	0.0	0.00	0.0								
Base Total:				-8251.0			223.0			-9187.6	
				As-Built Total:			223.0			-9187.6	
INFILTRATION Area X BSPM = Points							Area X SPM = Points				
2186.9 10.21 22328.2							2186.9 10.21			22328.2	

# ENERGY PERFORMANCE LEVEL (EPL) DISPLAY CARD

**ESTIMATED ENERGY PERFORMANCE SCORE\* = 83.1**

The higher the score, the more efficient the home.

1. New construction or existing	New	12. Cooling systems	
2. Single family or multi-family	Single family	a. Central Unit	Cap: 48.0 kBtu/hr
3. Number of units, if multi-family	1		SEER: 10.00
4. Number of Bedrooms	4	b. N/A	
5. Is this a worst case?	Yes	c. N/A	
6. Conditioned floor area (ft <sup>2</sup> )	2186.9 ft <sup>2</sup>	13. Heating systems	
7. Glass area & type	Single Pane Double Pane	a. Electric Heat Pump	Cap: 46.0 kBtu/hr
a. Clear - single pane	0.0 ft <sup>2</sup> 233.0 ft <sup>2</sup>		HSPF: 7.00
b. Clear - double pane	0.0 ft <sup>2</sup> 0.0 ft <sup>2</sup>	b. N/A	
c. Tint/other SHGC - single pane	0.0 ft <sup>2</sup> 0.0 ft <sup>2</sup>	c. N/A	
d. Tint/other SHGC - double pane		14. Hot water systems	
8. Floor types		a. Electric Resistance	Cap: 50.0 gallons
a. Slab-On-Grade Edge Insulation	R=0.0, 223.0(p) ft		EF: 0.88
b. N/A		b. N/A	
c. N/A		c. Conservation credits	
9. Wall types		(HR-Heat recovery, Solar	
a. Frame, Wood, Exterior	R=11.0, 1860.0 ft <sup>2</sup>	DHP-Dedicated heat pump)	
b. Frame, Wood, Adjacent	R=11.0, 270.0 ft <sup>2</sup>	15. HVAC credits	PT,
c. N/A		(CF-Coiling fan, CV-Cross ventilation,	
d. N/A		HF-Whole house fan,	
e. N/A		PT-Programmable Thermostat,	
10. Ceiling types		MZ-C-Multizone cooling,	
a. Under Attic	R=30.0, 2186.9 ft <sup>2</sup>	MZ-H-Multizone heating)	
b. N/A			
c. N/A			
11. Ducts			
a. Sup: Unc. Ret: Unc. AH: Garage	Sup. R=6.0, 145.0 ft		
b. N/A			

I certify that this home has complied with the Florida Energy Efficiency Code For Building Construction through the above energy saving features which will be installed (or exceeded) in this home before final inspection. Otherwise, a new EPL Display Card will be completed based on installed Code compliant features.

Builder Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Address of New Home: \_\_\_\_\_ City/FL Zip: \_\_\_\_\_



*\*NOTE: The home's estimated energy performance score is only available through the FLA/RES computer program. This is not a Building Energy Rating. If your score is 80 or greater (or 86 for a US EPA/DOE EnergyStar<sup>®</sup> designation), your home may qualify for energy efficiency mortgage (EEM) incentives if you obtain a Florida Energy Gauge Rating. Contact the Energy Gauge Hotline at 321/638-1492 or see the Energy Gauge web site at [www.fsec.ucf.edu](http://www.fsec.ucf.edu) for information and a list of certified Raters. For information about Florida's Energy Efficiency Code For Building Construction, contact the Department of Community Affairs at 850/487-1824.*

EnergyGauge<sup>®</sup> (Version: FLRCSB v3.30)



# Notice of Treatment

10964

**Applicator** Florida Pest Control & Chemical Co.

**Address** 536 SE Bay

**City** Lake City

**Phone** 752-1703

**Site Location**

**Subdivision** W Meadow Vista

**Lot#** 5

**Block#**

**Permit#** 22089

**Address** 219 Swfantasie Ct

## AREAS TREATED

**Print Technician's**

Area Treated	Date	Time	Gal.	Name
Main Body	7/26/04	200	500	TRAVIS
Patio/s #				
Stoop/s #				
Porch/s #				
Brick Veneer				
Extension Walls				
A/C Pad				
Walk/s #				
Exterior of Foundation				
Driveway Apron				
Out Building				
Tub Trap/s				
(Other)				

**Name of Product Applied** DW SPANTIC

.5 %

**Remarks**



**RECEIVED**  
11-15-04  
G

**COLUMBIA COUNTY**  
**OFFICE OF THE**  
**CLERK OF THE COUNTY**

# OCCUPANCY

**COLUMBIA COUNTY, FLORIDA**

## Department of Building and Zoning Inspection

This Certificate of Occupancy is issued to the below named permit holder for the building and premises at the below named location, and certifies that the work has been completed in accordance with the Columbia County Building Code.

Parcel Number 16-4S-16-03025-105

Building permit No. 000022089

Use Classification SFD, UTILITY

Fire: 62.37

Permit Holder STANLEY CRAWFORD

Waste: 134.75

Owner of Building STANLEY CRAWFORD

Total: 197.12

Location: 219 SW FANTASY GLEN

Date: 10/29/2004

*Stacy Dicker*

Building Inspector



**POST IN A CONSPICUOUS PLACE**  
*(Business Places Only)*