



Britt Surveying and Mapping, LLC
1438 SW Main Blvd • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

10/18/2022

Permit # 000045324 & 000045325

L-29016


Re: Lot 36 Bluebird Reserve

Mike Hartzog

To Whom It May Concern:

The finished floor elevation on Lot 36 is found to be 48.54 feet. The minimum floor elevation is determined to be 49.5 feet per the building permit. All elevations are shown are based on NAVD 88 datum.

Sincerely,



L. Scott Britt

LS 5757