



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM  
CONSTRUCTION INSPECTION AND FINAL APPROVAL

APPLICATION #: AP2039674  
PERMIT #: 12-SC-2850326  
DOCUMENT #: F12210993  
DATE PAID: 02/13/2024  
FEE PAID: 205.00  
RECEIPT #: 12-PID-6639232

APPLICANT: WILLIAM\*\*24-0134 HOLLAND

AGENT: Robert Ford III (North Florida Septic Tank, Inc.)

PROPERTY ADDRESS: 127 SE HAVEN Lake City, FL 32025

LOT: 83

BLOCK:

SUBDIVISION: Ebenezer Haven ID#: 10519-108

CHECKED [X] ITEMS ARE NOT IN COMPLIANCE WITH STATUTE OR RULE AND MUST BE CORRECTED.

TANK INSTALLATION

[IN] [01] TANK SIZE [1] 900.00 [2] Concrete  
[IN] [02] TANK MATERIAL Concrete  
[IN] [03] OUTLET DEVICE  
[IN] [04] MULTI-CHAMBERED [ Y / N ]  
[N/] [05] OUTLET FILTER  
[IN] [06] LEGEND 1. Unknown 2.  
[IN] [07] WATERTIGHT  
[IN] [08] LEVEL  
[IN] [09] DEPTH TO LID

DRAINFIELD INSTALLATION

[IN] [10] AREA [1] 225 [2] 275 SQFT  
[IN] [11] DISTRIBUTION BOX HEADER X  
[IN] [12] NUMBER OF DRAINLINES 1. 3.00 2.  
[IN] [13] DRAINLINE SEPARATION  
[IN] [14] DRAINLINE SLOPE  
[IN] [15] DEPTH OF COVER  
[IN] [16] ELEVATION [ ABOVE / BELOW ] BM 22.00  
[IN] [17] SYSTEM LOCATION  
[N/] [18] DOSING PUMPS  
[N/] [19] AGGREGATE SIZE  
[N/A] [20] AGGREGATE EXCESSIVE FINES  
[N/] [21] AGGREGATE DEPTH

FILL / EXCAVATION MATERIAL

[IN] [22] FILL AMOUNT  
[IN] [23] FILL TEXTURE  
[N/] [24] EXCAVATION DEPTH  
[N/] [25] AREA REPLACED  
[N/] [26] REPLACEMENT MATERIAL

SETBACKS

[N/] [27] SURFACE WATER FT  
[IN] [28] DITCHES 100+ FT  
[N/] [29] PRIVATE WELLS FT  
[N/] [30] PUBLIC WELLS FT  
[N/] [31] IRRIGATION WELLS FT  
[IN] [32] POTABLE WATER 20 FT  
[IN] [33] BUILDING FOUNDATIONS 20 FT  
[IN] [34] PROPERTY LINES 50 FT  
[N/] [35] OTHER FT

FILLED / MOUND SYSTEM

[ ] [36] DRAINFIELD COVER  
[ ] [37] SHOULDERS  
[ ] [38] SLOPES  
[ ] [39] STABILIZATION

ADDITIONAL INFORMATION

[IN] [40] UNOBSTRUCTED AREA  
[IN] [41] STORMWATER RUNOFF  
[N/] [42] ALARMS  
[N/] [43] MAINTENANCE AGREEMENT  
[IN] [44] BUILDING AREA  
[IN] [45] LOCATION CONFORMS WITH SITE PLAN  
[IN] [46] FINAL SITE GRADING  
[IN] [47] CONTRACTOR Robert Ford (North Florida Se  
[IN] [48] OTHER INFILTRATOR ARC 24

ABANDONMENT

[N/] [49] TANK PUMPED  
[N/] [50] TANK CRUSHED & FILLED

Comments: Comments are on page 2.

CONSTRUCTION [ APPROVED ] / DISAPPROVED [ ]: Columbia CHD  
Environmental Specialist I Sean P Havens (Florida Department of Health)

FINAL SYSTEM [ APPROVED ] / DISAPPROVED [ ]: Columbia CHD

(Explanation of Violations on following page)

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)  
Incorporated: 64E-6.003, FAC

EH Database v 1.0.1

AP2039674

EID2850326

Page 2 of 3

KR

DATE: 04/16/2024

DATE: 5/24/24