



37800

Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

03/15/19

L-25721

Re: Lot 13 Hunnington Place Phase 1, AKA 14-4S-16-02973-113

Adams Construction

To Whom It May Concern:

The top of the finished floor elevation is found to be 100.78 feet on said lot 13. The minimum floor elevation per the letter provided by David Winsberg, P.E. is 97.50 feet. The elevations shown hereon are based on plat datum (NGVD 29).

Sincerely,

L. Scott Britt
LS 5757